

Bangalore Electricity Supply Company Limited

Reliability Index For FY 10-11

Sl.No	Name of the Town/city	SAIFI for feeder	SAIDI for feeder	Reliability Index for feeder	SAIDI for consumer	Reliability Index for consumer
1	Davangere	764	113360	78.43	86905	83.47
2	Harihara	19569	193594	63.17	202303	61.51
3	Chitradurga	585	226126	56.98	205779	60.85
4	Hiriyur	325	97144	81.52	84389	83.94
5	Kolar	155	5618	98.93	5728	98.91
6	Chintamani	161	5689	98.92	5606	98.93
7	KGF	217	7715	98.53	7911	98.49
8	C.B.Pura	165	5991	98.86	4900	99.07
9	Nelmangala	193	6173	98.83	6895	98.69
10	Ramnagar	142	2930	99.44	5245	99.00
11	Chandapura	139	4698	99.11	6364	98.79
12	Yelhanka	103	3604	99.31	5927	98.87
13	Bangalore City	87	3241	99.38	3145	99.40
14	Tumkur	456	164093	68.78	146020	72.22
15	Tiptur	206	197883	62.35	202799	61.42
16	Madhugiri	157	199427	62.06	194820	62.93