

Bangalore Electricity Supply Company Limited

Reliability Index For FY 11-12

Sl.No	Name of the Town/city	SAIFI for feeder	SAIDI for feeder	Reliability Index for feeder	SAIDI for consumer	Reliability Index for consumer
1	Davangere	446	65311	87.57	51252	90.25
2	Harihara	170	122155	76.76	111325	78.82
3	Chitradurga	375	174948	66.71	144768	72.46
4	Hiriyur	263	12499	97.62	11737	97.77
5	Kolar	13675	5177	99.02	5064	99.04
6	Chintamani	141	5382	98.98	5440	98.97
7	KGF	235	6918	98.68	6791	98.71
8	C.B.Pura	157	3918	99.25	3891	99.26
9	Nelmangala	175	3197	99.39	3882	99.26
10	Ramnagar	236	3543	99.33	4356	99.17
11	Chandapura	140	3843	99.27	5147	99.02
12	Yelhanka	91	2490	99.53	5380	98.98
13	Bangalore City	84	597	99.89	759	99.86
14	Tumkur	1307	122566	76.68	107617	79.52
15	Tiptur	105	158977	69.75	171799	67.31
16	Madhugiri	1250	140283	73.31	142047	72.97