

Bangalore Electricity Supply Company Limited

Reliability Index For FY 12-13

Sl.No	Name of the Town/city	SAIFI for feeder	SAIDI for feeder	Reliability Index for feeder	SAIDI for consumer	Reliability Index for consumer
1	Davangere	531.92	46963.62	91.06	32585.44	93.80
2	Harihara	205.91	88672.61	83.13	79803.01	84.82
3	Chitradurga	387.13	37830.78	92.80	25163.36	95.21
4	Hiriyur	623.27	36110.93	93.13	43537.24	91.72
5	Kolar	222.29	5628.37	98.93	4367.65	99.17
6	Chintamani	437.70	14706.20	97.20	140982.51	73.18
7	KGF	212.94	7712.38	98.53	6516.62	98.76
8	C.B.Pura	148.54	3701.13	99.30	28919.90	94.50
9	Nelmangala	157.93	2446.56	99.53	4465.59	99.15
10	Ramnagar	161.88	3107.10	99.41	4371.52	99.17
11	Chandapura	110.87	3153.12	99.40	4582.25	99.13
12	Yelhanka	231.78	7650.53	98.54	7748.65	98.53
13	Bangalore City	107.50	3071.47	99.96	3941.65	99.95
14	Tumkur	267.50	24036.62	95.43	27033.31	94.86
15	Tiptur	1203.20	50030.40	90.48	58068.55	88.95
16	Madhugiri	575.60	40711.20	92.25	28947.39	94.49