

Bangalore Electricity Supply Company Limited

Reliability Index For FY 13-14

Sl.No	Name of the Town/city	SAIFI for feeder	SAIDI for feeder	Reliability Index for feeder	SAIDI for consumer	Reliability Index for consumer
1	Davangere	531.92	46963.62	91.06	32585.44	93.80
2	Harihara	378.07	23417.82	95.54	22878.36	95.65
3	Chitradurga	905.04	21855.74	95.84	22291.93	95.76
4	Hiriyur	298.38	39579.13	92.47	55664.70	89.41
5	Kolar	176.85	4724.55	99.10	3360.53	99.36
6	Chintamani	470.10	9532.50	98.19	105228.94	79.98
7	KGF	221.05	5710.06	98.91	5315.71	98.99
8	C.B.Pura	168.12	3434.02	99.35	2767.61	99.47
9	Nelmangala	162.10	26502.04	94.96	4249.28	99.19
10	Ramnagar	167.51	2787.75	99.47	4299.78	99.18
11	Chandapura	137.21	3750.17	99.29	4194.44	99.20
12	Yelhanka	265.08	6329.51	98.80	5324.87	98.99
13	Bangalore City	135.90	3596.29	99.32	4411.14	99.16
14	Tumkur	662.44	98048.06	81.35	94727.94	81.98
15	Tiptur	801.00	24972.00	95.25	26266.13	95.00
16	Madhugiri	510.50	29136.80	94.46	33578.25	93.61