

Bangalore Electricity Supply Company Limited
Reliability Index For FY14-15

Sl.No	Name of the Town/city	SAIFI for feeder	SAIDI for feeder	Reliability Index for feeder	SAIDI for consumer	Reliability Index for consumer
1	Davanagere	571	21359	95.94	16460	96.87
2	Harihara	500	24414	95.35	23408.35	95.55
3	Chitradurga	458	30004	94.29	41078	92.18
4	Hiriyuru	892	27337	94.80	27176.99	94.83
5	Kolar	129	92	99.98	99	99.98
6	Chintamani	193	128	99.98	128	99.98
7	KGF	219	178	99.97	182	99.97
8	C.B.Pura	153	63	99.99	63	99.99
9	Nelamangala	181	3276	99.38	4119	99.22
10	Ramnagar	497	9558	98.18	8839	98.32
11	Chandapura	289	10398	98.02	15612	97.03
12	Yelahanka	533	15119	97.12	15901	96.97
13	Bangalore City	190	4282	99.19	5284	98.99
14	Tumkur	472	27440	94.78	26129	95.03
15	Tiptur	690	46459	91.16	47022	91.05
16	Madhugiri	233	14967	97.15	15152	97.12