

Bangalore Electricity Supply Company Limited

Reliability Index and SAIDI SAIFI For FY 16-17

Sl.No	Name of the Town/city	SAIFI for feeder	SAIDI for feeder	Reliability Index of 11KV feeder	SAIDI for consumer	Reliability Index for consumer
1	Davanagere	472.09	19468.67	96.83	16672.02	96.83
2	Harihara	318.82	12301.25	97.66	11686.25	97.78
3	Chitradurga	500.77	28678.10	94.54	28155.83	94.64
4	Hiriyuru	319.75	12973.20	97.53	12352.30	97.65
5	Kolar	110.01	488.43	99.91	379.06	99.93
6	KGF	260.76	338.04	99.94	274.34	99.95
7	CB Pura	336.27	593.73	99.89	653.95	99.88
8	Chintamani	199.68	142.12	99.97	154.15	99.97
9	Nelamangala	340.67	5916.87	98.87	5071.94	99.04
10	Hosakote	520.21	29038.57	94.48	23049.70	95.61
11	Ramanagara	349.57	8383.01	99.88	5013.38	99.05
12	Chandapura	252.16	8219.00	98.43	14279.93	97.28
13	Kanakapura	427.39	23895.38	95.45	27113.10	94.84
14	Bangalore City	165.27	5353.14	98.98	6157.48	98.83
15	Tumkur	160.12	40325.52	92.33	42075.95	91.99
16	Tiptur	745.10	25730.72	99.86	25686.45	95.11
17	Madhugiri	298.64	19892.22	96.22	20593.30	96.08