

Compact Sub Station

Sl. No.	Name of the firm	Approved Material	Valid upto	O.M.No. & Date	Revalidated upto
1	M/s Schneider Electric Infrastructure Ltd., Milestone -87, Vadodara - Halol Highway village, Kotambi, O.O. Jarod, Taluk Kavat, Dist. Vadodara, Gujarat, E-mail: www.scheider-electric.co.in Ph No:9741312002	11/0.433kV, prefabricated/ Packaged Sub Station(PSS) with LV Switchgear and transformer rating upto 1000kVA	27.02.2021	GM(Q,S&S)/DGM-3/BC-11/19- 20/CYS-217 dtd:04.03.2020	
2	M/s C & S Electric Limited., 26A, Sector-31, Surajpur industrial Area, Kasna Road, Greater Noida- 201310 (U.P.) & Regd office: M/s C & S Electric Limited., 222,Okhla Industrial Estate, phase-III, New Delhi- 110020 Contact No:9900063038 (Tel: +91-11-03088 7520 -29) (E-mail: info@cselectric.co.in)	Compact Pre - fabricated Packaged Sub -Station 11kv/433V consisting of 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amorphous Core Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following outgoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer Make: M/s NGG Power Tech India Pvt Ltd. of rating 1000kVA Distribution Transformer only (with duly valid vendor approval of BESCO)	20.06.2021	GM(Q,S&S)/DGM-3/BC-11/20- 21/CYS-51 dtd:23.06.2020	
3	M/s Transgear Power Systems Private Limited, Sy No: 49/9, Site No:50A and 50B, 1st Cross, 8th Main, SLV Industrial Estate, Peenya 2nd Stage, Bengaluru Ph No: 9731604488/9731564488 Email: rajju@tgps.in/ santhosh@tgps.in	COMPACT PRE - FABRICATED PACKAGED SUB - STATION as per IEC-60694/IS-3427 Compact Pre - fabricated Packaged Sub-Station Indoor /Outdoor 11kV/ 433V consisting 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amorphous Core, Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following outgoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer Make: M/s Vijay Electric Co.of rating upto 1000kVA/from any BESCO Approved Vendor suitable for CSS.	01.01.2022	GM(Q,S&S)/DGM-3/BC-11/20- 21/CYS-296 dtd:31.03.2021	