



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/

Encl:

O/o GM (QS&S)

Corporate Office, K.R. Circle

Bangalore-560 001

Date: 02 MAR 2024

OFFICIAL MEMORANDUM

Sub : Vendor approval for supply of 12kV, 630A, 21kA, SF6 Ring Main Unit by M/s Lucy Electric India Pvt Ltd, Nashik.

Ref : 1. Firm letter No: BESCOM/12kV/RMU/2022/010 dtd: 22.11.2022.
2. Approved by Director (Technical), BESCOM vide para (84)/3532 dated: 01.03.2024 of T.O note no: GM (QS&S)/DGM-3/BC-11/23-24/2842 dated: 01.03.2024


Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.

| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|--|---|-------------------------|
| 1 | M/s Lucy Electric India Pvt Ltd. H-21, MIDC Ambad, Nashik - 422010, Maharashtra E-mail: Sales-IN- NSK@lucyelectric.com Ph No: 91 253 2381603/ 2387139/ 9731604488 | 12kV, 630A, 21kA, SF6 Ring Main Unit (DAS & Non DAS RMU) (Type: Aegis Model) The DAS RMUs shall have the following in addition to the Standards: <ul style="list-style-type: none">➤ DC motors, numerical Relays, Multi-functional meters, fault passage indicator (FPI), Metering CTs, Protection CTs, Auxiliary transformers, Potential transformer, Batteries, Battery chargers (12V & 24V), AC power socket and light for illumination of Control panel.➤ Control cable from each panel shall be wired and terminated to suitable 24 pin connectors in the control panel.➤ Suitable space for fixing the Remote Terminal Unit (RTU) and Radio Modem in Control panel.➤ Suitable clamps for fixing Antenna Pipe.➤ The Openings between feeder and control cabinet compartment shall be made vermin proof.➤ Antenna fixing clamps and antenna cable holes are to be provided.➤ Provision for handle & Padlock, a number lock of adequate size shall be provided to the RTU cabinet. | 01.03.2025 |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.
7. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete. Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. All the field officers shall procure only DAS RMUs for all the works including service connection and Self-execution of work in BMAZ area as per circular No. BESCOM/GM (DAS&SG)/DGM2 (DAS)/BC-46/2012-13/CYS-02 Dated 23.11.2012.
10. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
11. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore
2. All the Chief Engineer (Electy.,) O&M Zones, BESCOM.
3. The General Manager (El.) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s Lucy Electric India Pvt Ltd. H-21, MIDC Ambad, Nashik - 422010, Maharashtra
8. Office copy/M.F.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM (QS&S)/DGM-3/AE/BC-11/23-24/

Encl:

O/o GM (QS&S)

Corporate Office

K R Circle, BESCOM

Bangalore-560 001

Date: 02 MAR 2024

CYS-208

OFFICIAL MEMORANDUM

Sub : Vendor approval to M/s Lucy Electric India Pvt Ltd, Nashik for supply of RTU make Gemini 4.

Ref : 1. Firm Letter No: BESCOM/Gemini/RTU/2022/02 dated: 18.11.2022, 05.12.2022 & 27.02.2024.

2. Approved by Director (Technical) vide para (51)/3553 dated: 01.03.2024 of T.O Note No: GM(QS&S)/DGM-3/AE/BC-11/23-24/2843 dated: 01.03.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.


| Sl. No. | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|---------|---|---------------------|-------------------------|
| 1. | M/s Lucy Electric India Pvt Ltd. H-21, MIDC Ambad, Nashik - 422010, Maharashtra E-mail: Sales-IN-NSK@lucyelectric.com Ph No: 91 253 2381603/ 2387139/ 9731604488 | RTU make Gemini 4 | 01.09.2024 |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.

7. BESCO reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCO authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCO reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCO projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete. Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. The following Observations made by GM(DAS) shall be attended before supplies are made
- In future if any observation identified at the time of integration of RTU with DAS control center shall be attended.
 - The RTU should be compatible with all makes of DAS RMU in the network. The MODBUS communication configuration with different makes of DAS RMU and integration of these RTU with DAS RMU will be the responsibility of the vendor. The sets with loaded firmware to be provided to BESCO at the time of integration of RTUs.
 - IP 54 test report shall be submitted before 01.09.2024.
10. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
11. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.,)
Quality Standards and Safety,
BESCO.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCO, Bangalore
2. All the Chief Engineer (Electy.,) O&M Zones, BESCO.
3. The General Manager (El.,) Procurement / DAS, BESCO.
4. All Superintending Engineers (El.,) O&M Circle, BESCO.
5. All Executive Engineers (Ele.) O&M Divisions, BESCO.
6. PS to D (T) to place it before Director (Technical), BESCO.
7. M/s Lucy Electric India Pvt Ltd. H-21, MIDC Ambad, Nashik – 422010, Maharashtra
8. Office copy/M.F.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/ | CYS-209

Encl:

O/o GM (QS&S)

Corporate Office,

K.R. Circle

Bangalore-560 001

Date: 05 MAR 2024

OFFICIAL MEMORANDUM

Sub : Renewal of Vendor approval to M/s Macro Power Controls, Bangalore for supply of 63kVA EEL-1(1 star rated) Distribution Transformer as per Amendment 4 of IS-1180.

Ref : 1. Firm Letter dated: 27.02.2024.

2. Approved by Director (Technical) vide para (26)/3523 dtd: 29.02.2024 of T.O Note No: GM (QS&S)/DGM-3/AE/BC-11/2324/2817 dtd: 29.02.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.


| Sl No | Name of the Firm/ Address/ Contact details | Equipment/Materials | Period of validity upto |
|-------|--|--|--|
| 1 | M/s Macro Power Controls, No.24, 2 nd cross, Kadabagere cross, Magadi Main Road, Behind Bus Stop, Bangalore - 560091. E-mail: dmacropower@yahoo.in Ph:8792708263/8792708264/8792708267/8861954803 | 63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. | 03.01.2029 Subject to revalidation once in 2 years from the date of issue of this OM |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.
7. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.

8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does it absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete. Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore.
2. All the Chief Engineer(Electy.,) O&M Zones, BESCOM.
3. The General Manager (El.) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s Macro Power Controls, No.24, 2nd cross, Kadabagere cross, Magadi Main Road, Behind Bus Stop, Bangalore-560091.
8. Office copy / M.F



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-210

Encl:

O/o GM (QS&S)

Corporate Office,

K.R. Circle

Bangalore-560 001

Date: 05 MAR 2024

OFFICIAL MEMORANDUM

Sub : Renewal of Vendor approval to M/s V.T. Switchgears & Transformers, Bangalore for supply of 100kVA & 250kVA EEL-2 (2 star rated) Distribution Transformer as per Amendment 4 of IS-1180.

Ref : 1. Firm Letter dated: 19.01.2024 & 28.02.2024.
2. Approved by Director (Technical) vide para (21)/3529 dtd: 29.02.2024 of T.O Note No: GM (QS&S)/DGM-3/AE/BC-11/23-24/2820 dtd: 29.02.2024.

Conditional approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.

| Sl. No | Name of the Firm/ Address/ Contact details | Equipment/Materials | Period of validity upto |
|--------|---|---|-------------------------|
| 1 | M/s V.T. Switchgears and Transformers, No: 33, 3rd Phase, 4th Main, Peenya Industrial Area, Bangalore - 560058 Ph No: 9844028978 E-mail: vtsbg@gmail.com/city@vtst.in | 100kVA,EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. | 02.06.2024 |
| 2 | | 250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. | |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. The firm shall submit all the balance type tests reports for the above mention materials as per IS/IEC/BESCOM specification before 02.06.2024 for further needful.
5. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
6. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
7. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.

8. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.
9. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete.
- Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
10. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
11. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore.
2. All the Chief Engineer(Electy.,) O&M Zones, BESCOM.
3. The General Manager (El.) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s V.T. Switchgears and Transformers, No: 33, 3rd Phase, 4th Main, Peenya Industrial Area, Bangalore – 560058
8. Office copy / M.F



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM (QS&S)/DGM-3/AE/BC-11/23-24/ | CYS-211

Encl:

O/o GM (QS&S)

Corporate Office

K R Circle, BESCOM
Bangalore-560 001

Date: 05 MAR 2024

OFFICIAL MEMORANDUM

Sub : Vendor approval to M/s Mysore Electrical Industries Limited, Bangalore for supply of 11kV, HT Metering Cubicle (3CT, 3PT).

Ref : 1. Firm Letter No: MEI/MKTG/DGM/2022-23/26/9357 dtd: 08.09.2022 & 13.01.2024.

2. Approved by Director (Technical) vide para (34)/3505 dtd: 28.02.2024 of T.O Note No: BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/2799 dtd: 27.02.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.

| Sl No | Name of the Firm/ Address/Contact details | Equipment/ Materials | Period of validity upto |
|-------|--|--|----------------------------|
| 1 | M/s Mysore Electrical Industries Limited., Post Box No: 2221, Tumkur Road, Yeshwanthpur, Bengaluru - 560022 Ph No: 91-080-23376851 E-mail: meimd@rediffmail.com, mei.matls9@gmail.com/ meimktg@rediffmail.com | 11kV, HT Metering Cubicle (3CT, 3PT) 3phase, 4Wire | 04.03.2025 |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.

7. BESCO reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCO authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCO reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCO projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete. Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCO.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCO, Bangalore.
2. All the Chief Engineer(Electy.,) O&M Zones, BESCO.
3. The General Manager (El.) Procurement / DAS, BESCO.
4. All Superintending Engineers (El.), O&M Circle, BESCO.
5. All Executive Engineers (Ele.) O&M Divisions, BESCO.
6. PS to D (T) to place it before Director (Technical), BESCO.
7. M/s Mysore Electrical Industries Limited., Post Box No: 2221, Tumkur Road, Yeshwanthp
Bengaluru - 560022.
8. Office copy / M.F.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(Q, S&S)/DGM-3/AE/BC-11/23-24/

Encl:

O/o GM(QS&S)

Corporate Office, K.R. Circle

Bangalore-560 001

Date:

05 MAR 2024

OFFICIAL MEMORANDUM

Sub : Vendor approval for supply of LT/HT Line Hardware & Structural Materials by M/s Shayan Industries, Gauribidanur.

Ref : 1. Firm letter dtd: 31.08.2023 & 15.02.2024.

2. Approved by Director (Technical), BESCOM vide para (31)/3509 dated: 28.02.2024 of T.O note no: GM (QS&S)/DGM-3/AE/BC-11/2023-24/2809 dated: 28.02.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following materials to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.

| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|---|---|-------------------------|
| 1 | M/s Shayan Industries, KV KPTCL Power Station, BHD 440, M G Road, Gauribidanur, SIDCO Industrial Estate, Gowribidanur, - 561208 Ph No: 9141488898, 8155286436, 9164906043 E-mail: anju.anjan77@gmail.com , shayanindustries007@gmail.com | 11 kV Horizontal Cross Arm | 04.03.2025 |
| 2 | | 4 Pin and 2 Pin Cross Arms | |
| 3 | | Clamps for RCC/ PSCC poles | |
| 4 | | Guy set (Insulator & GI Wire has to be purchased by BESCOM approved vendors) | |
| 5 | | Single Pole Mounted Transformer Kit for erection of Transformers on 11Mtr Spun Pole | |
| 6 | | SPMT Materials for erection of transformers of 25/63kVA on 9mtr RCC/PSCC pole | |
| 7 | | Double pole TC sets for erection of transformers of 25/63/100 & 100/300kVA on RCC/PSCC Poles | |
| 8 | | 11kV DP set | |
| 9 | | LT/HT single top support | |
| 10 | | Pole clamp for HT/LT AB cable | |
| 11 | | Fish plate | |
| 12 | | 11kV Special 3 pin cross arm | |
| 13 | | Alkathine tube | |
| 14 | | Spiral Earth Electrode | |
| 15 | | GI Grounding Pipe B-class, 42mm Dia, 2.5mtrs long, 3.2mm thick with bolts & nuts, GI strip & washers complete | |
| 16 | | 11kV 200A Single Break GOS (Using Ceramic Insulator) | |
| 17 | | 11kV HG Fuse Unit | |
| 18 | | LT Protection kit | |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.

2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.
7. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent t approval of incorrect drawings are obsolete.
Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore
2. All the Chief Engineer (Electy.,) O&M Zones, BESCOM.
3. The General Manager (El.) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s Shayan Industries, KV KPTCL Power Station, BHD 440, M G Road, Gauribidanur, SIDCO Industrial Estate, Gowribidanur - 561208
8. Office copy / M.F.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(Q, S&S)/DGM-3/AE/BC-11/23-24/

Encl:

O/o GM(QS&S)

Corporate Office, K.R. Circle

Bangalore-560 001

Date:

13 MAR 2024

OFFICIAL MEMORANDUM

Sub : Vendor approval for supply of LT/HT Line Hardware & Structural Materials by M/s Sri Kamakshi Electricals, Bangalore

Ref : 1. Firm letter dtd: 05.01.2024.

2. Approved by Director (Technical), BESCOM vide para (23)/3592 dated: 05.03.2024 of T.O note no: GM (QS&S)/DGM-3/AE/BC-11/2023-24/2886 dated: 05.03.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following materials to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.


| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|---|---|-------------------------|
| 1 | M/s Sri Kamakshi Electricals, Near Vishwapragna School, Ground Floor, Sy No.114/1, Gidadapalya Village, Yalachaguppe, Bangalore - 562130 Ph No: 9916510416/9900800939 E-mail: srikamakshielectricals99@gmail.com | Double Pole TC sets for erection of transformers of 25/63/100kVA & 100/300kVA on RCC/ PSCC 9Mtr pole as per IS - 1977 | 12.03.2025 |
| 2 | | 11kV DP set | |
| 3 | | Single Pole Mounted Transformer (SPMT) Kit for erection of Transformer on 11Mtr Spun Pole as per IS-1977 | |
| 4 | | Single Pole Mounted Transformer (SPMT) Kit for erection on 9M Square section RCC/PSCC 9M Long Pole as per IS - 1977 | |
| 5 | | 11kV Horizontal Cross Arm | |
| 6 | | G I Grounding Pipe B-class, 42mm Dia, 2.5mtrs long, 3.2mm thick with bolts & nuts, GI strip & washers complete | |
| 7 | | Anchor Rod | |
| 8 | | RCC/PSCC Pole | |
| 9 | | LT/HT single top support | |
| 10 | | 4 Pin and 2 Pin Cross Arms | |
| 11 | | Spiral Earth Electrode | |
| 12 | | Guy set (Insulator & GI Wire has to be purchased by BESCOM approved vendors) | |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.

2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.
7. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete.
Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore
2. All the Chief Engineer (Electy.,) O&M Zones, BESCOM.
3. The General Manager (El.) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s Sri Kamakshi Electricals, Near Vishwapragna School, Ground Floor, Sy No.114/1, Gidadapalya Village, Yalachaguppe, Bangalore - 562130.
8. Office copy / M.F.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(Q, S&S)/DGM-3/AE/BC-11/23-24/

Encl:

O/o GM(QS&S)

Corporate Office, K.R. Circle

Bangalore-560 001

Date: 18 MAR 2024

CYS-214

OFFICIAL MEMORANDUM

Sub : Renewal of vendor approval for supply of LT/HT Line Hardware & Structural Materials by M/s S.H.S Engineers, Bangalore.

Ref : 1. Firm letter No: S.H.S/7676/2023-24 dtd: 09.05.2023 & 19.02.2024.

2. Approved by Director (Technical), BESCOM vide para (37)/3580 dated: 04.03.2024 of T.O note no: GM (QS&S)/DGM-3/AE/BC-11/2023-24/2868 dated: 04.03.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following materials to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.

| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|---|--|-------------------------|
| 1 | M/s S.H.S Engineers, No: 43/4, Thirumenahalli, Behind KNS College, Jakkuru Post, Yelahanka, Bangalore- 560 064 Ph No: 6360219656/9141731337/ 9845756878 E-mail: haleemasadiya1313@gmail.com / sadiqspl2007@yahoo.co.in | 11kV Horizontal cross arm | 15.03.2026 |
| 2 | | 11kV Special 3 Pin Cross Arms | |
| 3 | | 2 Pin & 4 Pin cross Arm | |
| 4 | | LT & HT single top support | |
| 5 | | Earth Guard Stirrup | |
| 6 | | Spiral Earth Electrode | |
| 7 | | Anti Climbing Device | |
| 8 | | Clamps for PSCC/RCC poles | |
| 9 | | Guy set (Insulator & GI wire has to be purchased by BESCOM approved Vendors) | |
| 10 | | Anchor Rod | |
| 11 | | Fish plate | |
| 12 | | PG clamps | |
| 13 | | LT protection kit | |
| 14 | | Aluminium End terminal 10sq mm to 150sq mm | |
| 15 | | HG Fuse Unit | |
| 16 | | Heavy Duty Copper Terminals Long Barrel 25 sq mm to 400 sq mm | |
| 17 | | G I Grounding Pipe B-class, 42mm Dia, 2.5mtrs long, 3.2mm thick with bolts & nuts, GI strip & washers complete | |
| 18 | | SPMT Materials for erection of transformer on 25/63kVA on 9mtr RCC/PSCC pole | |

| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|--|---|-------------------------|
| 19 | M/s S.H.S Engineers, No: 43/6, Thirumenahalli, Behind KNS College, Jakkuru Post, Yelahanka, Bangalore- 560 064 Ph No: 6360219656/9141731337/ 9845756878 E-mail: haleemasadiya1313@gmail.com / sadiqspl2007@yahoo.co.in | Double Pole TC sets for erection of transformers of 25/63/ 100kVA & 100/300 kVA on RCC/PSCC 9Mtr pole | 15.03.2026 |
| 20 | | Single Pole Mounted Transformer Kit for erection of Transformers on 11Mtr Spun Poles | |
| 21 | | 3 GOS and 1 GOS Frame set for Spun pole with & without transformers seating | |
| 22 | | H - frame set | |
| 23 | | 11kV DOLO Cutout | |
| 24 | | Spacers for DTC Wiring | |
| 25 | | Pre - Insulated Lugs - CPTAU for 16 to 120 Sqmm | |
| 26 | | Tee - Connectors - KZ3 95 | |
| 27 | | End Cap for 50/70 Sqmm | |
| 28 | | Pole Clamp for HT/LT AB cables | |
| 29 | | 11kV 400A DB GOS(Ceramic) | |
| 30 | | 11kV 200A SB GOS(Ceramic) | |
| 31 | | Bolts & nuts & GI pins | |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCO Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCO approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCO before they are put into service.
7. BESCO reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCO authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCO reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCO projects, poor performance, poor after sales service, etc.

8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete.

Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.

9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.,)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore
2. All the Chief Engineer (Electy..) O&M Zones, BESCOM.
3. The General Manager (El.,) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s S.H.S Engineers, No: 43/4, Thirumenahalli, Behind KNS College, Jakkuru Post, Yelahanka, Bangalore- 560 064
8. Office copy / M.F.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(Q, S&S)/DGM-3/AE/BC-11/23-24/

Encl:

O/o GM(QS&S)

Corporate Office, K.R. Circle

Bangalore-560 001

Date: 18 MAR 2024

CYS-215

OFFICIAL MEMORANDUM

Sub : Vendor approval for supply of LT/HT Line Hardware & Structural Materials by M/s AMS Engineers, Bangalore.

Ref : 1. Firm letter No: AMS/1313/2023-24 dtd: 09.05.2023 & 19.02.2024.

2. Approved by Director (Technical), BESCOM vide para (36)/3548 dated: 01.03.2024 of T.O note no: GM (QS&S)/DGM-3/AE/BC-11/2023-24/2841 dated: 29.02.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following materials to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.

| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|--|---|-------------------------|
| 1 | M/s AMS Engineers, No: 43/6, Thirumenahalli, Behind KNS College, Jakkuru Post, Yelahanka, Bangalore- 560 064 Ph No: 7619190698/ 6360219656/9141731337/ 9845756878 E-mail: maroofasadath7676@gmail.com haleemasadiya1313@gmail.com/ sadiqspl2007@yahoo.co.in | 11kV Horizontal cross arm | 15.03.2025 |
| 2 | | 11kV Special 3 Pin Cross Arms | |
| 3 | | 2 Pin & 4 Pin cross Arm | |
| 4 | | LT & HT single top support | |
| 5 | | Earth Guard Stirrup | |
| 6 | | Spiral Earth Electrode | |
| 7 | | Anti-Climbing Device | |
| 8 | | Clamps for PSCC/RCC poles | |
| 9 | | Guy set (Insulator & GI wire has to be purchased by BESCOM approved Vendors) | |
| 10 | | Anchor Rod | |
| 11 | | Fish plate | |
| 12 | | PG clamps | |
| 13 | | LT protection kit | |
| 14 | | Aluminium End terminal 10sq mm to 150sq mm | |
| 15 | | HG Fuse Unit | |
| 16 | | SPMT Materials for erection of transformer on 25/63kVA on 9mtr RCC/PSCC pole | |
| 17 | | Double Pole TC sets for erection of transformers of 25/63/ 100kVA & 100/300 kVA on RCC/PSCC 9Mtr pole | |
| 18 | | Single Pole Mounted Transformer Kit for erection of Transformers on 11Mtr Spun Poles | |

| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|---|--|-------------------------|
| 19 | M/s AMS Engineers, No: 43/6, Thirumenahalli, Behind KNS College, Jakkuru Post, Yelahanka, Bangalore- 560 064 Ph No: 7619190698/ 6360219656/9141731337/ 9845756878 E-mail: maroofasadath7676@gmail.com haleemasadiya1313@gmail.com / sadiqspl2007@yahoo.co.in | 3 GOS and 1 GOS Frame set for Spun pole with & without transformers seating | 15.03.2025 |
| 20 | | H - frame set | |
| 21 | | 11kV DOLO Cutout | |
| 22 | | Spacers for DTC Wiring | |
| 23 | | Pre - Insulated Lugs - CPTAU for 16 to 120 Sqmm | |
| 24 | | Tee - Connectors - KZ3 95 | |
| 25 | | End Cap for 50/70 Sqmm | |
| 26 | | Pole Clamp for HT/LT AB cables | |
| 27 | | G I Grounding Pipe B-class, 42mm Dia, 2.5mtrs long, 3.2mm thick with bolts & nuts, GI strip & washers complete | |
| 28 | | Heavy Duty Copper Terminals Long Barrel 25 sq mm to 400 sq mm | |
| 29 | Bolts & nuts | | |


The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.
7. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete.

Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.

9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore
2. All the Chief Engineer (Electy.,) O&M Zones, BESCOM.
3. The General Manager (El.) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s AMS Engineers, No: 43/6, Thirumenhalli, Jakkuru Post, Yelahanka, Bangalore- 560 064
8. Office copy / M.F.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(QS&S)/DGM(EL.,)-3/AE/BC-11/2023-24/

Encl:

O/o GM(QS&S)

Corporate Office, K.R. Circle

Bangalore-560 001

Date: 18 MAR 2024

CYS-216

OFFICIAL MEMORANDUM

Sub : Renewal of vendor approval for supply of 8&9Mtr PSCC Poles-200kg WL, 9Mtr PSCC Poles-300kg WL, 8Mtr RCC pole -115kg WL & 9Mtr RCC pole-145kgs WL by M/s Shiva Concrete Products, Tumkur.

Ref : 1. Firm letter No: SCPT/Vendor/23-24 dtd: 21.02.2024.
2. Approved by Director (Technical), BESCOM, vide para(12)/3679 dated: 14.03.2024 & of T.O Note No: GM (QS&S)/DGM-3/ AE/BC-11/23-24/2946 dated: 14.03.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.


| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|--|---------------------------|--|
| 1 | M/s Shiva Concrete products, Sy No: 96 & 95/4, B.P. Road, Oorukere Village, Tumkur - 572106 Ph No:0816-2018038 Email:sbp.tumkur@gmail.com | 8Mtr PSCC pole - 200kg WL | 18.02.2029 Subject to revalidation once in 2 years from the date of issue of this OM |
| 2 | | 9Mtr PSCC pole - 200kg WL | |
| 3 | | 9Mtr PSCC pole - 300kg WL | |
| 4 | | 9Mtr RCC pole - 145kg WL | |
| 5 | | 8Mtr RCC pole - 115kg WL | |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.

7. BESCO reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCO authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCO reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCO projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete.
Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 month from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCO.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCO, Bangalore
2. All the Chief Engineer (Electy.,) O&M Zones, BESCO.
3. The General Manager (El.) Procurement / DAS, BESCO.
4. All Superintending Engineers (El.), O&M Circle, BESCO.
5. All Executive Engineers (Ele.) O&M Divisions, BESCO.
6. PS to D (T) to place it before Director (Technical), BESCO.
7. M/s Shiva Concrete products, Sy No:96 & 95/4 - B.P. Road - Oorukere Village, Tumkur - 572106.
8. Office copy / M.F.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/ | CYS-219

Encl:

O/o GM (QS&S)

Corporate Office, K.R. Circle

Bangalore-560 001

Date: 27 MAR 2024

OFFICIAL MEMORANDUM

Sub : Renewal of vendor approval to M/s Ampturn Electrical Products private Limited., Bangalore for supply of LT Current Transformer & LT Potential Transformer.

Ref : 1. Firm letter dtd: 01.03.2023 & 12.03.2024.

2. Approved by Director (Technical), BESCOM vide para (44)/3670 dated:13.03.2024 of T.O note no: BESCOM/GM (QS&S)/DGM-3/AE/BC-11/23-24/2937 dtd: 13.03.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.

| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|--|---|---|
| 1 | | LT Current Transformer, 3.75VA, Ring type as per IS-2705 Part- 1&2 | |
| A | M/s Ampturn Electrical Products Private Limited., 248/2, Tumkur Road, T Begur, Bangalore Rural, Karnataka - 562123 Contact No: 9513229302/ 9513229308 E-mail: info@ampturn.com | Tape insulated Ring type LT CT's of ratios 50/5A to 400/5A 0.5s class, accuracy | 12.12.2027 Subject to revalidation once in 2 years from the date of issue of this OM |
| B | | Moulded case, Ring type LT CT's of ratios 50/5A to 400/5A 0.5s class, accuracy | |
| C | | Resin cast, Ring type, LT CT's of ratios 50/1A to 250/1A, 0.2s accuracy | 17.08.2028 Subject to revalidation once in 2 years from the date of issue of this OM |
| D | | 440V/√3:110V/√3, single phase Voltage Transformer, Indoor, resin cast, 50Hz, 5VA, 0.2Accuracy | |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.

6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.
7. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete.
Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore
2. All the Chief Engineer (Electy.,) O&M Zones, BESCOM.
3. The General Manager (El.) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s Ampturn Electrical Products Private Limited., 248/2, Tumkur Road, T Begur, Bangalore Rural, Karnataka - 562123
8. Office copy / M.F.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(Q, S&S)/DGM-3/AE/BC-11/23-24/CYS-220

Encl:

O/o GM(QS&S)

Corporate Office, K.R. Circle

Bangalore-560 001

Date: 28.03.2024

OFFICIAL MEMORANDUM

- Sub : Renewal of Vendor approval for supply of LT/HT Line Hardware & Structural Materials by M/s Shubham Comtech & Exports Pvt Ltd., , Bangalore
- Ref : 1. Firm letter No: VA/C/22-23/BESCOM/998 dtd: 08.02.2023 & 06.03.2024.
2. Approved by Director (Technical), BESCOM vide para (21)/3651 dated: 12.03.2024 of T.O note no: GM (QS&S)/DGM-3/AE/BC-11/2023-24/2921 dated: 12.03.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following materials to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.


| Sl. No | Name of the Firm/ Address/Contact details | Equipment/Materials | Period of validity upto |
|--------|---|---|-------------------------|
| 1 | M/s Shubham Comtech & Exports Pvt Ltd., Factory Unit: 84 & 85, Bommasandra – Jigani Link Road, KIADB Jigani Indl. Area, Bangalore – 560105 Regd Office: 3 rd floor, No.1, Naaz Complex, 3 rd cross, N.R.Road, Bangalore, Ph No: 08110-415642 E-mail: polesshubham@yahoo.co.in | G I Grounding Pipe B-class, 42mm Dia, 2.5mtrs long, 3.2mm thick with bolts & nuts, GI strip & washers complete | 15.03.2026 |
| 2 | | 4 Pin and 2 Pin Cross Arms | |
| 3 | | RCC/PSCC Pole | |
| 4 | | Double Pole TC sets for erection of transformers of 25/63/100kVA & 100/300kVA on RCC/ PSCC 9Mtr pole as per IS - 1977 | |
| 5 | | Single Pole Mounted Transformer (SPMT) Kit for erection of Transformer on 11Mtr Spun Pole as per IS-1977 | |
| 6 | | Single Pole Mounted Transformer (SPMT) Kit for erection on 9M Square section RCC/PSCC 9M Long Pole as per IS - 1977 | |
| 7 | | 11kV Horizontal Cross Arm | |
| 8 | | LT/HT single top support | |

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.
2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.

6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.
7. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete.
Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.),
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore
2. All the Chief Engineer (Electy.) O&M Zones, BESCOM.
3. The General Manager (El.) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s Shubham Comtech & Exports Pvt Ltd.,
Factory Unit: 84 & 85, Bommasandra – Jigani Link Road, KIADB Jigani Indl. Area, Bangalore – 560105
Regd Office: 3rd floor, No.1, Naaz Complex, 3rd cross, N.R.Road, Bangalore,
8. Office copy / M.F.