

Distribution Transformers

Sl. No.	Name of the firm	Material Approved	Valid upto	O.M. No. & Date	Status of revalidation	
1	M/s Kailash Transformers Pvt Ltd., #23, KIADB, 1st stage, Kapnoor Industrial Area, Kalaburagi – 585 104 Ph No: (08472) 257449. E-mail: kailashpvttd1@gmail.com	25kVA, 63kVA & 100kVA, star1 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026. (EEL-1 as per new amendment 4 of IS-1180)	25.01.2027	BESCOM /GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-32 dtd:19.07.2022 (Subject to revalidation once in 2 years)		
		250kVA star2 rated(EEL-3/5 star), Distribution Transformers	12.03.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 18-19/Cys-165 dated:05.01.2019 (Subject to revalidation every year)	12.03.2023 GM(QS&S)/DGM-3/BC-11/20-21/CYS-75 dtd:27.08.2021	
		25kVA, 63kVA & 100kVA Star2 Rated (EEL-3/5star rated), Distribution Transformers, Amorphous Core	26.11.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-32 dated:02.06.2020 (Subject to revalidation every year)		
2	M/s Mahalakshmi Transformers, No. 16, 13th Cross, Kareemsaab Layout, Hegganahalli, Peenya 2nd Stage, Bangalore-91 Mob:9845862604 E-mail:mit_koparde@yahoo.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	30.03.2027	BESCOM /GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-77 dtd:05.11.2022 (subject to revalidation once in 2 years)		
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	19.04.2027			
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	07.04.2027			
		63kVA Star2 rated (EEL-3/5 star) Distribution Transformer, CRGO core	03.09.2023			03.09.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-54 dtd:04.08.2021
		100kVA Star2 rated (EEL-3/5 star) Distribution Transformer, CRGO core	23.08.2023			23.08.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-54 dtd:04.08.2021
		250kVA Star2 rated (EEL-3/5 star) Distribution Transformer, CRGO core	24.09.2023			24.09.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-54 dtd:04.08.2021
3	M/s Shridi sai Electricals limited., plot No: 13/82, Industrial estate, Kadapa Dist.,Andhra Pradesh	25kVA, 63kVA, 100kVA, 250kVA & 500kVA, Star2 Rated (EEL-3/5 star), Al. wound, Amorphous Core Distribution Transformers,	02.07.2023	GM(QS&S)DGM(EL.)-4/BC-11/ 17-18/Cys-306 dated:21.03.2018 (Subject to revalidation every year)	09.02.2022 GM(QS&S)/DGM(EL.)-3/BC-11/21-22/CYS-64 dtd: 17.08.2021	
					GM(QS&S)/DGM(EL.)-3/BC-11/21-22/CYS-64 dtd: 17.08.2021	
4	M/s Raikar Electric Company, No:20, Raghavendra Industrial Estate, Thigalarpalya Main Road, Near peenya 2nd stage, Bangalore - 560058. Ph No: 9845169654, 9535256093. E-mail:raikar.blr2000@gmail.com	25kVA, 63kVA & 100kVA BEE star 1 rated EEL-2 Distribution Transformers	20.03.2023	GM(QS&S)DGM(EL.)-4/BC-11/ 17-18/Cys-315 dated:27.03.2018 (Subject to revalidation every year)	20.03.2023 GM(QS&S)/AE/BC-11/ 21-22/Cys-141 dated:27.12.2021	
		63kVA & 100kVA Star2 Rated (EEL-3/5 star rated) Al wound, CRGO core, Distribution Transformers	12.03.2024	GM(QS&S)/AE/BC-11/ 21-22/Cys-141 dated:27.12.2021 (Subject to revalidation once in 2 years)		
		250kVA & 500kVA Star2 Rated (EEL-3/5 star rated) Al wound, CRGO core, Distribution Transformers	23.06.2025			
5	M/s Vijay Electric Co, #146/117/34/3, Kadabgere Village, Dasanapura Hobli, Bangalore - 562130 Ph:9886406701,9886606764, 080-22718017 E-mail:info@vijayelectric.com	25kVA, BEE star 1 rated, (EEL-2/4 star), Distribution Transformers	23.11.2022	GM(QS&S)DGM(EL.)-4/BC-11/ 17-18/Cys-214 dated:21.12.2017	23.11.2022 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-270 dtd:04.03.2021	
		63kVA, BEE star 1 rated, (EEL-2/4 star rated), Distribution Transformers	08.01.2023		08.01.2023 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-270 dtd:04.03.2021	
		100kVA, BEE star 1 rated, (EEL-2/4 star rated) Distribution Transformers	31.08.2022		31.08.2022 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-270 dtd:04.03.2021	
		25kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, CRGO Core, Aluminium Wound,	04.07.2024		04.03.2023 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-270 dtd:04.03.2021	
		63kVA, & 100kVA star 2 rated, (EEL-3/5star rated), Distribution Transformers	08.01.2023		08.01.2023 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-270 dtd:04.03.2021	
		250kVA, BEE star2 rated, (EEL-3/5star rated), Distribution Transformers	17.11.2022		17.11.2022 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-270 dtd:04.03.2021	
		500kVA BEE Star 2 Rated (EEL-3/5star rated), Distribution Transformers	23.02.2023		23.02.2023 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-270 dtd:04.03.2021	
		1000kVA star2 rated (EEL-3/5 star), CRGO core, Distribution Transformers,	23.08.2023		23.08.2023 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-270 dtd:04.03.2021	
	M/s Perfect Electricals, Plot No: 152, ...	25kVA star1 rated (EEL-2/4 star), Distribution Transformers	03.09.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 18-19/Cys-164 dated:01.01.2019 (Subject to revalidation every year)	03.09.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-294 dated:31.03.2021	
		63kVA & 100kVA star1 rated(EEL-2/4 star), Distribution Transformers	05.11.2023		05.11.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-294 dated:31.03.2021	
		500kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	26.12.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20 /Cys-221 dated:10.03.2020	30.03.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-294 dated:31.03.2021	

6	Sompura 1st stage, MALIB, Near Dabaspete, Nelamangala Taluk, Bangalore - 562111. Ph No:9845062309. E-mail: perfectswamy@yahoo.com	25kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled Distribution Transformers,	23.11.2025	GM(QS&S)/AE/BC-11/ 21-22 /Cys-133 dated:10.12.2021 (Subject to first revalidation dated before: 10.12.2022 and then it will be revalidated once in 2 years)	
		63kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers			
		100kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers	14.08.2026	GM(QS&S)/AE/BC-11/ 21-22 /Cys-133 dated:10.12.2021 (Subject to first revalidation dated before: 10.12.2022 and then it will be revalidated once in 2 years)	
7	M/s Primetech Transformers, Kuthanur Village, Calicut Road, Gundlupet Taluk, Gundlupet - 571111, Chamarajnaragar (Ph No:9242783800) (E-mail:roopacorporation@yahoo.com)	25kVA & 63kVA star1 rated (EEL-2/4 star), CRGO Core Distribution Transformers	14.08.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 18-19/Cys-173 dated:19.01.2019	16.04.2021 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-27 dated:29.05.2020
		100kVA star1 rated(EEL-2/4 star), CRGO core Distribution Transformers	06.03.2023		
8	M/s Vijay Power control systems, B-65 & P-16, 3 rd cross, 3 rd stage Peenya industrial Estate, Bangalore-560 058 Ph.info@vijaytransformers.com	63kVA, 100kVA & 250kVA star2 rated (EEL-3/5star rated), Distribution Transformers, CRGO Core	16.08.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 18-19/Cys-189 dated:11.02.2019 (Subject to revalidation every year)	
		500kVA star2 rated (EEL-3/5star rated),Distribution Transformers, CRGO Core,	20.12.2023		
9	M/s Maruthi Electrical & Engineering Works, Plot No:5, Near Jnana Bharathi School, Holalkere Road, Chitradurga - 577501 Contact No: 8277291999/9448169800 E-mail: mceewtransformers@gmail.com	25kVA, 63kVA, and 100kVA BEE star1 rated(4star/EEL-2) Distribution Transformers, CRGO Core	23.04.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 18-19/Cys-191 dated:12.02.2019 (Subject to revalidation every year)	23.04.2023 GM(QS&S)DGM(EL.)-3/BC-11/21-22/CYS-59 dtd:09.08.2021
10	M/s Vignesh Vidyuth controls, No. 55, 17th Cross (Old 30th Cross), Doddanna Industrial Estate, Peenya 2nd Stage, Bangalore-91 Contact No: 9845134612/9886634612 E-mail: vigneshvidyuth@rediffmail.com	25kVA, BEE star1 rated (4star/EEL-2) Distribution Transformers, 50Hz, CRGO Core	05.11.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 18-19/Cys-205 dated:05.03.2019 (Subject to revalidation every year)	
		250kVA & 500kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	09.07.2025	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-164 dated:09.11.2020 (Subject to revalidation once in 2 years)	
11	M/s National Transcare Sy No:17/4, Opp Agriculture University, Lingasugur Road, Raichur - 584101 Contact No:9845244968/7795228032 E-mail:ntcr@rediffmail.com ntcr@yahoo.com	25kVA, star1 rated (EEL-2/4star) Distribution Transformers, CRGO Core	12.11.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-48 dated:18.06.2019 (Subject to revalidation every year)	
		63kVA, star1 rated (EEL-2/4star) Distribution Transformers, CRGO Core	05.07.2023		
12	M/s V.T. Switchgears and Transformers, No:33, 3rd Phase, 4th Main, Peenya Industrial Area, Bangalore - 560058 Ph no:91-80-28392235/35, 9844028978, 9986523600 E-mail:vtsb@gmail.com, city@vtst.in	100kVA star2 rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core	30.11.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-51 dated:21.06.2019 (Subject to revalidation every year)	
		250kVA star2 rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core			
		500kVA star2 rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core	14.03.2024		
13	M/s Chetan Electric Private Limited, No:32-B, Veerasandra, KIADB Industrial Area, Anekal Taluk, Electronic City Post, Bangalore - 560100 Mob:080-25536439 Email:chetanelectric@hotmail.com, chetanelectric@yahoo.com & chetanelectric10@gmail.com	25kVA Star1/Star2 Rated (EEL-2/EEL-3), Distribution Transformers, 50Hz, CRGO Core	08.06.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-52 dated:21.06.2019 (Subject to revalidation every year)	
		63kVA Star1/Star2 Rated (EEL-2/EEL-3), Distribution Transformers, 50Hz, CRGO Core			
		100kVA Star1/Star2 Rated (EEL-2/EEL-3) Distribution Transformers, 50Hz, CRGO Core	29.05.2024		
		250kVA Star1/Star2 Rated (EEL-2/EEL-3), Distribution Transformers, 50Hz, CRGO Core	04.03.2024		
14	M/s Cauvery Power Control, Sy No: 31/2, Chennaih Badavane, Annibesent School Road, Gollarahatti, Magadi Main Road, Vishwanedam Post, Bangalore - 560091 Contact No:9880922686/9741122686 E-mail:cauverypower@gmail.com	25kVA/63kVA/100kVA, Star1 Rated (EEL-2/4 star), Distribution Transformers	24.12.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-58 dated:06.07.2019 (Subject to revalidation every year)	24.12.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-55 dtd:05.08.2021
		63kVA/100kVA, Star2 Rated (EEL-3/5 star), Distribution Transformers,	24.12.2023		
15	M/s EL-TRA Equipment Company(I) Pvt Ltd, 11th Mile, NH-4, Old Madras Road, Avalahalli, Virognagar P.O, Bangalore- 560049 (Ph No:080 28472790/28472229) (E-mail: Eltra5@rediffmail.com, eltra2012@gmail.com)	100kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers	13.12.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-72 dated:23.07.2019 (Subject to revalidation every year)	13.12.2023 GM(QS&S)/DGM-3/BC-11/20-21/CYS-110 dtd:08.11.2021
		250kVA & 500kVA Star2 Rated (EEL-3/5star rated), Distribution Transformers	10.04.2024		10.04.2024 GM(QS&S)/DGM-3/BC-11/20-21/CYS-110 dtd:08.11.2021
16	M/s Amar Industries, Plot No: #R9 TO R12, KSSIDC Industrial Estate, Hosahalli Camp(E.J), Sindhanur-584 128, Raichur Mob No: 9538361911,9739384442, 9742243677	25kVA & 63kVA BEE Star1 Rated (EEL-2/4star), Distribution Transformers	15.05.2022	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-76 dated:24.07.2019 (Subject to revalidation every year)	15.05.2022 GM(QS&S)/DGM-3/BC-11/2021-22/CYS-96 dtd:04.10.2021
		100kVA BEE Star1 Rated (EEL-2/4star),Distribution Transformers	29.11.2023		29.11.2023 GM(QS&S)/DGM-3/BC-11/2021-22/CYS-96 dtd:04.10.2021
		25kVA, Star2 rated (EEL-3/5star) CRGO core, Aluminium wound, Distribution Transformer			

	E-mail:aisnd2015@gmail.com	63kVA, Star2 rated (EEL-3/5star) CRGO core, Aluminium wound, Distribution Transformer,	07.06.2024	GM(QS&S)/DGM-3/BC-11/2020-21/CYS-121 dtd:10.09.2020 (Subject to revalidation every year)	04.10.2023 GM(QS&S)/DGM-3/BC-11/2021-22/CYS-96 dtd:04.10.2021
		100kVA, Star2 rated (EEL-3/5star) CRGO core, Aluminium wound, Distribution Transformer,			
17	M/s B.M.G Transformers Site No:15&16, Sy No:34/3, Kadabagere Village, Dasanapura Hobli, Bangalore - 562130 (Ph No:9448622534 / 9880869024) (E-mail: bmgtransformers@yahoo.com)	25kVA & 63kVA, Star1 Rated(EEL-2/ 4star) Distribution Transformers, CRGO Core, Aluminium wound	22.12.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-109 dated:06.09.2019 (Subject to revalidation every year)	
		100kVA, Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound	27.09.2023		
		25kVA,63kVA & 100kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Copper Wound,	20.03.2023		
18	M/s Shri Datta Transformers, No:405, Mudhol Jamkhandi Main Road, Shirool Cross, Shirool, Mudhol Taluk, Dist Bagalkot, Karnataka - 587313 Mob: 9886313068, 9538593449	25kVA & 63kVA Star1 Rated (EEL-2/4star),Distribution Transformers, 50Hz, CRGO Core, Aluminium wound	25.10.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-119 dated:23.09.2019 (Subject to revalidation every year)	
		100kVA, Star2 Rated (EEL-3/5 star),Distribution Transformers, 50Hz, CRGO Core, Aluminium wound	10.12.2023		
19	M/s Karthik Electricals, #A195, 4th Cross, Peenya 1st stage, Peenya Industrial Estate, Bangalore - 560058 Ph No: 9980014892,8884762 574 E-mail: karthiktransformers@yahoo.in	25kVA, 63kVA & 100kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound	13.06.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-157 dated:18.11.2019 (Subject to revalidation every year)	13.06.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 2021-22/Cys-125 dated:23.11.2021
		63kVA Star2 Rated (EEL-3/ 5star) Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	23.05.2024		23.05.2024 GM(QS&S)DGM(EL.)-3/BC-11/ 2021-22/Cys-125 dated:23.11.2021
		100kVA Star2 Rated (EEL-3/5 star) Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	30.04.2024		30.04.2024 GM(QS&S)DGM(EL.)-3/BC-11/ 2021-22/Cys-125 dated:23.11.2021
20	M/s Shree Bhyraveshwara Electrical Works, #M1, Industrial Area, Lokikere Road, Near Bypass, Davangere- 577 005. Ph No: 9449683214/9448463453. E-mail: anandm1020@rediff.com/ vmnrnataraj99@gmail.com	25kVA, Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound	25.07.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-175 dated: 23.12.2019 (Subject to revalidation every year)	25.07.2023 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-272 dtd:04.03.2021
		100kVA, Star2 rated (EEL-3/5star) Distribution Transformer, CRGO core, Aluminium wound	18.11.2024		04.03.2023 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-272 dtd:04.03.2021
21	M/s Chaitanya Electric Company, No.2, B.M.Shankarappa Estate, Telecom Layout Road, Sunkadakatte, Bangalore - 560091. Ph No:080 23486457, Email:chaitanyaelectric@rediffmail.com.	25kVA, 63kVA, 100kVA, 250kVA & 500kVA BEE star1 rated (EEL-2/4star) Distribution Transformers	12.03.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 17-18/Cys-311 dated: 24.03.2018 (Subject to revalidation every year)	12.03.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-291 dated: 26.03.2021
		25kVA, 63kVA, 100kVA, 250kVA & 500kVA BEE star2 rated (EEL-3/5star) Distribution Transformers	05.02.2023		05.02.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-291 dated: 26.03.2021
22	M/s. Kalpa Elektrikal Pvt Ltd., No.4413, 149/25, III main road, Industrial town, Rajajinagar, Bangalore - 560010 Ph No: 080-23303103, 23356049 & 23405248 Email: sales@kalpaelektrikal.com.	200kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound,	17.7.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/ Cys-179 dated: 26.12.2019 (Subject to revalidation every year)	28.10.2023 BESCOM/GM(QS&S)/DGM-3/BC-11/2021-22/CYS-112 dtd:08.11.2021
23	M/s S.M. Enterprises, No.4911, M.C. Road, Beside Fire station, Mandya - 571402 (Ph No: 9900111081 08232-297029) E-mail: smemdy@gmail.com	25kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	11.12.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/ Cys-195 dated: 16.01.2020 (Subject to revalidation every year)	
		63kVA & 100kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	11.03.2024		
24	M/s Magnitude, #480 B/2, IV Phase, Peenya Industrial Area, Bangalore - 560058 (Ph No:91 80 41227804) E-mail: magnitudetransformer@gmail.com	25kVA, Star1 Rated(EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	04.04.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-198 dated: 28.01.2020 (Subject to revalidation every year)	
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	10.03.2027		
		250kVA, Star2 Rated(EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	06.12.2024		
		100kVA, Star2 Rated(EEL-3/5star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	18.05.2025		
		500kVA, Star2 Rated(EEL-3/5star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	10.06.2024		
M/s Nagashree Enterprises, No:2, Mallayya Industrial Area, Vasundhavadakatti, Chidambaram Dist	25kVA & 63kVA BEE Star 1 Rated (EEL-2) Al. Wound CRGO core, Distribution Transformers	03.01.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 17-18/Cys-271 dated: 20.02.2018 & CYS-319 dtd:28.03.2018 (Subject to revalidation every year)	03.01.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-281 dated: 17.03.2021	
	100kVA & 250kVA BEE Star 2 Rated (EEL-3) Al Wound CRGO core, Distribution Transformers	14.03.2023		14.03.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-281 dated: 17.03.2021	
	100kVA, Star1 Rated(EEL-2/4star) CRGO Core Distribution Transformers	18.07.2023		18.07.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-281 dated: 17.03.2021	

25	<p>ಆಣ್ವಿಕವಿಭಾಗದ ಕಛೇರಿ, ಸಿಕ್ಕಂದಿಬಾವಾ ರಸ್ತೆ, ಬೆಂಗಳೂರು - 560090, Ph No:9449732909, 9663073059, 9538047909. E-mail:nagashretrafo@gmail.com</p>	25kVA Star2 Rated(EEL-3/5star rated), CRGO Core Distribution Transformers	19.12.2024	GM(QS&S)DGM(EL.-3)/BC-11/ 19-20/Cys-211 dated: 19.02.2020 (Subject to revalidation every year)	17.03.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-281 dated: 17.03.2021	
		63kVA Star2 Rated(EEL-3/5star rated), CRGO core Distribution Transformers	18.07.2023		18.07.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-281 dated: 17.03.2021	
		500kVA Star2 Rated(EEL-3/5star rated), CRGO core Distribution Transformers	03.12.2024		17.03.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-281 dated: 17.03.2021	
26	<p>M/s Excel Power controls & Systems, #53/1,2nd Main, Off Magadi Main Road, Kottigepalya, Bangalore-560091 Ph No: 9845332465 Email: exceltrafos@gmail.com</p>	11kV/433V ,3 Phase- Distribution Transformers, CRGO Core, AI wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and conforming to latest versions of IS - 1180 & IS - 2026.		GM(QS&S)DGM(EL.-3)/BC-11/20-21/Cys-02 dated: 17.04.2020 (Subject to revalidation every year)		
		25kVA, star1 rated (EEL-2/4star rated)	18.01.2025			
		100kVA,star1 rated (EEL-2/4star rated) & star2 rated (EEL-3/5star rated)	24.05.2024			
		250kVA,star2 rated (EEL-3/5star rated)	09.11.2024			
		500kVA,star2 rated (EEL-3/5star rated)	20.02.2025			
27	<p>M/s Raj power Controls, No.116/7 & 117/6, mookambika Temple Road, Machohalli forest gate, Magadi Main road, Bangalore - 560091, Mob:9611146656,9886260538, Email:rajpowers@live.com, rajeshrgowda@gmail.com</p>	25kVA,63kVA & 100kVA BEE star 1 rated, EEL-2, Distribution Transformers	03.11.2022	GM(QS&S)DGM(EL.-4)/BC-11/ 17-18/Cys-223 dated:26.12.2017 (Subject to revalidation every year)	03.11.2022 GM(QS&S)/DGM(EL.-3)/BC-11/21-22/CYS-48 dtd:29.07.2021	
		25kVA, 63kVA and 100kVA BEE star 2 rated EEL-3 Distribution Transformers	22.01.2023		22.01.2023 GM(QS&S)/DGM(EL.-3)/BC-11/21-22/CYS-48 dtd:29.07.2021	
		250kVA,star2 rated (EEL-3/5star rated)	06.01.2025		GM(QS&S)/DGM(EL.-3)/BC-11/20-21/CYS-13 dtd:12.05.2020 (Subject to revalidation every year)	29.07.2023 GM(QS&S)/DGM(EL.-3)/BC-11/21-22/CYS-48 dtd:29.07.2021
		500kVA,star2 rated (EEL-3/5star rated)	07.11.2024			
28	<p>M/s Jain Electrical Industry, Behind Bharat petroleum pump, sindhagi Road, Ind: 586 209 Ph No: 9448129016/9980646616/9620116109. E-mail:anant.jain@jainpower.com</p>	25kVA star2 rated (EEL-3/5star), Distribution Transformers, CRGO core,	07.12.2022	GM(QS&S)DGM(EL.-3)/BC-11/18-19/ CYS-103 dtd: 27.09.2018. (Subject to revalidation every year)	29.05.2021 GM(QS&S)/DGM(EL.-3)/BC-11/20-21/CYS-24 dtd:29.05.2020	
		63kVA star2 rated (EEL-3/5star), Distribution Transformers, CRGO core,	07.12.2022			
		100kVA star2 rated (EEL-3/5star), Distribution Transformers, CRGO core,	07.12.2022			
29	<p>M/s Nandadeepa Power Controls, No.30, Kachohalli Industrial Area, Dasanapura Hobli, Bangalore - 562123 (Ph No: 9066619819) (E-mail: npctransformer@gmail.com, ganpathdewasi2013@gmail.com)</p>	25kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound	07.09.2023	GM(QS&S)DGM(EL.-3)/BC-11/20-21/Cys-29 dated: 30.05.2020 (Subject to revalidation every year)		
		100kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, , CRGO Core, Copper Wound,	11.01.2025			
30	<p>M/s Danish Private Limited., F-679-680,G-694, Sitapur Industrial Area, Jaipur - 302022. Mob:8947822222 E-mail: info@danish.co.in</p>	500kVA Star2 Rated(EEL-3/5star rated), CRGO Core, Aluminium/Copper Wound Distribution Transformers, .	17.12.2024	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-170 dated: 13.11.2020 (Subject to revalidation every year)		
		1000kVA Star2 Rated(EEL-3/5star rated) CRGO Core Copper Wound Distribution Transformers	17.12.2024			
31	<p>M/s Voltech Manufacturing Company Limited., Sy No: 212/1,212/2,213/3, Pillaipakkam Village, Sriperumputhur Taluk, Kanchipuram-602105) (E- mail: transformers@voltechgroup.com) (Ph No: 91-44-27107288)</p>	250kVA, Star2 Rated(EEL-3/5star rated), CRGO Core, Copper Wound, Distribution Transformers,	18.03.2024	GM(QS&S)DGM(EL.-3)/BC-11/20-21/Cys-63 dated: 30.07.2020 (Subject to revalidation every year)	18.03.2024 GM(QS&S)DGM(EL.-3)/BC-11/ 21-22/Cys-88 dated: 22.09.2021	
		500kVA, BEE star2 rated (EEL-3/5 Star rated) Distribution Transformers, CRGO core	04.06.2023		04.06.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 21-22/Cys-88 dated: 22.09.2021	
32	<p>M/s Unipower Technical Services and Consultancy Pvt Ltd., #47/2, Kachohalli Village, Dasanapura Hobli, Magadi Main Road, Bengaluru-590091 Ph No: 9742387774 Email:marketing@unipts.com/ contact@unipts.com.</p>	200kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound	09.09.2024	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-70 dated: 11.08.2020 (Subject to revalidation every year)	08.12.2023 GM(QS&S)/DGM-3/AE/BC-11/ 22-23/Cys-91 dated: 19.12.2022	
		25kVA, EEL-1 (1star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound	09.09.2026		19.12.2024 GM(QS&S)/DGM-3/AE/BC-11/ 22-23/Cys-91 dated: 19.12.2022	
		63kVA, 100kVA and 250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound	19.06.2023		GM(QS&S)/DGM-3/AE/BC-11/ 22-23/ Cys-91 dated: 19.12.2022	
33	<p>M/s Unimip Power Transformer Pvt Ltd., 26/A, II phase, Peenya Industrial Area, Bengaluru-560 058 (Ph No:8028396184, E-mail:contact@umpt.in)</p>	500kVA star2 rated (EEL-3/5 star), Distribution Transformers, CRGO core,	27.07.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 18-19/Cys-112 dated: 09.10.2018 (Subject to revalidation every year)	14.08.2021 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-86 dated: 17.08.2020	
34	<p>M/s Ohm Sree Manikanta Electricals, No: 23, 3rd 'a' cross, TTP Colony, Neigadaranahalli, Nagasandra Post, Bangalore - 560073 (Factory Unit: Sy. No:111/2, Site No 1 & 2, Gangandanahalli village, Near Nice Road Bridge, Lakshimpura Post, Bangalore North Taluk, Bangalore - 562123) (Ph No: 0808- 22792936, 080-2272445) (E-mail: Transformers@osmec.co.in)</p>	100kVA, BEE star2 rated (EEL-3/5 Star rated) Distribution Transformers, Amorphous core	28.06.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 17-18/Cys-123 dated:31.10.2018 (Subject to revalidation every year)	27.08.2021 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-98 dated: 28.08.2020	
		250kVA, Star2 rated (EEL-3/5star) Distribution Transformer, CRGO core, Aluminium wound	04.12.2024		GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-99 dated: 28.08.2020 (Subject to revalidation every year)	
		500kVA, Star2 rated (EEL-3/5star) Distribution Transformer, CRGO core, Copper wound	10.01.2024			
35	<p>M/s S.M. Enterprises. (TM AND OD), No.4911, Beside Fire station, M.C.Road, Mandya - 571402 Ph No. 9900111081, 08232-297029 Email: smemdy@gmail.com</p>	100kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers CRGO Core, Aluminium Wound	25.11.2024	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-116 dated: 07.09.2020 (Subject to revalidation every year)		
		250kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers, CRGO Core, Aluminium Wound	09.12.2024			
		500kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers, CRGO Core, Aluminium Wound	11.01.2025			
36	<p>M/s J.M. Electrical Works, Sy No:224/C/3, Holagundi road, Near by JSS college, Huvinahadagali Town and Taluk, Ballari Ph No:9902371432 E-mail:dileepjnew@gmail.com</p>	25kVA, 63kVA & 100kVA star1 rated(EEL-2/4star), Distribution Transformers, CRGO core	27.03.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 18-19/Cys-133 dated: 13.11.2018	27.03.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-290 dated: 25.03.2021	
		25kVA & 63kVA star2 rated(EEL-3/5star), Distribution Transformers, CRGO core	03.04.2023		03.04.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-290 dated: 25.03.2021	
		100kVA star2 rated (EEL-3/5star),Distribution Transformers, CRGO core	23.08.2023		23.08.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-290 dated: 25.03.2021	

37	M/s Vijayashree Power, NH-206, Sy No: 113, Behind Byraveshwara petrol bunk, Nittur-572223, Gubbi Taluk, Tumkur Dist. Ph No: 998621445, 8904465178 Email: vijayshreepower@gmail.com	11kV/433V ,3 Phase- Distribution Transformers, CRGO Core, Al wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.		GM(QS&S)/DGM-3/BC-11/21-22/CYS-20 dated: 14.06.2021	
		25kVA, star1 rated (EEL-2/4star rated)	14.06.2022		
		100kVA, star2 rated (EEL-3/5star rated)			
38	M/s Telawane Power equipments private Ltd, R-457, MIDC, Rabale, Behind Pipeline Road, Thane Belapur Road, Navi Mumbai-400 701. Ph No: 9964655000 Email.Id: Raghunath@telwane.com	11kV/433V ,3 Phase- Distribution Transformers, CRGO Core, copper wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
		500kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, copper Wound, Distribution Transformers,	12.07.2022	GM(QS&S)/DGM-3/BC-11/21-22/CYS-40 dated: 12.07.2021	
39	M/s Surabhi Industries, Haleyuru Village, Amrathur Road, Huliurudurga Hobli, Kunigal Taluk, Dist: Tumkur - 572123 Karnataka Ph :9741512323/9880139039 E-mail: vijayashreetrans69@gmail.com	25kVA, 63kVA & 100kVA Star1 Rated (EEL-2/4star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound,	06.08.2022	GM(QS&S)/DGM-3/BC-11/21-22/CYS-56 dated: 06.08.2021	
		25kVA, 63kVA & 100kVA Star2 Rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound,			
40	M/s Suvarna Transformers, Kabbinahalay, Gorur Road, Hassan - 573201, Ph No:080-22281199	25kVA & 63kVA, Star1 Rated (EEL-2/4 star rated) Al wound, CRGO core, Distribution Transformers,	11.08.2022	GM(QS&S)/DGM-4/BC-11/17-18/CYS-240 dated: 11.01.2018	GM(QS&S)/DGM-3/BC-11/21- 22/CYS-91 dated: 23.09.2021
		25kVA, 63kVA & 100kVA Star2 Rated (EEL-3/5 star rated) Al wound, CRGO core, Distribution Transformers,	23.01.2023	GM(QS&S)/DGM-4/BC-11/18-19/CYS-10 dated: 16.04.2018	
41	M/s Chuan Shun Electric Company India Private Limited (CSE Power). No.79-B, KIADB Industrial Area, Jigani Phase I, Jigani, Anekal Taluk, Bangalore-560105. Ph No: 91 80 29776476/77/78 8762800500 & 9945280876	63kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers	09.10.2025	GM(QS&S)/AE/BC-11/21-22/CYS-132 dated:10.12.2021 (Subject to revalidation once in 2 years)	
		100kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers			
		250kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, Aluminium/ Copper Wound, ONAN Cooled, Distribution Transformers			
42	M/s Sri Sairam Power Controls #1/4, Lakshamaiah Industrial Layout, Abbigeri Village Bengaluru-560090 Ph NO:91-080-23253811/ E-mail: info@sairampowercontrols.com/ sairampower@gmail.com	25kVA, Star1 Rated(EEL-2/4star) CRGO Core, Aluminium wound 50Hz, Distribution Transformers	17.11.2025	GM(QS&S)/AE/BC-11/21-22/CYS-153 dated:17.01.2022 (Subject to revalidation once in 2 years)	
		200kVA Star2 Rated(EEL-3/ 5star rated), 50Hz, CRGO Core, Aluminium Wound, Distribution Transformers			
		500kVA Star2 Rated(EEL-3/ 5star rated), 50Hz, CRGO Core, Aluminium Wound, Distribution Transformers	13.10.2025		
43	M/s Power Tech Transformers, No.32, Indiranagar, Near RNS Paints, Nagasandra Post, Doddabiderakalli, Bangalore - 560073 Ph No:96630220273/9886020326 E-mail:Powertech.vinod@gmail.com	100kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, Distribution Transformers	25.11.2025	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys- 155 dated: 25.01.2022 (Subject to revalidation once in 2 years)	
44	M/s S.K. Transformer, No.71/2, Seegehalli Village, Magadi Main Road, Bangalore - 562130 Ph:9341252405 E-mail:sk.trafo.co@gmail.com	63kVA Star2 Rated (EEL-3/5 star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers	31.12.2023	GM(QS&S)/DGM-3/BC-11/19-20/CYS- 115 dtd:18.09.2019 (Subject to revalidation every year)	31.12.2023 GM(QS&S)/DGM(EI)-3/BC-11/20- 21/CYS-239 dtd:04.02.2021
		500kVA, Star2 Rated (EEL-3/5 star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers,	10.06.2023		10.06.2023 GM(QS&S)/DGM(EI)-3/BC-11/20- 21/CYS-239 dtd:04.02.2021
		25kVA, 63kVA & 100kVA Star1 Rated (EEL-2/4star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers (Star 1 rated Distribution Transformers shall be used in Rural Area only)	29.11.2026	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys- 157 dated: 28.01.2022 (Subject to revalidation once in 2 years)	
		250kVA, Star2Rated (EEL-3/5star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers. (Star2 rated Distribution Transformers shall be used in Urban Area only)	08.12.2026		
45	M/s Vijay Electricals (VE Transformers) No:9, Byraveshwara Industrial Estate, Andrahalli Main Road, Near Peeenya 2nd stage, Bangalore - 560091 Mob:9035620230,9986395630 Email:v-electricals@yahoo.in/ marketing@vetransformers.com	100kVA & 500kVA star2 rated (EEL-3/5star) Distribution Transformer Revalidation of Vendor approval	04.09.2023	GM(QS&S)DGM(EI.-3)/BC-11/ 18- 19/Cys-214 dated:20.03.2019	
		100kVA & 500kVA Star2 Rated (EEL-3/ 5star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	04.09.2023		
		Renewal of vendor approval			
		25kVA star1 rated (EEL-2/4 star), CRGO core, 50Hz, Distribution Transformers, (Star1 rated Distribution Transformers shall be used in Rural Area only)	29.01.2025 (Subject to revalidation once in 2 years)	BESCOM/GM(QS&S)/AE/BC-11/ 21- 22/Cys-158 dated:31.01.2022	
		63kVA & 100kVA star1 rated (EEL-2/4 star), CRGO core, 50Hz, Distribution Transformers, (Star1 rated Distribution Transformers shall be used in Rural Area only)	25.03.2026 (Subject to revalidation once in 2 years)		
		250kVA star1 rated (EEL-2/4 star), CRGO core, Distribution Transformers, (Star1 rated Distribution Transformers shall be used in Rural Area only)	02.08.2023		
		63kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core,	08.07.2027 (Subject to revalidation once in 2 years)	BESCOM/GM(QS&S)/DGM-3/AE/BC- 11/2022-23/CYS-94 dtd:21.12.2022	
		250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core,	05.03.2024		
		Vendor Approval			
		500kVA star2 rated (EEL-3/5 star), Aluminium & Copper wound, CRGO Core Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	23.07.2024	BESCOM/GM(QS&S)/AE/BC-11/ 21- 22/Cys-158 dated:31.01.2022	
		1000kVA star2 rated (EEL-3/5 star), Copper wound, CRGO Core 50Hz, Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	04.10.2024		

46	M/s Venkat Switchgears, No:150, 10th Main, 3rd Phase, Peenya Industrial Area, Bangalore - 560058 (Ph No:080 23722274) (E-mail: lakshmpathiad @venkatswitchgears.com)	250kVA, Star2 Rated(EEL-3/5star rated), Distribution Transformers	01.04.2024	GM(QS&S)DGM(EL.-3)/BC-11/ 19-20/Cys-62 dated:10.07.2019 (Subject to revalidation every year)
		63kVA & 100kVA star1 rated (EEL-2/4 star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers (Star1 rated Distribution Transformers shall be used in Rural Area only)	28.02.2027	BESCOM/GM(QS&S)/AE/BC-11/21-22/CYS-176 dtd:22.03.2022 (Subject to revalidation once in 2 years)
		200kVA, Star2 Rated (EEL-3/5star rated) Aluminium wound & Copper wound, CRGO core, Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	11.07.2024	
47	M/s SLV Transformer, Ground floor, Sy No.124, Near Abhaya School, Jangalpalya Village, Jigani Hobli Anekal Taluk, Bangalore - 560083 Ph No:9686661992/9448369932 E-mail: slvtransformer20@gmail.com	25kVA, star1 rated, Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	16.02.2026	BESCOM/GM(QS&S)/AE/BC-11/2022-23/CYS-21 dtd: 21.06.2022 (subject to revalidation once in 2 years)
		63kVA, star1 rated, Distribution Transformers, CRGO core, 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	14.04.2027	
		100kVA, star2 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-2 as per new amendment 4 of IS-1180)	25.11.2025	
		250kVA, star2 rated, Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-2 as per new amendment 4 of IS-1180)	08.02.2026	
48	M/s Vijayashree Power, Sy No. 113, NH-206, Behind Byraveshwara Petrol Bunk, Nittur, Gubbi Tq, Tumkur Dist-572223 Ph No: 9986261445/8904465178 E-mail: vijayashreepower@gmail.com	25kVA, star1 rated, Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	17.05.2026	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-25 dtd: 05.07.2022 (subject to revalidation once in 2 years)
		100kVA, star2 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-2 as per new amendment 4 of IS-1180)	20.01.2026	
49	M/s Siliguri Electric Works, Khaprali Road (1/2 KM from khaprali More), P.O. Nirmal, (Matigara), Darjeeling - 734010 Ph No: 9933066620/9733309977 E-mail: sew@gmail.com / siligurielectricworks@yahoo.com	25kVA, 63kVA, 100kVA star1 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	13.07.2023	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-31 dtd: 18.07.2022
		250kVA & 500kVA star1 rated, Distribution Transformers, CRGO Core, Copper wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)		
50	M/s R.V.Transformer manufacturing Co., D-14/A, Industrial Area, Lokikere Road, Davangere-577 005 E-mail: rvtransformer.mfgco@yahoo.in Ph:9448119142, 9980728611	25kVA, 63kVA & 100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	29.07.2023	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-56 dtd: 15.09.2022
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	17.02.2026	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-56 dtd: 15.09.2022 (Subject to revalidation once in 2 years)
51	M/s Supreme Power Technologies, Sy no:191, Kurubarahalli, Tavarekere Post/Hobli, Tavarekere, Bangalore - 562130 Ph:9880295333,9480220911 E-mail: supremepower@gmail.com	100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium	22.02.2026 (Subject to revalidation once in 2 years)	GM(QS&S)DGM(EL.-3)/AE/BC-11/ 22-23/Cys-46 dated: 25.08.2022
		Vendor Approval		
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	25.08.2023	GM(QS&S)DGM(EL.-3)/AE/BC-11/ 22-23/Cys-46 dated: 25.08.2022
52	M/s Viji Power Trasformers Pvt Ltd Plot No: 21, Metha Industrial Estate, Machohalli, Magadi Main Road, Bangalore. Contact No: 9900111089 E-mail: vijitechdinakar10@yahoo.com	100kVA ,250kVA & 500kVA star2 rated (EEL-3/5star) Distribution Transformers, 50Hz, CRGO Core,	10.12.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 19-20/Cys-47 dated:15.06.2019 (Subject to revalidation every year)
		100kVA star2 rated(EEL-3/5 star)Distribution Transformers, 50Hz, Amorphous Core		
		25kVA & 63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	14.04.2027	GM(QS&S)DGM(EL.-3)/AE/BC-11/ 22-23/Cys-52 dated: 09.09.2022 (subject to revalidation once in 2 years)
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	29.06.2027	

53	M/s Vijay Transformer Vidyuth Company No:4, Survey No.63/1 & 63/2, Karihobhanahalli, Thigalarapalya Village, Peenya 2nd stage, Bangalore - 560058 Ph:9886824635/9900126914 E-mail: vijaytransformer2020@gmail.com	63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound	20.06.2023	GM(QS&S)/DGM-3/BC-11/21-22/CYS-33 dated: 05.07.2021	
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	17.02.2026		
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	17.05.2026	GM(QS&S)DGM(EL.)-3/AE/BC-11/ 22-23/Cys-53 dated: 09.09.2022 (Subject to revalidation once in 2 years)	
		100kVA & 250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound,	03.03.2026		
54	M/s Dynalektrik Equipment Private Limited, #49/2, Vaderamanchanahalli Village, Kallu balu to anekal Road, Jigani Hobli, Anekal Taluk, Bengaluru (Bangalore) Urban, Karnataka - 560105 Ph :91(80)29611999 E-mail:info@dynalektrik.com	250kVA 2Star Rated(EEL-2), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	10.02.2026	GM(QS&S)/DGM-3/BC-11/22-23/CYS-55 dated: 13.09.2022 (Subject to revalidation once in 2 years)	
		25kVA & 63kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	14.07.2026		
		Vendor Approval			
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	09.09.2023		
55	M/s Vijay Vidyuth Udyog #10, Survey No: 168/1, Machohalli, Dasanapura Hobli, Magadi Road, Bengaluru -560 091. Ph no: 966345451/ 9341225120 & 9341225512 Email:info@vijayvidyuth.com	25kVA, 63kVA & 100kVA EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	01.08.2027	GM(QS&S)/DGM-3/AE/BC-11/ 22-23/CYS-60 dtd:19.09.2022 (Subject to revalidation once in 2 years)	
		63kVA, 100kVA & 500kVA star2 EEL-3, Al wound, CRGO core Distribution Transformers	12.02.2023	GM(QS&S)DGM(EL.)-4/BC-11/ 17-18/Cys-304 dated: 26.03.2018 (Subject to revalidation every year)	12.02.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 21-22/Cys-38 dated: 09.07.021
		250kVA, star2 EEL-3, Al wound, CRGO core Distribution Transformers	16.01.2023	BESCOM/GM(QS&S)/AE/BC-11/21-22/CYS-149 dtd:06.01.2022	
56	M/s Macro Power Controls, No.24, 2nd cross, Kadabagere cross, Magadi Main Road, Behind Bus Stop, Bangalore - 560091. E-mail: dmacropower@yahoo.in Ph:8792708263/8792708264/8792708267/8861954803	25kVA, 63kVA & 100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	03.11.2023		
		Renewal of Vendor Approval			
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	10.02.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-76 dtd:03.11.2022 (Subject to revalidation once in 2 years)	
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	28.09.2023		
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	25.09.2023		
		250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	13.10.2027		
57	M/s Flow Line Transformers Private Limited, No.82/3B, B.H.Road, Basavanahalli, Nalamangala, Bangalore - 562123 Ph No: 918027724092/27723938 Email:sales@flowlinetransformers.com	25kVA, 63kVA & 100kVA EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	29.10.2026		
		200kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	19.07.2026	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-84 dated: 28.11.2022 (Subject to revalidation once in 2 years)	
		100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	11.08.2023		
		500kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
58	M/s Sri Shanthaveera Transformers MFG. Co., Basavanapura Main Road, Swathanranagar, Opp. SEA college, Virgonagar Post, Bangalore - 560049. Ph No: 080-95436753/ 9844469813 E-mail: shanthaveeraa@yahoo.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	01.08.2027	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-117 dated:19.01.2023 (Subject to revalidation once in 2 years)	