

## Distribution Transformers

Sl. No.	Name of the firm	Material Approved	Valid upto	O.M. No. & Date	Status of revalidation
1	M/s Kailash Transformers Pvt Ltd., #23, KIADB, 1st stage, Kapnoor Industrial Area, Kalaburagi – 585 104 Ph No: (08472) 257449. E-mail: kailashpvtltd1@gmail.com	25kVA, 63kVA & 100kVA, star1 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	25.01.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-32 dtd:19.07.2022 (Subject to revalidation once in 2 years)	
2	M/s Mahalakshmi Transformers, No. 16, 15th Cross, Karemsaab Layout, Hegganahalli, Peenya 2nd Stage, Bangalore-91 Mob:9845862604/9900526104 E-mail:mit_koparde@yahoo.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	30.03.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-77 dtd:05.11.2022 (subject to revalidation once in 2 years)	
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	19.04.2027		
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	07.04.2027		
		25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	01.12.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-158 dtd:12.01.2024 (subject to revalidation once in 2 years)	
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	13.11.2028		
		250kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026	26.02.2028		
3	M/s Raikar Electric Company, No:20, Raghavendra Industrial Estate, Thigalarpalya Main Road, Near peenya 2nd stage, Bangalore - 560058. Ph No: 9845169654, 9535256093. E-mail:raikar.blr2000@gmail.com	63kVA & 100kVA Star2 Rated (EEL-3/5 star rated) Al wound, CRGO core, Distribution Transformers	12.03.2024	GM(QS&S)/AE/BC-11/ 21-22/Cys-141 dated:27.12.2021 (Subject to revalidation once in 2 years)	
		250kVA & 500kVA Star2 Rated (EEL-3/5 star rated) Al wound, CRGO core, Distribution Transformers	23.06.2025		
4	M/s Perfect Electricals, Plot No: 152, Sompura 1st stage, KIADB, Near Dabaspete, Nelamangala Taluk, Bangalore – 562111. Ph No:9845062309. E-mail: perfectswamy@yahoo.com	500kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	26.12.2024	GM(QS&S)DGM(EL.-)3/BC-11/ 19-20 /Cys-221 dated:10.03.2020	30.03.2023 GM(QS&S)DGM(EL.-)3/BC-11/ 20-21/Cys-294 dated:31.03.2021
		25kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled Distribution Transformers,	23.11.2025	GM(QS&S)/AE/BC-11/ 21-22 /Cys-133 dated:10.12.2021 (Subject to first revalidation dated before: 10.12.2022 and then it will be revalidated once in 2 years)	Not revalidated
		63kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers			
		100kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers	14.08.2026	GM(QS&S)/AE/BC-11/ 21-22 /Cys-133 dated:10.12.2021 (Subject to first revalidation dated before: 10.12.2022 and then it will be revalidated once in 2 years)	Not revalidated
		250kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers			
5	M/s Vignesh Vidyuth controls, No. 55, 17th Cross (Old 30th Cross), Doddanna Industrial Estate, Peenya 2nd Stage, Bangalore-91 Contact No: 9845134612/9886634612 E-mail: vigneshvidyuth@rediffmail.com	250kVA & 500kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	09.07.2025	GM(QS&S)DGM(EL.-)3/BC-11/ 20-21/Cys-164 dated:09.11.2020 (Subject to revalidation once in 2 years)	Not revalidated
6	M/s V.T. Switchgears and Transformers, No:33, 3rd Phase, 4th Main, Peenya Industrial Area, Bangalore - 560058 Ph no:91-80-28392235/35, 9844028978, 9986523600 E-mail:vtstbg@gmail.com, city@vtst.in	500kVA star2 rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core	14.03.2024	GM(QS&S)DGM(EL.-)3/BC-11/ 19-20/Cys-51 dated:21.06.2019 (Subject to revalidation every year)	Not revalidated
7	M/s Chetan Electric Private Limited, No:32-B, Veerasandra, KIADB Industrial Area, Anekal Taluk, Electronic City Post, Bangalore – 560100 Mob:080-25536439 Email:chetanelectric@hotmail.com, chetanelectric@yahoo.com & chetanelectric10@gmail.com	25kVA Star1/Star2 Rated (EEL-2/EEL-3), Distribution Transformers, 50Hz, CRGO Core	08.06.2024	GM(QS&S)DGM(EL.-)3/BC-11/ 19-20/Cys-52 dated:21.06.2019 (Subject to revalidation every year)	Not revalidated
		63kVA Star1/Star2 Rated (EEL-2/EEL-3), Distribution Transformers, 50Hz, CRGO Core			
		100kVA Star1/Star2 Rated (EEL-2/EEL-3) Distribution Transformers, 50Hz, CRGO Core	29.05.2024		
		250kVA Star1/Star2 Rated (EEL-2/EEL-3), Distribution Transformers, 50Hz, CRGO Core	04.03.2024		
8	M/s EL-TRA Equipment Company(I) Pvt Ltd, 11th Mile, NH-4, Old Madras Road, Avalahalli, Virrognagar P.O, Bangalore-560049 (Ph No:080 28472790/28472229) (E-mail: Eltra5@rediffmail.com, eltra2012@gmail.com)	250kVA & 500kVA Star2 Rated (EEL-3/5star rated), Distribution Transformers	10.04.2024	GM(QS&S)DGM(EL.-)3/BC-11/ 19-20/Cys-72 dated:23.07.2019 (Subject to revalidation every year)	10.04.2024 GM(QS&S)/DGM-3/BC-11/20-21/CYS-110 dtd:08.11.2021
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	23.06.2027 (Subject to revalidation once in 2 years from the date of issue of this OM)	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-19 dtd:08.05.2023	

9	M/s Amar Industries, Plot No: #R9 To R12, KSSIDC Industrial Estate, Hosahalli Camp(E.J), Sindhanur-584 128, Raichur Mob No: 9538361911,9739384442, 9742243677 E-mail:aisnd2015@gmail.com	63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	09.06.2027 (Subject to revalidation once in 2 years from the date of issue of this OM)				
		25kVA, Star2 rated (EEL-3/5star) CRGO core, Aluminium wound, Distribution Transformer	07.06.2024	GM(QS&S)/DGM-3/BC-11/2020-21/CYS-121 dtd:10.09.2020 (Subject to revalidation every year)	04.10.2023 GM(QS&S)/DGM-3/BC-11/2021-22/CYS-96 dtd:04.10.2021		
		63kVA, Star2 rated (EEL-3/5star) CRGO core, Aluminium wound, Distribution Transformer,					
		100kVA, Star2 rated (EEL-3/5star) CRGO core, Aluminium wound, Distribution Transformer,					
10	M/s Karthik Electricals, #A195, 4th Cross, Peenya 1st stage, Peenya Industrial Estate, Bangalore - 560058 Ph No: 9980014892,8884762 574 E-mail: karthiktransformers@yahoo.in	63kVA Star2 Rated (EEL-3/ 5star) Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	23.05.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-157 dated:18.11.2019 (Subject to revalidation every year)	23.05.2024 GM(QS&S)DGM(EL.)-3/BC-11/ 2021-22/Cys-125 dated:23.11.2021		
		100kVA Star2 Rated (EEL-3/5 star) Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	30.04.2024		30.04.2024 GM(QS&S)DGM(EL.)-3/BC-11/ 2021-22/Cys-125 dated:23.11.2021		
11	M/s Shree Bhyraveswara Electrical Works, #M1, Industrial Area, Lokikere Road, Near Bye-pass, Davangere- 577 005. Ph No: 9449683214/9448463453. E-mail: anandm1020@rediff.com/vmnrtaraj99@gmail.com	100kVA, Star2 rated (EEL-3/5star) Distribution Transformer, CRGO core, Aluminium wound	18.11.2024	GM(QS&S)DGM(EL.)-3/AE/BC-11/ 23-24/Cys-150 dated: 04.01.2024			
		25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	04.01.2025				
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.					
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	15.06.2028 Subject to revalidation once in 2 years from the date of issue of this OM				
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	23.12.2025				
12	M/s Kalpa Elektrikal Pvt Ltd., Registered Office: No.4413, 149/25, III main, Industrial Town, Rajajinagar, Bangalore - 560073. Factory Unit: Sy No. 133/4, Chikkahanumanthaiiah Industrial Area, Machohalli, Magadi Main Road, Bangalore - 560091 Contact No: 9945238615/ 23303103, 23356049, 23405248. E-mail: sales@kalpaelektrikal.com/info@kalpaelektrikal.com	200kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound,	17.7.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/ Cys-179 dated: 26.12.2019 (Subject to revalidation every year)	28.10.2023 BESCOM/GM(QS&S)/DGM-3/BC-11/2021-22/CYS-112 dtd:08.11.2021		
		11kV/433V, 500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Copper Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	25.03.2024			GM(QS&S)DGM(EL.)-3/BC-11/ 23-24/ Cys-145 dated: 26.12.2023	
13	M/s S.M. Enterprises, No.4911, M.C. Road, Beside Fire station, Mandya – 571402 (Ph No: 9900111081 08232-297029) E-mail: smemdy@gmail.com	25kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	11.12.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/ Cys-195 dated: 16.01.2020 (Subject to revalidation every year)	Not revalidated		
		63kVA & 100kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	11.03.2024				
14	M/s Magnitude, #480 B/2, IV Phase, Peenya Industrial Area, Bangalore - 560058 (Ph No:91 80 41227804) E-mail: magnitudetransformer@gmail.com	25kVA, Star1 Rated(EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	04.04.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-198 dated: 28.01.2020 (Subject to revalidation every year)			
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	10.03.2027			GM(QS&S)DGM(EL.)-3/BC-11/2022-23/Cys-118 dated:19.01.2023 (Subject to revalidation every year)	
		250kVA, Star2 Rated(EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	06.12.2024			GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-198 dated: 28.01.2020 (Subject to revalidation every year)	Not revalidated
		100kVA, Star2 Rated(EEL-3/5star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	18.05.2025			GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-20 dated: 26.05.2020 (Subject to revalidation every year)	Not revalidated
		500kVA, Star2 Rated(EEL-3/5star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	10.06.2024			GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-130 dated: 28.09.2020 (Subject to revalidation every year)	Not revalidated
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026	12.04.2028	GM(QS&S)DGM(EL.)-3/BC-11/ 23-24/Cys-84 dated: 07.09.2023 (Subject to revalidation: once in 2 years)			

15	M/s Nagashree Enterprises, No:2, Mallaya Industrial Area, Kereguddadahalli, Chikkabavara Post, Bangalore - 560090, Ph No:9449732909, 9663073059, 9538047909. E-mail:nagashretra@gmail.com	63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	14.05.2028	GM(QS&S)DGM(EL.)-3/BC-11/ 23-24/Cys-84 dated: 07.09.2023 (Subject to revalidation once in 2 years)	
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	15.08.2028	GM(QS&S)DGM(EL.)-3/BC-11/ 23-24/Cys-84 dated: 07.09.2023 (Subject to revalidation once in 2 years)	
		25kVA Star2 Rated(EEL-3/5star rated), CRGO Core Distribution Transformers	19.12.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-211 dated: 19.02.2020 (Subject to revalidation every year)	Not revalidated
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	18.07.2028	GM(QS&S)DGM(EL.)-3/BC-11/ 23-24/Cys-84 dated: 07.09.2023 (Subject to revalidation once in 2 years)	
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	25.04.2028	GM(QS&S)DGM(EL.)-3/BC-11/ 23-24/Cys-84 dated: 07.09.2023 (Subject to revalidation once in 2 years)	
		250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	30.04.2028	GM(QS&S)DGM(EL.)-3/BC-11/ 23-24/Cys-84 dated: 07.09.2023 (Subject to revalidation once in 2 years)	
		500kVA Star2 Rated(EEL-3/5star rated), CRGO core Distribution Transformers	03.12.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-211 dated: 19.02.2020 (Subject to revalidation every year)	Not revalidated
16	M/s Excel Power controls & Systems, #53/1,2nd Main, Off Magadi Main Road, Kottigepalya, Bangalore-560091 Ph No: 9845332465 Email: exceltrafos@gmail.com	11kV/433V ,3 Phase- Distribution Transformers, CRGO Core, Al wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.		GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-02 dated: 17.04.2020 (Subject to revalidation every year)	Not revalidated
		25kVA, star1 rated (EEL-2/4star rated)	18.01.2025		
		100kVA, star1 rated (EEL-2/4star rated) & star2 rated (EEL-3/5star rated)	24.05.2024		
		250kVA, star2 rated (EEL-3/5star rated)	09.11.2024		
		500kVA, star2 rated (EEL-3/5star rated)	20.02.2025		
17	M/s Nandadeepa Power Controls, No:30, Kachohalli Industrial Area, Dasanapura Hobali, Bangalore - 562123 (Ph No: 9066619819) (E-mail: npctransformer@gmail.com, ganpathdewasi2013@gmail.com)	100kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, CRGO Core, Copper Wound,	11.01.2025	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-29 dated: 30.05.2020 (Subject to revalidation every year)	Not revalidated
18	M/s Danish Private Limited., F-679-680,G-694, Sitapur Industrial Area, Jaipur - 302022. Mob:8947822222 E-mail: info@danish.co.in	500kVA Star2 Rated(EEL-3/5star rated), CRGO Core, Aluminium/Copper Wound Distribution Transformers, .	17.12.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-170 dated: 13.11.2020 (Subject to revalidation every year)	Not revalidated
		1000kVA Star2 Rated(EEL-3/5star rated) CRGO Core ,Copper Wound Distribution Transformers	17.12.2024		
19	M/s Voltech Manufacturing Company Limited., Sy No: 212/1,212/2,213/3, Pillaipakkam Village, Sriperumputhur Taluk, Kanchipuram-602105) (E- mail: transformers@voltechgroup.com) (Ph No: 91-44-27107288)	250kVA, Star2 Rated(EEL-3/5star rated), CRGO Core, Copper Wound, Distribution Transformers,	18.03.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-63 dated: 30.07.2020 (Subject to revalidation every year)	18.03.2024 GM(QS&S)DGM(EL.)-3/AE/BC-11/ 23-24/ /Cys-72 dated: 11.08.2023
20	M/s Unipower Technical Services and Consultancy Pvt Ltd., #47/2, Kachohalli Village, Dasanapura Hobli, Magadi Main Road, Bengaluru-590091 Ph No: 9742387774 Email:marketing@unipts.com/ contact@unipts.com.	200kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound	09.09.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-70 dated: 11.08.2020 (Subject to revalidation every year)	08.12.2023 GM(QS&S)DGM(EL.)-3/AE/BC-11/ 22-23/Cys-91 dated: 19.12.2022
		25kVA, EEL-1 (1star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound	09.09.2026	GM(QS&S)/AE/BC-11/ 21-22/Cys-131 dated: 08.12.2021 (Subject to revalidation once in 2 years)	19.12.2024 GM(QS&S)DGM(EL.)-3/AE/BC-11/ 22-23/Cys-91 dated: 19.12.2022
		63kVA, 100kVA and 250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound	07.04.2028	GM(QS&S)/DGM-3/AE/BC-11/ 23-24/ Cys-32 dated: 12.06.2023 (Subject to revalidation once in 2 years from the date of issue of this OM)	
21	M/s Ohm Sree Manikanta Electricals, No: 23, 3rd 'a' cross, TTP Colony, Nelagadarahalli, Nagasandra Post, Bangalore - 560073 (Factory Unit: Sy. No.111/2, Site No 1 & 2, Gangondanahalli village, Near Nice Road Bridge, Lakshimpura Post, Bangalore North Taluk, Bangalore - 562123) (Ph No: 0808- 22792936, 080-2272445) (E-mail: Transformers@osmec.co.in)	250kVA, Star2 rated (EEL-3/5star) Distribution Transformer, CRGO core, Aluminium wound	04.12.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-99 dated: 28.08.2020 (Subject to revalidation every year)	Not revalidated
		500kVA, Star2 rated (EEL-3/5star) Distribution Transformer, CRGO core, Copper wound	10.01.2024		
22	M/s S.M. Enterprises. (TM AND OD), No.4911, Beside Fire station, M.C.Road, Mandya - 571402 Ph No. 9900111081, 08232-297029 Email: smendy@gmail.com	100kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers CRGO Core, Aluminium Wound	25.11.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-116 dated: 07.09.2020 (Subject to revalidation every year)	Not revalidated
		250kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers, CRGO Core, Aluminium Wound	09.12.2024		
		500kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers, CRGO Core, Aluminium Wound	11.01.2025		
23	M/s Chuan Shun Electric Company Jigani Private Limited (CSE Power). No.79-B, KIADB Industrial Area, Jigani Phase I, Jigani, Anekal Taluk, Bangalore-560105. Ph No: 91 80 29776476/77/78 8762800500 & 9945280876	63kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers	09.10.2025	GM(QS&S)/AE/BC-11/21-22/CYS-132 dated:10.12.2021 (Subject to revalidation once in 2 years)	Not revalidated
		100kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers			
		250kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, Aluminium/ Copper Wound, ONAN Cooled, Distribution Transformers			
	M/s Sri Sairam Power Controls #1/4, Lakshamaiah Industrial Layout, Abbigere Bangalore - 560090	25kVA, Star1 Rated(EEL-2/4star) CRGO Core, Aluminium wound 50Hz, Distribution Transformers	17.11.2025		

24	Vinod Power Controls Ph No:91-080-23253811/ E-mail: info@sairampowercontrols.com/ sairampower@gmail.com	200kVA Star2 Rated(EEL-3/ 5star rated), 50Hz, CRGO Core, Aluminium Wound, Distribution Transformers		GM(QS&S)/AE/BC-11/21-22/CYS-153 dated:17.01.2022 (Subject to revalidation once in 2 years)	
		500kVA Star2 Rated(EEL-3/ 5star rated), 50Hz, CRGO Core, Aluminium Wound, Distribution Transformers	13.10.2025		
25	M/s Power Tech Transformers, No.32, Indranagar, Near RNS Paints, Nagasandra Post, Doddabiderakallu, Bangalore - 560073 Ph No:96630220273/9886020326 E-mail:Powertech.vinod@gmail.com	100kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, Distribution Transformers	25.11.2025	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys-155 dated: 25.01.2022 (Subject to revalidation once in 2 years)	
26	M/s S.K. Transformer, No.71/2, Seegehalli Village, Magadi Main Road, Bangalore - 562130 Ph:9341252405 E-mail:sk.trafo.co@gmail.com	25kVA, 63kVA & 100kVA Star1 Rated (EEL-2/4star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers (Star 1 rated Distribution Transformers shall be used in Rural Area only)	29.11.2026	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys-157 dated: 28.01.2022 (Subject to revalidation once in 2 years)	
		250kVA, Star2Rated (EEL-3/5star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers. (Star2 rated Distribution Transformers shall be used in Urban Area only)	08.12.2026		
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	21.08.2028	BESCOM/GM(QS&S)/AE/BC-11/ 23-24/Cys-117 dated: 07.11.2023 Subject to revalidation once in 2 years from the date of issue of this OM	
		500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
27	M/s Vijay Electricals (VE Transformers) No:9, Byraveshwara Industrial Estate, Andrahalli Main Road, Near Peenya 2nd stage, Bangalore - 560091 Mob:9035620230,9986395630 Email:v-electricals@yahoo.in/ marketing@vetransformers.com	25kVA star1 rated (EEL-2/4 star), CRGO core, 50Hz, Distribution Transformers, (Star1 rated Distribution Transformers shall be used in Rural Area only)	29.01.2025 (Subject to revalidation once in 2 years)	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys-158 dated:31.01.2022	
		63kVA & 100kVA star1 rated (EEL-2/4 star), CRGO core, 50Hz, Distribution Transformers, (Star1 rated Distribution Transformers shall be used in Rural Area only)	25.03.2026 (Subject to revalidation once in 2 years)		
		63kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core,	08.07.2027 (Subject to revalidation once in 2 years)	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-94 dtd:21.12.2022	
		Vendor Approval			
		500kVA star2 rated (EEL-3/5 star), Aluminium & Copper wound, CRGO Core Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	23.07.2024	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys-158 dated:31.01.2022	
		1000kVA star2 rated (EEL-3/5 star), Copper wound, CRGO Core 50Hz, Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	04.10.2024		
28	M/s Venkat Switchgears, No:150, 10th Main, 3rd Phase, Peenya Industrial Area, Bangalore - 560058 (Ph No:080 23722274) (E-mail: lakshmpathiad @venkatswitchgears.com)	250kVA, Star2 Rated(EEL-3/5star rated), Distribution Transformers	01.04.2024	GM(QS&S)DGM(EEL-3)-BC-11/ 19-20/ Cys-62 dated:10.07.2019 (Subject to revalidation every year)	Not revalidated
		63kVA & 100kVA star1 rated (EEL-2/4 star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers (Star1 rated Distribution Transformers shall be used in Rural Area only)	28.02.2027	BESCOM/GM(QS&S)/AE/BC-11/21-22/CYS-176 dtd:22.03.2022 (Subject to revalidation once in 2 years)	
		200kVA, Star2 Rated (EEL-3/5star rated) Aluminium wound & Copper wound, CRGO core, Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	11.07.2024		
29	M/s SLV Transformer, Ground floor, Sy No.124, Near Abhaya School, Jangalpalya Village, Jigani Hobli Anekal Taluk, Bangalore - 560083 Ph No:9686661992/9448369932 E-mail: slvtransformer20@gmail.com	25kVA, star1 rated, Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	16.02.2026	BESCOM/GM(QS&S)/AE/BC-11/2022-23/CYS-21 dtd: 21.06.2022 (subject to revalidation once in 2 years)	
		63kVA, star1 rated, Distribution Transformers, CRGO core, 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	14.04.2027		
		100kVA, star2 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-2 as per new amendment 4 of IS-1180)	25.11.2025		
		250kVA, star2 rated, Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-2 as per new amendment 4 of IS-1180)	08.02.2026		
30	M/s Vijayashree Power, Sy No. 113, NH-206, Behind Byraveshwara Petrol Bunk, Nittur, Gubbi Tq, Tumkur Dist-572223 Ph No: 9986261445/8904465178 E-mail: vijayashreepower@gmail.com	25kVA, star1 rated, Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	17.05.2026	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-25 dtd: 05.07.2022 (subject to revalidation once in 2 years)	
		100kVA, star2 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-2 as per new amendment 4 of IS-1180)	20.01.2026		
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	27.10.2024	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2023-24/CYS-110 dtd: 27.10.2023	
31	M/s R.V. Transformer manufacturing Co., D-14/A, Industrial Area, Lokikere Road, Davangere-577 005 E-mail: rvtransformer.mfgco@yahoo.in Ph:9448119142, 9980728611	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	17.02.2026	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-56 dtd: 15.09.2022 (Subject to revalidation once in 2 years)	
		100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium	22.02.2026	GM(QS&S)DGM(EEL-3)/AE/BC-11/ 22-23/ Cys-46 dated: 25.08.2022 (Subject to revalidation once in 2 years)	

32	M/s Supreme Power Technologies, Sy no:191, Kurubarahalli, Behind Jagadamba Petrol Bunk, Tavarekere Post, Magadi Main Road, Tavarekere, Bangalore - 562130 Ph:9880295333,9480220911 E-mail:supremepower@gmail.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	12.10.2026	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-133 dtd:11.12.2023 Subject to revalidation once in 2 years from the date of issue of this OM	
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	25.10.2026		
		250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	06.01.2027		
33	M/s Viji Power Transformers Pvt Ltd Plot No: 21, Metha Industrial Estate, Machohalli, Magadi Main Road, Bangalore. Contact No: 9900111089 E-mail: vijitechdinakar10@yahoo.com	25kVA & 63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	14.04.2027	GM(QS&S)/DGM(EL.-)3/AE/BC-11/ 22-23/Cys-52 dated: 09.09.2022 (subject to revalidation once in 2 years)	
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	29.06.2027		
		25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	22.09.2027		
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	07.12.2027				
34	M/s Vijay Transformer Vidyuth Company No:4, Survey No.63/1 & 63/2, Karibohhanahalli, Thigalarapalya Village, Peenya 2nd stage, Bangalore - 560058 Ph:9886824635/9900126914 E-mail: vijaytransformer2020@gmail.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	17.02.2026	GM(QS&S)/DGM(EL.-)3/AE/BC-11/ 22-23/Cys-53 dated: 09.09.2022 (Subject to revalidation once in 2 years)	
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	17.05.2026		
		100kVA & 250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound,	03.03.2026		
35	M/s Dynalektrik Equipment Private Limited, #49/2, Vaderamanahalli Village, Kalu bahu to anekal Road, Jigani Hobli, Anekal Taluk, Bengaluru (Bangalore) Urban, Karnataka - 560105 Ph :91(80)29611999 E-mail:info@dynalektrik.com	250kVA 2Star Rated(EEL-2), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	10.02.2026	GM(QS&S)/DGM-3/BC-11/22-23/CYS-55 dated: 13.09.2022 (Subject to revalidation once in 2 years)	Not revalidated
		25kVA & 63kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	14.07.2026		
		Vendor Approval			
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	09.09.2023		
36	M/s Vijay Vidyuth Udyog #10, Survey No: 168/1, Machohalli, Dasanapura Hobli, Magadi Road, Bengaluru -560 091. Ph no: 966345451 / 9341225120 & 9341225512 Email:info@vijayvidyuth.com	25kVA, 63kVA & 100kVA EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	01.08.2027	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-60 dtd:19.09.2022 (Subject to revalidation once in 2 years)	
		25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	25.01.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-130 dtd:10.02.2023 (Subject to revalidation once in 2 years)	
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	25.01.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-107 dtd:21.04.2023 (Subject to revalidation once in 2 years)	
		100 kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	25.01.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-130 dtd:10.02.2023 (Subject to revalidation once in 2 years)	
		250 kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	25.01.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-130 dtd:10.02.2023 (Subject to revalidation once in 2 years)	
		500 kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	28.02.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-07 dtd:21.04.2023 (Subject to revalidation once in 2 years)	
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	10.02.2027 (Subject to revalidation once in 2 years)	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-76 dtd:03.11.2022	
37	M/s Macro Power Controls, No.24, 2nd cross, Kadabagere cross, Magadi Main Road, Behind Bus Stop, Bangalore - 560091. E-mail: dmacropower@yahoo.in Ph:8792708263/8792708264/8792708267/ 8861954803	250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	13.10.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-101 dtd:02.01.2023	

		500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	22.11.2027	(Subject to revalidation once in 2 years)	
38	M/s Flow Line Transformers Private Limited, No.82/3B, B.H.Road, Basavanahalli, Nalamangala, Bangalore - 562123 Ph No: 918027724092/27723938 Email:sales@flowlinetransformers.com	25kVA, 63kVA & 100kVA EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	29.10.2026	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-84 dated: 28.11.2022 (Subject to revalidation once in 2 years)	
		200kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	19.07.2026		
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	14.06.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-90 dtd: 13.09.2023 (Subject to revalidation once in 2 years)	
		500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	11.07.2027		
39	M/s Sri Shanthaveera Transformers MFG. Co., Basavanapura Main Road, Swathanthranagar, Opp. SEA college, Virgonagar Post, Bangalore - 560049. Ph No: 080-95436753/ 9844469813 E-mail: shanthaveeraa@yahoo.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	01.08.2027	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-117 dated:19.01.2023 (Subject to revalidation once in 2 years)	
40	M/s Vijay Electric Co., Factory Unit: #146/117/34/3, Kadabagere Village, Dasanapura Hobli, Bangalore-562130 Regd Office: No.22, Vyshnavinagar, Babasabpalya, Kengeri, Bangalore - 560060. Ph No: 91 9886406701/ 9886606764 Email:info@vijayelectric.com/ sales@vijayelectric.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	25.01.2028 (Subject to revalidation once in 2 years)		
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	04.02.2028 (Subject to revalidation once in 2 years)		
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	10.02.2028 (Subject to revalidation once in 2 years)		
		25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	04.07.2024	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-131 dated:13.02.2023	
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	20.10.2027 (Subject to revalidation once in 2 years)		
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	16.05.2027 (Subject to revalidation once in 2 years)		
		250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	01.11.2027 (Subject to revalidation once in 2 years)		
		500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	07.01.2024		
		1000kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	05.03.2025	GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-121 dated:10.11.2023	
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	12.01.2026		
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	12.12.2027		
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.		GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-25 dated:24.05.2023 (Subject to revalidation once in 2 years from the date of issue of this OM)	
		250kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	25.02.2028		

41	<p>M/s Chaitanya Electric Company,          Sy No: 60/2, Seegehalli, Magadi Main Road,          Bangalore - 560112.          Ph no: 9606260808          Email:          chaitanyaelectric@rediffmail.com</p>	<p>100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	01.12.2027		
		<p>250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	03.01.2028		
		<p>500kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	12.06.2028		
		<p>25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	12.06.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-146 dated:29.12.2023	Subject to revalidation once in 2 years from the date of issue of this OM
		<p>63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	12.06.2028		
		<p>500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	22.05.2028		
42	<p>M/s Raj power Controls, No.116/7 &amp; 117/6,          mookambika Temple Road, Machohalli forest gate,          Magadi Main road, Bangalore - 560091,          Mob:9611146656,9886260538,          Email:rajpowers@live.com,          rajeshrgowda@gmail.com</p>	<p>250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	06.01.2025	GM(QS&S)/DGM(EI)-3/BC-11/20-21/CYS-13 dtd:12.05.2020	06.01.2025 GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-45 dtd:27.06.2023
		<p>500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	07.11.2024	(Subject to revalidation every year)	07.11.2024 GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-45 dtd:27.06.2023
		<p>25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	18.02.2028		
		<p>63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	20.02.2028		
		<p>100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	28.03.2028	GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-44 dtd:27.06.2023	(Subject to revalidation once in 2 years from the date of issue of this OM)
		<p>25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>			
		<p>63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	20.02.2028		
		<p>100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	26.04.2028		
43	<p>M/s Srinivasa Concrete Products,          Sy No.156/1, #547, Alur Village, Anaji Hobli,          Davangere - 577512          Ph No:9448213045/8553502125 E-mail:          srinivasaelectricals16@gmail.com</p>	<p>25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>			
		<p>25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	07.07.2024	GM(QS&S)/DGM-3/AE/BC-11/23-24/ CYS-50 dtd:07.07.2023	
		<p>100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>			
44	<p>M/s K V T Associates,          Plot No.89 P1, 2nd stage, Mundargi Industrial Area, KIADB, Bangalore Road, Ballari - 583102          Ph No: 9448006807/ 9535319570</p>	<p>25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>			
		<p>63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>	25.07.2024	GM(QS&S)/DGM-3/AE/BC-11/23-24/ CYS-57 dtd:26.07.2023	
		<p>100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 &amp; IS - 2026.</p>			

45	<p>M/s Prakash Metal Products, Registered Office: 101/1B/3, Ayodhya Village, Near Kempageri, Karwar Road, Hubballi. Unit-I: Sy No:101/1B/3, Ayodhya Village, Near Kempageri, Karwar Road, Hubballi Unit-II Sy No: 47, Anchatager Village, Karwar Road, Hubballi Ph No: 0836-2303024 E-mail: prakash_pmp@yahoo.co.in</p>	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	28.07.2025	GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-61 dtd:28.07.2023	
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	19.07.2027 (Subject to revalidation once in 2 years from the date of issue of this OM)		
		25kVA, EEL-2 (2star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
		63kVA, EEL-2 (2star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	04.08.2027 (Subject to revalidation once in 2 years from the date of issue of this OM)		
		100kVA, EEL-2 (2star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	22.05.2024		
46	<p>M/s Kiran Power Rectification Services (P) Ltd., Plot No. 10, 4th Phase, Bommasandra Industrial Area, Jigani Bommasandra Link Road, Bangalore - 560099 Ph No: 080-42077095 9901599774/9886520575 /9741158602 E-mail:sales@kprindia.com</p>	250kVA, EEL-2 (2star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	15.08.2028	GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-96 dtd: 22.09.2023 (Subject to revalidation once in 2 years)	
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	07.08.2028		
		250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
47	<p>M/s Astron Elektrik Sy No: Old 48, New 48/3, 3rd Main, Keonics Layout, Karivobanahalli, Thigalarapalya Main Road, Peenya 2 nd stage, Bangalore - 560058 Registered Office: No.V-44, 8th Main Road, 2nd stage, Peenya Industrila Area, Bangalore - 560058 Mob: 9986699522/903567147 E-mail:astronelektrik@gmail.com/ astronelektrik@yahoo.com</p>	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	19.10.2024	GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-107 dtd: 19.10.2023	
		63kVA, 100kVA & 250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
48	<p>M/s Suvarna Transformers, Kabbinahally, Gorur Road, Hassan - 573201 Registered Office: 11-6-513, 2nd floor, Jyothi Building, Maidan Road, Mangalore, Dakshina kannada - 575001 Ph No: 9448466925 E-mail: suvarnatransformers@gmail.com</p>	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	13.01.2027	GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-109 dtd: 27.10.2023 Subject to revalidation once in 2 years from the date of issue of this OM	
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	05.01.2027		
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	29.11.2026		
49	<p>M/s J.M. Electrical Works, Sy No.224/C/3, Holagundi Road, Near by JSS collage, Huvinahadagali Town &amp; Taluk, Ballari - 583219 Ph No: 9902371432 E-mail: dileepjmew@gmail.com</p>	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	24.08.2028	GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-116 dtd:06.11.2023 Subject to revalidation once in 2 years from the date of issue of this OM	
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	22.08.2028		
		25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	08.08.2028		
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	17.08.2028		



50	M/s Maruthi Electrical and Engineering Works. Plot No.5, Near Jnana Bharathi School, Holalkere Road, KHB Colony, Chitradurga - 577501 E-mail: meewtransformers@gmail.com Ph: 8277291999/9448169800	63kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026	04.01.2025	GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS- 148 dtd:04.01.2024 Subject to revalidation once in 2 years from the date of issue of this OM
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	27.07.2028	