

Distribution Transformers

Sl. No.	Name of the firm	Material Approved	Valid upto	O.M. No. & Date	Status of revalidation	
1	M/s Kailash Transformers Pvt Ltd., #23, KIADB, 1st stage, Kapnoor Industrial Area, Kalaburagi – 585 104 Ph No: (08472) 257449. E-mail: kailashpvtltd1@gmail.com	25kVA, 63kVA & 100kVA, star1 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and conforming to latest versions of IS – 1180 & IS – 2026. (EEL-1 as per new amendment 4 of IS-1180)	25.01.2027	BESCOM /GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-32 dtd:19.07.2022 (Subject to revalidation once in 2 years)		
		25kVA, 63kVA & 100kVA Star2 Rated (EEL-3/5star rated), Distribution Transformers, Amorphous Core	26.11.2023	GM(QS&S)DGM(EL.,)-3/BC-11/ 20-21/Cys-32 dated:02.06.2020 (Subject to revalidation every year)		
2	M/s Mahalakshmi Transformers, No. 16, 13th Cross, Kareemsaab Layout, Hegganahalli, Peenya 2nd Stage, Bangalore-91 Mob:9845862604 E-mail:mit_koparde@yahoo.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and conforming to latest versions of IS – 1180 & IS – 2026.	30.03.2027	BESCOM /GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-77 dtd:05.11.2022 (subject to revalidation once in 2 years)		
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and conforming to latest versions of IS – 1180 & IS – 2026.	19.04.2027			
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and conforming to latest versions of IS – 1180 & IS – 2026.	07.04.2027			
			63kVA Star2 rated (EEL-3/5 star) Distribution Transformer, CRGO core	03.09.2023		03.09.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-54 dtd:04.08.2021
			100KVA Star2 rated (EEL-3/5 star) Distribution Transformer, CRGO core	23.08.2023	GM(QS&S)DGM(EL.,)-3/BC-11/ 18-19/Cys-185 dated:02.02.2019 (Subject to revalidation every year)	23.08.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-54 dtd:04.08.2021
			250kVA Star2 rated (EEL-3/5 star) Distribution Transformer, CRGO core	24.09.2023		24.09.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-54 dtd:04.08.2021
3	M/s Shridi sai Electricals limited., plot No: 13/82, Industrial estate, Kadapa Dist.,Andhra Pradesh	25kVA, 63kVA, 100kVA, 250kVA & 500kVA, Star2 Rated (EEL-3/5 star), Al. wound, Amorphous Core Distribution Transformers,	02.07.2023	GM(QS&S)DGM(EL.,)-4/BC-11/ 17-18/Cys-306 dated:21.03.2018 (Subject to revalidation every year)	09.02.2022 GM(QS&S)/DGM(EL)-3/BC-11/21-22/CYS-64 dtd: 17.08.2021	
					GM(QS&S)/DGM(EL)-3/BC-11/21-22/CYS-64 dtd: 17.08.2021	
4	M/s Raikar Electric Company, No:20, Raghavendra Industrial Estate, Thigalarpalya Main Road, Near peenya 2nd stage, Bangalore - 560058. Ph No: 9845169654, 9535256093. E-mail:raikar.blr2000@gmail.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and conforming to latest versions of IS – 1180 & IS – 2026.	18.10.2023	GM(QS&S)/DGM-3/AE/BC-11/ 23-24/Cys-08 dated: 26.04.2023		
		63kVA & 100kVA Star2 Rated (EEL-3/5 star rated) Al wound, CRGO core, Distribution Transformers	12.03.2024	GM(QS&S)/AE/BC-11/ 21-22/Cys-141 dated:27.12.2021 (Subject to revalidation once in 2 years)		
		250kVA & 500kVA Star2 Rated (EEL-3/5 star rated) Al wound, CRGO core, Distribution Transformers	23.06.2025			
5	M/s Perfect Electricals, Plot No: 152, Sompura 1st stage, KIADB, Near Dabaspete, Nelamangala Taluk, Bangalore – 562111. Ph No:9845062309. E-mail: perfectswamy@yahoo.com	25kVA star1 rated (EEL-2/4 star), Distribution Transformers	03.09.2023	GM(QS&S)DGM(EL.,)-3/BC-11/ 18-19/Cys-164 dated:01.01.2019 (Subject to revalidation every year)	03.09.2023 GM(QS&S)DGM(EL.,)-3/BC-11/ 20-21/Cys-294 dated:31.03.2021	
		63kVA & 100kVA star1 rated(EEL-2/4 star), Distribution Transformers	05.11.2023		05.11.2023 GM(QS&S)DGM(EL.,)-3/BC-11/ 20-21/Cys-294 dated:31.03.2021	
		500kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	26.12.2024	GM(QS&S)DGM(EL.,)-3/BC-11/ 19-20 /Cys-221 dated:10.03.2020	30.03.2023 GM(QS&S)DGM(EL.,)-3/BC-11/ 20-21/Cys-294 dated:31.03.2021	
		25kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled Distribution Transformers,	23.11.2025	GM(QS&S)/AE/BC-11/ 21-22 /Cys-133 dated:10.12.2021 (Subject to first revalidation dated before: 10.12.2022 and then it will be revalidated once in 2 years)		
		63kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers				
		100kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers	14.08.2026	GM(QS&S)/AE/BC-11/ 21-22 /Cys-133 dated:10.12.2021 (Subject to first revalidation dated before: 10.12.2022 and then it will be revalidated once in 2 years)		
		250kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers				

6	M/s Primetech Transformers, Kuthanur Village, Calicut Road, Gundulpet Taluk, Gundlupet – 5711111, Chamarajinagar (Ph No:9242783800) (E-mail:roopacorporation@yahoo.com)	25kVA & 63kVA star1 rated (EEL-2/4 star), CRGO Core Distribution Transformers	14.08.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 18-19/Cys-173 dated:19.01.2019	16.04.2021 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-27 dated:29.05.2020	
7	M/s Vijay Power control systems, B-65 & P-16, 3 rd cross, 3 rd stage Peenya industrial Estate, Bangalore-560 058 Ph:info@vijaytransformers.com	63kVA, 100kVA & 250kVA star2 rated (EEL-3/5star rated), Distribution Transformers, CRGO Core	16.08.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 18-19/Cys-189 dated:11.02.2019 (Subject to revalidation every year)		
		500kVA star2 rated (EEL-3/5star rated), Distribution Transformers, CRGO Core,	20.12.2023			
8	M/s Maruthi Electrical & Engineering Works, Plot No:5, Near Jnana Bharathi School, Holalkere Road, Chitradurga - 577501 Contact No: 8277291999/9448169800 E-mail: meewtransformers@gmail.com	25kVA, 63kVA, and 100kVA BEE star1 rated(4star/EEL-2) Distribution Transformers, CRGO Core	23.04.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 18-19/Cys-191 dated:12.02.2019 (Subject to revalidation every year)	23.04.2023 GM(QS&S)DGM(EL.-3)/BC-11/21-22/CYS-59 dtd:09.08.2021	
9	M/s Vignesh Vidyuth controls, No. 55, 17th Cross (Old 30th Cross), Doddanna Industrial Estate, Peenya 2nd Stage, Bangalore-91 Contact No: 9845134612/9886634612 E-mail: vigneshvidyuth@rediffmail.com	25kVA, BEE star1 rated (4star/EEL-2) Distribution Transformers, 50Hz, CRGO Core	05.11.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 18-19/Cys-205 dated:05.03.2019 (Subject to revalidation every year)		
		250kVA & 500kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	09.07.2025	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-164 dated:09.11.2020 (Subject to revalidation once in 2 yerass)		
10	M/s National Transcare Sy No:17/4, Opp Agriculture University, Lingasugur Road, Raichur - 584101 Contact No:9845244968/7795228032 E-mail:ntccrcr@rediffmail.com ntcrcr@yahoo.com	25kVA, star1 rated (EEL-2/4star) Distribution Transformers, CRGO Core	12.11.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 19-20/Cys-48 dated:18.06.2019 (Subject to revalidation every year)		
		63kVA, star1 rated (EEL-2/4star) Distribution Transformers, CRGO Core				
		100kVA, star1 rated (EEL-2/4star) Distribution Transformers, CRGO Core	05.07.2023			
11	M/s V.T. Switchgears and Transformers, No:33, 3rd Phase, 4th Main, Peenya Industrial Area, Bangalore - 560058 Ph no:91-80-28392235/35, 9844028978, 9986523600 E-mail:vtstbg@gmail.com, city@vtst.in	100kVA star2 rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core	30.11.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 19-20/Cys-51 dated:21.06.2019 (Subject to revalidation every year)		
		250kVA star2 rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core				
		500kVA star2 rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core	14.03.2024			
12	M/s Chetan Electric Private Limited, No:32-B, Veerasandra, KIADB Industrial Area, Anekal Taluk, Electronic City Post, Bangalore – 560100 Mob:080-25536439 Email:chetanelectric@hotmail.com, chetanelectric@yahoo.com & chetanelectric10@gmail.com	25kVA Star1/Star2 Rated (EEL-2/EEL-3), Distribution Transformers, 50Hz, CRGO Core	08.06.2024	GM(QS&S)DGM(EL.-3)/BC-11/ 19-20/Cys-52 dated:21.06.2019 (Subject to revalidation every year)		
		63kVA Star1/Star2 Rated (EEL-2/EEL-3), Distribution Transformers, 50Hz, CRGO Core				
		100kVA Star1/Star2 Rated (EEL-2/EEL-3) Distribution Transformers, 50Hz, CRGO Core	29.05.2024			
		250kVA Star1/Star2 Rated (EEL-2/EEL-3), Distribution Transformers, 50Hz, CRGO Core	04.03.2024			
13	M/s Cauvery Power Control, Sy No: 31/2, Chennaih Badavane, Annabesent School Road, Gollarahatti, Magadi Main Road, Vishwaneddam Post, Bangalore – 560091 Contact No:9880922686/9741122686 E-mail:cauverypower@gmail.com	25kVA/63kVA/100kVA, Star1 Rated (EEL-2/4 star), Distribution Transformers	24.12.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 19-20/Cys-58 dated:06.07.2019 (Subject to revalidation every year)	24.12.2023 GM(QS&S)DGM(EL.-3)/BC-11/21-22/CYS-55 dtd:05.08.2021	
		63kVA/100kVA, Star2 Rated (EEL-3/5 star), Distribution Transformers,	24.12.2023			
14	M/s EL-TRA Equipment Company(l) Pvt Ltd, 11th Mile, NH-4, Old Madras Road, Avalahalli, Virognagar P.O, Bangalore- 560049 (Ph No:080 28472790/28472229) (E-mail: Eltra5@rediffmail.com, eltra2012@gmail.com)	100kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers	13.12.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 19-20/Cys-72 dated:23.07.2019 (Subject to revalidation every year)	13.12.2023 GM(QS&S)DGM(EL.-3)/BC-11/20-21/CYS-110 dtd:08.11.2021	
		250kVA & 500kVA Star2 Rated (EEL-3/5star rated), Distribution Transformers	10.04.2024		10.04.2024 GM(QS&S)DGM(EL.-3)/BC-11/20-21/CYS-110 dtd:08.11.2021	
15	M/s Amar Industries, Plot No: #R9 TO R12, KSSIDC Industrial Estate, Hosahalli Camp(E.J), Sindhanur-584 128, Raichur Mob No: 9538361911,9739384442, 9742243677 E-mail:aisnd2015@gmail.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	23.06.2027 (Subject to revalidation once in 2 years from the date of issue of this OM)	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-19 dtd:08.05.2023		
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	09.06.2027 (Subject to revalidation once in 2 years from the date of issue of this OM)			
		100kVA EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180	29.11.2023			29.11.2023 BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-19 dtd:08.05.2023
		25kVA, Star2 rated (EEL-3/5star) CRGO core, Aluminium wound, Distribution Transformer				04.10.2023 GM(QS&S)DGM(EL.-3)/BC-11/2021-22/CYS-96 dtd:04.10.2021
		63kVA, Star2 rated (EEL-3/5star) CRGO core, Aluminium wound, Distribution Transformer,	07.06.2024			

		100kVA, Star2 rated (EEL-3/5star) CRGO core, Aluminium wound, Distribution Transformer,			
16	M/s B.M.G Transformers Site No:15&16, Sy No:34/3, Kadabagere Village, Dasanapura Hobli, Bangalore - 562130 (Ph No:9448622534 / 9880869024) (E-mail: bmgtransformers@yahoo.com)	25kVA & 63kVA, Star1 Rated(EEL-2/ 4star) Distribution Transformers, CRGO Core, Aluminium wound	22.12.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-109 dated:06.09.2019 (Subject to revalidation every year)	
		100kVA, Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound	27.09.2023		
17	M/s Shri Datta Transformers, No:405, Mudhol Jankhandi Main Road, Shirol Cross, Shirol, Mudhol Taluk, Dist Bagalkot, Karnataka - 587313 Mob: 9886313068, 9538593449	25kVA & 63kVA Star1 Rated (EEL-2/4star),Distribution Transformers, 50Hz, CRGO Core, Aluminium wound	25.10.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-119 dated:23.09.2019 (Subject to revalidation every year)	
		100kVA, Star2 Rated (EEL-3/5 star),Distribution Transformers, 50Hz, CRGO Core, Aluminium wound	10.12.2023		
18	M/s Karthik Electricals, #A195, 4th Cross, Peenya 1st stage, Peenya Industrial Estate, Bangalore - 560058 Ph No: 9980014892,8884762 574 E-mail: karthiktransformers@yahoo.in	25kVA, 63kVA & 100kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound	13.06.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-157 dated:18.11.2019 (Subject to revalidation every year)	13.06.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 2021-22/Cys-125 dated:23.11.2021
		63kVA Star2 Rated (EEL-3/ 5star) Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	23.05.2024		23.05.2024 GM(QS&S)DGM(EL.)-3/BC-11/ 2021-22/Cys-125 dated:23.11.2021
		100kVA Star2 Rated (EEL-3/5 star) Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound	30.04.2024		
19	M/s Shree Bhyraveshwara Electrical Works, #M1, Industrial Area, Lokikere Road, Near Bypass, Davangere- 577 005. Ph No: 9449683214/9448463453. E-mail: anandm1020@rediff.com/ vmnrnataraj99@gmail.com	25kVA, Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound	25.07.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-175 dated: 23.12.2019 (Subject to revalidation every year)	25.07.2023 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-272 dtd:04.03.2021
		100kVA, Star2 rated (EEL-3/5star) Distribution Transformer, CRGO core, Aluminium wound	18.11.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-115 dated: 07.09.2020 (Subject to revalidation every year)	04.03.2023 GM(QS&S)/DGM(EL.)-3/BC-11/20-21/CYS-272 dtd:04.03.2021
20	M/s. Kalpa Elektrikal Pvt Ltd., No.4413, 149/25, III main road, Industrial town, Rajajinagar, Bangalore - 560010 Ph No: 080-23303103, 23356049 & 23405248 Email: sales@kalpaelektrikal.com.	200kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound,	17.7.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/ Cys-179 dated: 26.12.2019 (Subject to revalidation every year)	28.10.2023 BESCOM/GM(QS&S)/DGM-3/BC-11/2021-22/CYS-112 dtd:08.11.2021
21	M/s S.M. Enterprises, No.4911, M.C. Road, Beside Fire station, Mandya - 571402 (Ph No: 9900111081 08232-297029) E-mail: smemdy@gmail.com	25kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	11.12.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/ Cys-195 dated: 16.01.2020 (Subject to revalidation every year)	
		63kVA & 100kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	11.03.2024		
22	M/s Magnitude, #480 B/2, IV Phase, Peenya Industrial Area, Bangalore - 560058 (Ph No:91 80 41227804) E-mail: magnitudetransformer@gmail.com	25kVA, Star1 Rated(EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	04.04.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-198 dated: 28.01.2020 (Subject to revalidation every year)	
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	10.03.2027	GM(QS&S)DGM(EL.)-3/BC-11/2022-23/Cys-118 dated:19.01.2023 (Subject to revalidation every year)	
		250kVA, Star2 Rated(EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	06.12.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-198 dated: 28.01.2020 (Subject to revalidation every year)	
		100kVA, Star2 Rated(EEL-3/5star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	18.05.2025	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-20 dated: 26.05.2020 (Subject to revalidation every year)	
		500kVA, Star2 Rated(EEL-3/5star) Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	10.06.2024	GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-130 dated: 28.09.2020 (Subject to revalidation every year)	
23	M/s Nagashree Enterprises, No:2, Mallaya Industrial Area, Kereguddadadahalli, Chikkabavara Post, Bangalore - 560090, Ph No:9449732909, 9663073059, 9538047909. E-mail:nagashreetra@gmail.com	25kVA & 63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	17.06.2023	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-151 dtd:17.03.2023	
		100kVA & 250, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.			
		100kVA, Star1 Rated(EEL-2/4star) CRGO Core Distribution Transformers	18.07.2023		18.07.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-281 dated: 17.03.2021
		25kVA Star2 Rated(EEL-3/5star rated), CRGO Core Distribution Transformers	19.12.2024		17.03.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-281 dated: 17.03.2021
		63kVA Star2 Rated(EEL-3/5star rated), CRGO core Distribution Transformers	18.07.2023	GM(QS&S)DGM(EL.)-3/BC-11/ 19-20/Cys-211 dated: 19.02.2020 (Subject to revalidation every year)	18.07.2023 GM(QS&S)DGM(EL.)-3/BC-11/ 20-21/Cys-281 dated: 17.03.2021

		500kVA Star2 Rated(EEL-3/5star rated), CRGO core Distribution Transformers	03.12.2024		17.03.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-281 dated: 17.03.2021
24	M/s Excel Power controls & Systems, #53/1,2nd Main, Off Magadi Main Road, Kottigepalya, Bangalore-560091 Ph No: 9845332465 Email: exceltrafos@gmail.com	11kV/433V ,3 Phase- Distribution Transformers, CRGO Core, Al wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. 25kVA, star1 rated (EEL-2/4star rated) 100kVA,star1 rated (EEL-2/4star rated) & star2 rated (EEL-3/5star rated) 250kVA,star2 rated (EEL-3/5star rated) 500kVA,star2 rated (EEL-3/5star rated)	18.01.2025 24.05.2024 09.11.2024 20.02.2025	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-02 dated: 17.04.2020 (Subject to revalidation every year)	
25	M/s Nandadeepa Power Controls, No:30, Kachohalli Industrial Area, Dasanapura Hobali, Bangalore - 562123 (Ph No: 9066619819) (E-mail: npctransformer@gmail.com, ganpathdewasi2013@gmail.com)	25kVA Star1 Rated (EEL-2/4star) Distribution Transformers, CRGO Core, Aluminium wound 100kVA, Star2 Rated (EEL-3/5star rated), Distribution Transformers, , CRGO Core, Copper Wound,	07.09.2023 11.01.2025	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-29 dated: 30.05.2020 (Subject to revalidation every year)	
26	M/s Danish Private Limited., F-679-680,G-694, Sitapur Industrial Area, Jaipur - 302022. Mob:8947822222 E-mail: info@danish.co.in	500kVA Star2 Rated(EEL-3/5star rated), CRGO Core, Aluminium/Copper Wound Distribution Transformers, , 1000kVA Star2 Rated(EEL-3/5star rated) CRGO Core ,Copper Wound Distribution Transformers	17.12.2024 17.12.2024	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-170 dated: 13.11.2020 (Subject to revalidation every year)	
27	M/s Voltech Manufacturing Company Limited., Sy No: 212/1,212/2,213/3, Pillaipakkam Village, Sriperumthur Taluk, Kanchipuram-602105) (E- mail: transformers@voltechgroup.com) (Ph No: 91-44-27107288)	250kVA, Star2 Rated(EEL-3/5star rated), CRGO Core, Copper Wound, Distribution Transformers, 500kVA, BEE star2 rated (EEL-3/5 Star rated) Distribution Transformers, CRGO core	18.03.2024 04.06.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-63 dated: 30.07.2020 (Subject to revalidation every year) GM(QS&S)DGM(EL.-3)/BC-11/17-18/Cys-85 dated: 28.07.2018 (Subject to revalidation every year)	18.03.2024 GM(QS&S)DGM(EL.-3)/BC-11/ 21-22/Cys-88 dated: 22.09.2021 04.06.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 21-22/Cys-88 dated: 22.09.2021
28	M/s Unipower Technical Services and Consultancy Pvt Ltd., #47/2, Kachohalli Village, Dasanapura Hobli, Magadi Main Road, Bengaluru-590091 Ph No: 9742387774 Email:marketing@unipts.com/ contact@unipts.com.	200kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound 25kVA, EEL-1 (1star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound 63kVA, 100kVA and 250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound 500kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	09.09.2024 09.09.2026 07.04.2028	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-70 dated: 11.08.2020 (Subject to revalidation every year) GM(QS&S)/AE/BC-11/ 21-22/Cys-131 dated: 08.12.2021 (Subject to revalidation once in 2 years) GM(QS&S)/DGM-3/AE/BC-11/ 23-24/ Cys-32 dated: 12.06.2023 (Subject to revalidation once in 2 years from the date of issue of this OM)	08.12.2023 GM(QS&S)/DGM-3/AE/BC-11/ 22-23/Cys-91 dated: 19.12.2022 19.12.2024 GM(QS&S)/DGM-3/AE/BC-11/ 22-23/Cys-91 dated: 19.12.2022
29	M/s Unimag Power Transformer Pvt Ltd., 26/A, II phase, Peenya Industrial Area, Bengaluru-560 058 (Ph No:8028396184, E-mail:contact@umpt.in)	500kVA star2 rated (EEL-3/5 star), Distribution Transformers, CRGO core,	27.07.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 18-19/Cys-112 dated: 09.10.2018 (Subject to revalidation every year)	14.08.2021 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-86 dated: 17.08.2020
30	M/s Ohm Sree Manikanta Electricals, No: 23, 3rd 'a' cross, TTP Colony, Nelagadarahalli, Nagasandra Post, Bangalore - 560073 (Factory Unit: Sy. No:111/2, Site No 1 & 2, Gangondanahalli village, Near Nice Road Bridge, Lakshimpura Post, Bangalore North Taluk, Bangalore - 562123) (Ph No: 0808-22792936, 080-2272445) (E-mail: Transformers@osmec.co.in)	100kVA, BEE star2 rated (EEL-3/5 Star rated) Distribution Transformers, Amorphous core 250kVA, Star2 rated (EEL-3/5star) Distribution Transformer, CRGO core, Aluminium wound 500kVA, Star2 rated (EEL-3/5star) Distribution Transformer, CRGO core, Copper wound	28.06.2023 04.12.2024 10.01.2024	GM(QS&S)DGM(EL.-4)/BC-11/ 17-18/Cys-123 dated:31.10.2018 (Subject to revalidation every year) GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-99 dated: 28.08.2020 (Subject to revalidation every year)	27.08.2021 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-98 dated: 28.08.2020
31	M/s S.M. Enterprises. (TM AND OD), No.4911, Beside Fire station, M.C.Road, Mandya - 571402 Ph No: 9900111081, 08232-297029 Email: smemdy@gmail.com	100kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers CRGO Core, Aluminium Wound 250kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers, CRGO Core, Aluminium Wound 500kVA Star2 Rated(EEL-3/5star rated), Distribution Transformers, CRGO Core, Aluminium Wound	25.11.2024 09.12.2024 11.01.2025	GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-116 dated: 07.09.2020 (Subject to revalidation every year)	
32	M/s J.M. Electrical Works, Sy No:224/C/3, Holagundi road, Near by JSS college, Huvinahadagali Town and Taluk, Ballari Ph No:9902371432 E-mail:dileepjmew@gmail.com	100kVA star2 rated (EEL-3/5star),Distribution Transformers, CRGO core	23.08.2023	GM(QS&S)DGM(EL.-3)/BC-11/ 18-19/Cys-133 dated: 13.11.2018	23.08.2023 GM(QS&S)DGM(EL.-3)/BC-11/ 20-21/Cys-290 dated: 25.03.2021
33	M/s Chuan Shun Electric Company India Private Limited (CSE Power), No.79-B, KIADB Industrial Area, Jigani Phase I, Jigani, Anekal Taluk, Bangalore-560105. Ph No: 91 80 29776476/77/78 8762800500 & 9945280876	63kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled,Distribution Transformers 100kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, Distribution Transformers 250kVA, Star2 Rated (EEL-3/5star rated), 50Hz, CRGO Core, Aluminium/ Copper Wound, ONAN Cooled,Distribution Transformers	09.10.2025	GM(QS&S)/AE/BC-11-21-22/CYS-132 dated:10.12.2021 (Subject to revalidation once in 2 years)	
34	M/s Sri Sairam Power Controls #1/4, Lakshamaiah Industrial Layout, Abbigere Village Bengaluru-560090 Ph No:91-080-23253811/ E-mail: info@sairampowercontrols.com/ sairampower@gmail.com	25kVA, Star1 Rated(EEL-2/4star) CRGO Core, Aluminium wound 50Hz,Distribution Transformers 200kVA Star2 Rated(EEL-3/ 5star rated), 50Hz, CRGO Core, Aluminium Wound, Distribution Transformers 500kVA Star2 Rated(EEL-3/ 5star rated), 50Hz, CRGO Core, Aluminium Wound, Distribution Transformers	17.11.2025 13.10.2025	GM(QS&S)/AE/BC-11-21-22/CYS-153 dated:17.01.2022 (Subject to revalidation once in 2 years)	
35	M/s Power Tech Transformers, No.32, Indiranagar, Near RNS Paints, Nagasandra Post, Doddabiderakallu, Bangalore - 560073 Ph No:9663020273/9886020326 E-mail:Powertech.vinod@gmail.com	100kVA Star2 Rated(EEL-3/5star rated), 50Hz, CRGO Core, Aluminium Wound, Distribution Transformers	25.11.2025	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys-155 dated: 25.01.2022 (Subject to revalidation once in 2 years)	

36	M/s S.K. Transformer, No.71/2, Seeghalli Village, Magadi Main Road, Bangalore - 562130 Ph:9341252405 E-mail:sk.trafo.co@gmail.com	63kVA Star2 Rated (EEL-3/5 star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers	31.12.2023	GM(QS&S)/DGM-3/BC-11/19-20/CYS-115 dtd:18.09.2019 (Subject to revalidation every year)	31.12.2023 GM(QS&S)/DGM(EI)-3/BC-11/20-21/CYS-239 dtd:04.02.2021
		500kVA, Star2 Rated (EEL-3/5 star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers,	10.06.2023		10.06.2023 GM(QS&S)/DGM(EI)-3/BC-11/20-21/CYS-239 dtd:04.02.2021
		25kVA, 63kVA & 100kVA Star1 Rated (EEL-2/4star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers (Star1 rated Distribution Transformers shall be used in Rural Area only)	29.11.2026	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys-157 dated: 28.01.2022 (Subject to revalidation once in 2 years)	
		250kVA, Star2Rated (EEL-3/5star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers. (Star2 rated Distribution Transformers shall be used in Urban Area only)	08.12.2026		
37	M/s Vijay Electricals (VE Transformers) No:9, Byraveshwara Industrial Estate, Andrahalli Main Road, Near Peenya 2nd stage, Bangalore - 560091 Mob:9035620230,9986395630 Email:v-electricals@yahoo.in/ marketing@vetransformers.com	100kVA & 500kVA star2 rated (EEL-3/5star) Distribution Transformer Revalidation of Vendor approval	04.09.2023	GM(QS&S)DGM(EI.)-3/BC-11/ 18-19/Cys-214 dated:20.03.2019	
		100kVA & 500kVA Star2 Rated (EEL-3/ 5star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	04.09.2023		
		Renewal of vendor approval			
		25kVA star1 rated (EEL-2/4 star), CRGO core, 50Hz, Distribution Transformers, (Star1 rated Distribution Transformers shall be used in Rural Area only)	29.01.2025 (Subject to revalidation once in 2 years)	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys-158 dated:31.01.2022	
		63kVA & 100kVA star1 rated (EEL-2/4 star), CRGO core, 50Hz, Distribution Transformers, (Star1 rated Distribution Transformers shall be used in Rural Area only)	25.03.2026 (Subject to revalidation once in 2 years)		
		250kVA star1 rated (EEL-2/4 star), CRGO core, Distribution Transformers, (Star1 rated Distribution Transformers shall be used in Rural Area only)	02.08.2023		
		63kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core,	08.07.2027 (Subject to revalidation once in 2 years)	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-94 dtd:21.12.2022	
		250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core,	05.03.2024		
		Vendor Approval			
		500kVA star2 rated (EEL-3/5 star), Aluminium & Copper wound, CRGO Core Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	23.07.2024	BESCOM/GM(QS&S)/AE/BC-11/ 21-22/Cys-158 dated:31.01.2022	
1000kVA star2 rated (EEL-3/5 star), Copper wound, CRGO Core 50Hz, Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	04.10.2024				
38	M/s Venkat Switchgears, No:150, 10th Main, 3rd Phase, Peenya Industrial Area, Bangalore - 560058 (Ph No:080 23722274) (E-mail: lakshmpathiad@venkatswitchgears.com)	250kVA, Star2 Rated(EEL-3/5star rated), Distribution Transformers	01.04.2024	GM(QS&S)DGM(EI.)-3/BC-11/ 19-20/Cys-62 dated:10.07.2019 (Subject to revalidation every year)	
		63kVA & 100kVA star1 rated (EEL-2/4 star), 50Hz, CRGO Core, Aluminium wound, Distribution Transformers (Star1 rated Distribution Transformers shall be used in Rural Area only)	28.02.2027		BESCOM/GM(QS&S)/AE/BC-11/21-22/CYS-176 dtd:22.03.2022 (Subject to revalidation once in 2 years)
		200kVA, Star2 Rated (EEL-3/5star rated) Aluminium wound & Copper wound, CRGO core, Distribution Transformers (Star2 rated Distribution Transformers shall be used in Urban Area only)	11.07.2024		
39	M/s SLV Transformer, Ground floor, Sy No.124, Near Abhaya School, Jangalpalya Village, Jigani Hobli Anekal Taluk, Bangalore - 560083 Ph No:9686661992/9448369932 E-mail: slvtransformer20@gmail.com	25kVA, star1 rated, Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	16.02.2026		
		63kVA, star1 rated, Distribution Transformers, CRGO core, 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	14.04.2027		
		100kVA, star2 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-2 as per new amendment 4 of IS-1180)	25.11.2025	BESCOM/GM(QS&S)/AE/BC-11/2022-23/CYS-21 dtd: 21.06.2022 (subject to revalidation once in 2 years)	
		250kVA, star2 rated, Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-2 as per new amendment 4 of IS-1180)	08.02.2026		
40	M/s Vijayashree Power, Sy No. 113, NH-206, Behind Byraveshwara Petrol Bunk, Nittur, Gubbi Tq, Tumkur Dist-572223	25kVA, star1 rated, Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026. (EEL-1 as per new amendment 4 of IS-1180)	17.05.2026	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-25 dtd: 05.07.2022	

	Ph No: 9986261445/8904465178 E-mail: vijayashreepower@gmail.com	100kVA, star2 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026. (EEL-2 as per new amendment 4 of IS-1180)	20.01.2026	(subject to revalidation once in 2 years)
41	M/s Siliguri Electric Works, Khaprali Road (1/2 KM from khaprali More), P.O. Nirmal, (Matigara), Darjeeling – 734010 Ph No: 9933066620/9733309977 E-mail: sew@gmail.com/ siligurielectricworks@yahoo.com	25kVA, 63kVA, 100kVA star1 rated, Distribution Transformers, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026. (EEL-1 as per new amendment 4 of IS-1180) 250kVA & 500kVA star1 rated, Distribution Transformers, CRGO Core, Copper wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026. (EEL-1 as per new amendment 4 of IS-1180)	13.07.2023	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-31 dtd: 18.07.2022
42	M/s R.V.Transformer manufacturing Co., D-14/A, Industrial Area, Lokikere Road, Davangere-577 005 E-mail: rvtransformer.mfgco@yahoo.in Ph:9448119142, 9980728611	25kVA, 63kVA & 100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026. 25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	29.07.2023 17.02.2026	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-56 dtd: 15.09.2022 BESCOM/GM(QS&S)/DGM-3/AE/BC-11/2022-23/CYS-56 dtd: 15.09.2022 (Subject to revalidation once in 2 years)
43	M/s Supreme Power Technologies, Sy no:191, Kurubarahalli, Tavarekere Post/Hobli, Tavarekere, Bangalore - 562130 Ph:9880295333,9480220911 E-mail: supremepoweri@gmail.com	100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Vendor Approval 25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 63kVA & 250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound,	22.02.2026 (Subject to revalidation once in 2 years) 25.08.2023	GM(QS&S)DGM(EL.-)3/AE/BC-11/ 22-23/ Cys-46 dated: 25.08.2022 GM(QS&S)DGM(EL.-)3/AE/BC-11/ 22-23/ Cys-46 dated: 25.08.2022
44	M/s Viji Power Transformers Pvt Ltd Plot No: 21, Metha Industrial Estate, Machohalli, Magadi Main Road, Bangalore. Contact No: 9900111089 E-mail: vijitechdinakar10@yahoo.com	100kVA ,250kVA & 500kVA star2 rated (EEL-3/5star) Distribution Transformers, 50Hz, CRGO Core, 100kVA star2 rated(EEL-3/5 star)Distribution Transformers, 50Hz, Amorphous Core 25kVA & 63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound	10.12.2023 14.04.2027 29.06.2027	GM(QS&S)DGM(EL.-)3/BC-11/ 19-20/Cys-47 dated: 15.06.2019 (Subject to revalidation every year) GM(QS&S)DGM(EL.-)3/AE/BC-11/ 22-23/Cys-52 dated: 09.09.2022 (subject to revalidation once in 2 years)
45	M/s Vijay Transformer Viduth Company No:4, Survey No.63/1 & 63/2, Karibobhanahalli, Thigalarapalya Village, Peenya 2nd stage, Bangalore - 560058 Ph:9886824635/9900126914 E-mail: vijaytransformer2020@gmail.com	63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound 25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 100kVA & 250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound,	20.06.2023 17.02.2026 17.05.2026 03.03.2026	GM(QS&S)/DGM-3/BC-11/21-22/CYS-33 dated: 05.07.2021 GM(QS&S)DGM(EL.-)3/AE/BC-11/ 22-23/Cys-53 dated: 09.09.2022 (Subject to revalidation once in 2 years)
46	M/s Dynalektric Equipment Private Limited, #49/2, Vaderamanchanahalli Village, Kallu balu to anekal Road, Jigani Hobli, Anekal Taluk, Bengaluru (Bangalore) Urban, Karnataka - 560105 Ph :91(80)29611999 E-mail:info@dynalektric.com	250kVA 2Star Rated(EEL-2), Distribution Transformers, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026. 25kVA & 63kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026. Vendor Approval 100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	10.02.2026 14.07.2026 09.09.2023	GM(QS&S)/DGM-3/BC-11/22-23/CYS-55 dated: 13.09.2022 (Subject to revalidation once in 2 years)
		25kVA, 63kVA & 100kVA EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	01.08.2027 25.01.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-60 dtd:19.09.2022 (Subject to revalidation once in 2 years) GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-130 dtd:10.02.2023 (Subject to revalidation once in 2 years)

47	M/s Vijay Vidyuth Udyog #10, Survey No: 168/1, Machohalli, Dasanapura Hobli, Magadi Road, Bengaluru -560 091. Ph no: 966345451/ 9341225120 & 9341225512 Email:info@vijayvidyuth.com	63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	25.01.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-130 dtd:10.02.2023 (Subject to revalidation once in 2 years)
		100 kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	25.01.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-130 dtd:10.02.2023 (Subject to revalidation once in 2 years)
		250 kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	25.01.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-130 dtd:10.02.2023 (Subject to revalidation once in 2 years)
		500 kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	28.02.2028	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-07 dtd:21.04.2023 (Subject to revalidation once in 2 years)
48	M/s Macro Power Controls, No.24, 2nd cross, Kadabagere cross, Magadi Main Road, Behind Bus Stop, Bangalore - 560091. E-mail: dmaacropower@yahoo.in Ph:8792708263/8792708264/8792708267/8861954803	25kVA, 63kVA & 100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	03.11.2023	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-76 dtd:03.11.2022
		Renewal of Vendor Approval		
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	10.02.2027 (Subject to revalidation once in 2 years)	
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	28.09.2023	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-101 dtd:02.01.2023 (Subject to revalidation once in 2 years)
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	25.09.2023	
		250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	13.10.2027	
500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	22.11.2027			
49	M/s Flow Line Transformers Private Limited, No.82/3B, B.H.Road, Basavanahalli, Nalamangala, Bangalore - 562123 Ph No: 918027724092/27723938 Email:sales@flowlinetransformers.com	25kVA, 63kVA & 100kVA EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	29.10.2026	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-84 dated: 28.11.2022 (Subject to revalidation once in 2 years)
		200kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	19.07.2026	
		100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	11.08.2023	
		500kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.		
50	M/s Sri Shanhaveera Transformers MFG. Co., Basavanapura Main Road, Swathanthranagar, Opp. SEA college, Virgonagar Post, Bangalore - 560049. Ph No: 080-95436753/ 9844469813 E-mail: shanhaveeraa@yahoo.com	25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	01.08.2027	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-117 dated:19.01.2023 (Subject to revalidation once in 2 years)
		25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	25.01.2028 (Subject to revalidation once in 2 years)	
		63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	04.02.2028 (Subject to revalidation once in 2 years)	
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	10.02.2028 (Subject to revalidation once in 2 years)	

51	<p>M/s Vijay Electric Co., #146/117/34/3, Kadabagere Village, Dasanapura Hobli, Bangalore-562130. Ph No: 91 9886406701 / 9886606764. Email: info@vijayelectric.com, sales@vijayelectric.com</p>	<p>25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>1000kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS-1180 & IS- 2026.</p>	<p>04.07.2024</p> <p>20.10.2027 (Subject to revalidation once in 2 years)</p> <p>16.05.2027 (Subject to revalidation once in 2 years)</p> <p>01.11.2027 (Subject to revalidation once in 2 years)</p> <p>07.01.2024</p> <p>23.08.2023</p>	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-131 dated:13.02.2023	
52	<p>M/s Chaitanya Electric Company, Sy No: 60/2, Seegehalli, Magadi Main Road, Bangalore - 560112. Ph no: 9606260808 Email: chaitanyaelectric@rediffmail.com</p>	<p>25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>250kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>500kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p>	<p>12.01.2026 (Subject to revalidation once in 2 years from the date of issue of this OM)</p> <p>12.12.2027 (Subject to revalidation once in 2 years from the date of issue of this OM)</p> <p>25.02.2028 (Subject to revalidation once in 2 years from the date of issue of this OM)</p> <p>01.03.2024</p> <p>08.12.2023</p> <p>01.12.2027 (Subject to revalidation once in 2 years from the date of issue of this OM)</p> <p>03.01.2028 (Subject to revalidation once in 2 years from the date of issue of this OM)</p>	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-25 dated:24.05.2023	
		<p>250kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>500kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p> <p>25kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.</p>	<p>06.01.2025</p> <p>07.11.2024</p> <p>18.02.2028</p>	GM(QS&S)/DGM(EI)-3/BC-11/20-21/CYS-13 dtd:12.05.2020 (Subject to revalidation every year)	<p>06.01.2025 GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-45 dtd:27.06.2023</p> <p>07.11.2024 GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-45 dtd:27.06.2023</p>

53	M/s Raj power Controls, No.116/7 & 117/6, mookambika Temple Road, Machohalli forest gate, Magadi Main road, Bangalore - 560091, Mob:9611146656,9886260538, Email:rajpowers@live.com, rajeshrgowda@gmail.com	63kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	20.02.2028	GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-44 dtd:27.06.2023 (Subject to revalidation once in 2 years from the date of issue of this OM)
		100kVA, EEL-1 (1star rated), Distribution Transformer as per new amendment 4 of IS 1180, CRGO Core, Aluminium wound 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	28.03.2028	
		25kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.		
		63kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	20.02.2028	
		100kVA, EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	26.04.2028	