

**HT , LT U.G. cables & PVC insulated Al wire**

Sl.No	Name of the firm	particulars	Valid upto	O.M.No. & Date	Revalidated upto		
1	M/s. Chandresh Cables Ltd, G-6, New Madhavpura market, Near Police Commissioner Office, Ahmedabad-380004 Factory Unit: Block No.1108, Chhatral Taluka Kalol Dist, Gandhinagar - 382729 Gujrat (E-mail: sales@avocab.com, sangameshbc@avocab.com) (Ph No: 91-79-25623055, 25623056, 25623057)(Mob: 9901491011)	11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2)					
		3CX240sq.mm (55 GI Wires - 3.15mm Dia)	17.02.2025	GM(QS&S)/DGM-3/BC-11/20-21/CYS-69 dtd:11.08.2020. (Subject revalidation every year)			
		3CX400sq.mm (51 GI Wires - 4mm Dia)					
		HT XLPE UG cable	11kV, 3x95 sqmm HT XLPE UG cable	31.12.2021	GM(Q,S&S)DGM - 4/BC-11/17-18 /cys-39 dated:19.05.2017 (Subject revalidation every year)	14.11.2020 GM(Q,S&S)DGM -3/BC-11/19-20 /cys-155 dated: 18.11.2019	
		Copper control cables 1.1kV class					
		1.1 kV 4x2.5sqmm Control cables	1.1 kV 4x6 sqmm Control cables	29.06.2021		14.11.2020 vide CYS-155 dtd:18.11.2019	
		19C x 2.5sqmm armoured cable with standed copper conductor(control cable)				30.10.2020	30.10.2020 vide CYS-155 dtd:18.11.2019
		1.1kV LT, XLPE, PVC extruded Inner Sheath armoured LT UG cable as per IS-7098-part 1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975					
		4C x 16Sq mm,(11 GI Strips - 4.0 x 0.8mm)	4C x 25Sq mm,(13 GI Strips - 4.0 x 0.8mm)	24.10.2024	GM(Q,S&S)DGM - 3/BC-11/19-20/Cys-182 dated:27.12.2019 (subject to Revalidation every year)		
		3.5C x 95Sq mm,(21 GI Strips - 4.0 x 0.8mm)					
		3.5C x 185Sq mm, (28 GI Strips - 4.0 x 0.8mm)	3.5C x 400Sq mm,(39 GI Strips - 4.0 x 0.8mm)				
		3.5C x 70Sq mm,(18 GI Strips - 4.0 x 0.8mm)					
		3.5C x 150Sq mm, (25 GI Strips - 4.0 x 0.8mm)	3.5C x 240Sq mm,(30 GI Strips - 4.0 x 0.8mm)	24.10.2024	GM(QS&S)/DGM-3/BC-11/20-21/CYS-69 dtd:11.08.2020. (Subject revalidation every year)		
		3.5C x 300 Sqmm, (32 GI Strips - 4.0 x 0.8mm)					
		4C x 10 Sqmm, (10 GI Strips - 4.0 x 0.8mm)					
		1.1KV Class HR (Heat Resistant) PVC Insulated & UnSheathed Aluminium Wires Multistrand Single core Lead wires as per IS- 694: 2010					
		PVC Wire - 25 Sqmm Al Wt: 6.7 Kgs, Total Wt: 11.5Kgs for 100Mtrs	PVC Wire - 240 Sqmm Al Wt: 63.5 Kgs, Total Wt: 87Kgs for 100Mtrs	18.01.2025	GM(QS&S)/DGM-3/BC-11/20-21/CYS-69 dtd:11.08.2020. (Subject revalidation every year)		
		2	M/s Universal Cables Limited, P.O. Birla, Vikas, Satna, Madhya Pradesh	11 kV, 3Cx400 sq.mm XLPE HT UG Cable	31.12.2020	GM(Q,S&S)DGM - 3/BC-11/15-16/Cys-133 dated:28.12.2015(subject to Revalidation every year)	31.12.2020 vide CYS-147 dtd:08.11.2019
				11 kV, 3C X 95 sq.mm XLPE HT UG Cable	28.02.2021	GM(Q,S&S)DGM - 3/BC-11/15-16/cys-13 dated:05.05.2016(subject to Revalidation every year)	Ravalidated upto 08.11.2020 vide cys-147dated: 08.11.2019
11 kV, 3C X 240 sq.mm XLPE HT UG Cable	31.01.2021						

3	M/s SBEE Cables (India), Ltd, No:29, J.C.W Industrial estate Kanakapura Road, B'lore-64 (Ph No: 080-26662172, 26860166)	PVC insulated, Unsheathed Aluminium wires, single core multistrand,LT Lead wire, 1.1kV class ,			BESCOM/GM(QS&S)/DGM (Ele)-3/BC-11/19-20/CYS- 90 dtd:16.08.2019	
		1C x 95 Sq. mm	08.03.2021		14.08.2020	
		1C x 120 Sq. mm	08.03.2021			
		1C x 185 Sq. mm	09.03.2021			
		1C x 240 Sq. mm	09.03.2021			
		LT XLPE, Copper/Aluminium UG cable (armoured)				
		3C x 2.5 Sq. mm	07.03.2021	GM(Q,S&S)DGM - 4/BC-11/16-17/cys- 27 dated:03.06.2016 ( subject to revalidation every year)	14.08.2020	
		4C x 10 Sq.mm	07.03.2021			
		3.5C x 50 Sq. mm	30.04.2021			
		3.5C x 95 Sq. mm	30.04.2021			
		3.5C x 185sq.mm	27.02.2021			
		3.5C x 240 Sq.mm	30.04.2021			
		4C x 16 Sq.mm	30.04.2021			
		LT PVC AL UG Cable (Armoured)				
		3.5C x 50 Sq. mm	29.04.2021			
		4C x 16 Sq.mm	30.04.2021			
		4Cx 95 Sq. mm	31.08.2020			
		4C x 400 Sq. mm	01.05.2020		14.08.2020	
		Copper Control Cable				
		4C x 2.5 Sq. mm	12.05.2020		31.08.2020	
		4C x 6.0 Sq. mm	12.05.2020		01.05.2020	
		19C x 2.5 Sq.mm	12.01.2020		12.05.2020	
					12.01.2020	
11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2)						
3CX95sq.mm (54 GI Wires - 2.5mm Dia)	19.08.2024	GM(Q,S&S)DGM - 3/BC-11/19-20/cys- 95 dated:23.08.2019 ( subject to revalidation every year)	19.12.2022 GM(Q,S&S)DGM -3/BC- 11/20-21/cys-193 dated:21.12.2020			
3CX240sq.mm (55 GI Wires - 3.15mm Dia)						
3CX400sq.mm (51 GI Wires - 4mm Dia)						
1.1kV class HR (Heat Resistant) PVC Insulated & Unsheathed Aluminium wires multistrand single core lead wire as per IS-694:2010						
PVC Wire - 16 Sqmm Al Wt: 4.2 Kgs, Total Wt: 7.5Kgs for 100Mtrs	13.01.2025	GM(Q,S&S)DGM - 3/BC-11/19-20/cys- 204 dated:03.02.2020 ( subject to revalidation every year)				
PVC Wire - 25 Sqmm Al Wt: 6.7 Kgs, Total Wt: 11.5Kgs for 100Mtrs						
11kV 3C x 95 sq. mm. HT XLPE UG cable	31.08.2025	GM(Q,S&S)DGM - 3/BC-11/20-21/CYS- 153 dtd:02.11.2020 (Subject revalidation every year)				
11kV 3x240 sq. mm HT XLPE UG cable						
11kV 3C x 400 sq. mm. HT XLPE UG cable	02.01.2022	GM(Q,S&S)DGM - 4/BC-11/17-18/cys- 274 dated:21.02.2018 (Subject revalidation every year)	29.10.2021 GM(QS&S)/DGM-3/BC- 11/20-21/CYS-154 dtd: 02.11.2020			
1.1kV LT, XLPE PVC extruded Inner Sheath armoured LT UG cable as per IS-1554 (Part-1) or IS-7098 Part-1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975						
6 Sqmm, 2Core,(24 GI wire - 1.4mm)	05.10.2022					
10Sqmm, 2Core,(9GI Strips - 4.0 x 0.8mm)						
10Sqmm, 4Core,(10 GI Strips- 4.0 x 0.8mm)						
16 Sqmm, 2Core,(9 GI Strips - 4.0 x 0.8mm)						
16 Sqmm, 4 Core,(11 GI Strips - 4.0 x 0.8mm)						
25 Sqmm, 2 Core,(12 GI Strips - 4.0 x 0.8mm)						
25 Sqmm, 3.5 Core,(12 GI Strips - 4.0 x 0.8mm)						
25 Sqmm, 4 Core,(13 GI Strips - 4.0 x 0.8mm)						
35 Sqmm, 3.5Core,(14 GI Strips - 4.0 x 0.8mm)						
35 Sqmm, 4 Core,(15 GI Strips - 4.0 x 0.8mm)						
4	M/s Polycab India Ltd., (Formerly Polycab Wires Limited) 74/8-9, Daman Indl Estate Village, Kadalya, Daman and 67-72 Noorpura, Tal- Halol. B-78, No:18, 4th Main Road, KSSIDC Industrial Estate, 6th block, Rajajinagar, Bangalore - 560010. Contact No: 8017036678 E-mail: kumar.gaurav@polycab.com					

		50 Sqmm, 3.5 Core, (16 GI Strips - 4.0 x 0.8mm)			
		50 Sqmm, 4 Core, (17 GI Strips - 4.0 x 0.8mm)			
		70 Sqmm, 3.5 Core, (18 GI Strips - 4.0 x 0.8mm)			
		95 Sqmm, 3.5 Core, (21 GI Strips - 4.0 x 0.8mm)			
		120 Sqmm, 3.5 Core, (23 GI Strips - 4.0 x 0.8mm)			
		150 Sqmm, 3.5 Core, (25 GI Strips - 4.0 x 0.8mm)			
		185 Sqmm, 3.5 Core, (28 GI Strips - 4.0 x 0.8mm)			
		240 Sqmm, 3.5 Core, (30 GI Strips - 4.0 x 0.8mm)			
		300 Sqmm, 3.5 Core, (32 GI Strips - 4.0 x 0.8mm)			
		400 Sqmm, 3.5 Core, (39 GI Strips - 4.0 x 0.8mm)			
5	M/s Gloster Cables Limited, Sy No: 310/E, NH-7, Kallakal Village, Toopran Mandal, Dist., Medak (A.P)-502334 (Ph No: 91 8454250511/12, 250769/71) (E-mail: info@glostercable.com)	11kV 3C x 240 sq.mm HT XLPE UG Cable	04.04.2022	GM(Q,S&S)DGM - 4)/BC-11/17-18 /cys-26 dated:12.05.2017 (Subject revalidation every year)	04.04.2021 GM(QS&S)/DGM-3/BC-11/20-21/CYS-78 dtd:14.08.2020
		11kV 3C x 400 sq.mm HT XLPE UG Cable			
		11kV 3C x 95 sq.mm HT XLPE UG Cable	20.06.2021	GM(Q,S&S)DGM - 4)/BC-11/17-18 /cys-133 dated:16.09.2017 (Subject revalidation every year)	20.06.2021 GM(QS&S)/DGM-3/BC-11/20-21/CYS-78 dtd:14.08.2020
6	M/s Havells India Ltd., 5 <sup>th</sup> Floor, The estate, # 121-Dickenson road, Bangalore-560 042 ( Factory unit: A-461/462 & SP-215, MIA, Alwar, Rajasthan)	11kV 3x95 sq. mm XLPE UG cable	17.03.2022	GM(Q,S&S)DGM - 4)/BC-11/17-18 /cys-28 dated:17.05.2017 (Subject revalidation every year)	Revalidated vide cys-70 dated: 18.07.2019
		11kV 3x 240 sq. mm XLPE UG cable	23.01.2022		
		LT XLPE AB cable of size 3C x 35 + 25 sq mm ( Insulated Messenger)	28.01.2021	GM(QS&S)/DGM-4/BC-11/17-18/CYS-51 dtd:05.06.2017 (Subject to revalidation every year)	
		Armoured LT UG Cable 1.1kV class			
		3.5x 400sq mm	29.04.2019		
		3.5x25sq mm	20.07.2022		
		4x25sq mm	28.04.2019	GM(Q,S&S)DGM - 4)/BC-11/17-18 /cys-140 dated:21.09.2017 (Subject revalidation every year)	
		4x16sqmm	20.12.2021		
		11kV HT XLPE UG Cable			
		3x400sq mm	08.07.2019		
		1.1kV LT, XLPE, PVC extruded Inner Seath armoured UG LT cable as per IS-7098-part 1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975			
		2C x 10 sq mm (9 GI Strips - 4.0 x 0.8mm)	20.12.2021		GM(Q,S&S)DGM - 3)/BC-11/18-19/cys-69 dated:18.07.2019 (Subject revalidation every year)
		4C x 10 sq mm (10 GI Strips - 4.0 x 0.8mm)	10.01.2024		
		3.5C x 35 sq mm (14 GI Strips - 4.0 x 0.8mm)	31.01.2024		
		4C x 50 sq mm (17 GI Strips - 4.0 x 0.8mm)	20.12.2021		
		3.5C x 95 sq mm (21 GI Strips - 4.0 x 0.8mm)	10.01.2024		
		3.5C x 150 sq mm (25 GI Strips - 4.0 x 0.8mm)	29.01.2024		
		3.5C x 185 sq mm (28 GI Strips - 4.0 x 0.8mm)	11.01.2024		
		3.5C x 240 sq mm (30 GI Strips - 4.0 x 0.8mm)	10.01.2024		

		11kV, 3 Core, HTUG Cable pressure extruded, inner sheath ROUND WIRE ARMORED as per IS-7098 (Part-2)			
		3C x 400 Sq mm, (51 GI Wires - 4mm Dia)	12.07.2024		
7	M/s Dynamic Cables Ltd., H-581-A-592-A, Road No:6. VKI Area, Jaipur - 302013	11kV, 3 x 95 sq. mm HT XLPE UG cable	12.09.2022	GM(Q,S&S)DGM - 4)/BC-11/17-18 /cys-163 dated:07.10.2017 (Subject revalidation every year)	GM(QS&S)/DGM(EI)-3/BC-11/20-21/CYS-163 dtd:09.11.2020
	11kV, 3 x 240 sq. mm HT XLPE UG cable				
	11kV, 3 x 400 sq. mm HT XLPE UG cable				
8	M/s Insucon cables & Cond(P) Ltd., # 314-A, 3rd Floor, City centre, Sansar chandra Road, Jaipur-302001, Raj(Factory Unit: Road No:5A, F-61-63, Bindayaka Industrial Area, Jaipur-12)	Armoured LT UG Cable 1.1class	30.06.2022	GM(Q,S&S)DGM - 4)/BC-11/17-18 /cys-72 dated:11.07.2017 (Subject revalidation every year)	30.06.2022 GM(QS&S)/DGM-3/BC-11/20-21/CYS-169 dtd:12.11.2020
		4C x 16sq mm			
		3.5C x 95sq mm			
		3.5C x 240sq mm			
		3.5C x 400sq mm			
		4C x 25sq mm			
		PVC Insulatec & Unsheathed Aluminium Wires, Single Core Multistrand 1.1kV class	30.06.2022		
		1C x 16 sqmm			
		1C x 50 sqmm			
		1C x 95 sqmm			
		1C x120 sqmm			
1C x 150 sqmm					
1C x 185 sqmm					
1C x 240 sqmm					
9	M/s GEMSCAB INDUSTRIES LTD., No: 40, Rajasthani Udyog Nagar, G.T Karnal Road, Delhi-110 033 (Factory unit: SP-4-868, RIICO Industrial area, Pathredi (Bhiwadi), P.O Tapukara, Dist, Alwar, Rajasthan) Contact No: 7230085142, 7230085143 E-mail:bhiwadi@gemscab.com	11kV 3C x 95 sq.mm HT XLPE UG Cable	12.05.2021	GM(Q,S&S)DGM - 3)/BC-11/18-19/cys-159 dated:15.07.2016 (Subject revalidation every year)	12.05.2021 GM(QS&S)/DGM-3/BC-11/20-21/CYS-42 dtd:18.06.2020
		11kV 3C x 240 sq.mm HT XLPE UG Cable	10.05.2021		
		11kV 3CX400sq.mm, HT XLPE UG cable	18.01.2024	GM(Q,S&S)DGM - 3)/BC-11/18-19/cys-212 dated:12.03.2019 (Subject revalidation every year)	16.06.2021 GM(QS&S)/DGM-3/BC-11/20-21/CYS-42 dtd:18.06.2020
10	M/s Vishal cables Pvt Ltd., No:56, Gr. Floor, Ashoka Shopping Centre, G.T. Hospital Complex, L.T. Road, Mumbai - 400001 Factory Unit: Plot No: E-41, Addl. Ambernath MIDC, Anandnagar, Ambernath East - 421506, Thane, Maharashtra Contact No: 0251-2620077 (E-mail: vishalcables@gmail.com)	1.1kV Class HR (Heat Resistant) PVC Insulated, Copper Control cables as per IS-554 (Part-1)			
		2 Core, 2.5 Sq mm (18 No GI Wires (1.4mm))	22.04.2024	GM(Q,S&S)DGM -3)/BC-11/19-20/cys-64 dated:11.07.2019 (Subject revalidation every year)	
		4 Core, 2.5 Sq mm, (21 No GI Wires (1.4mm))			
		19 Core, 2.5 Sq mm, (36 No GI Wires (1.6mm))			
		2 Core, 6 Sq mm, (24 No GI Wires (1.4mm))			
		4 Core, 16 Sq mm, (30 No GI Wires (1.6mm))			
		1.1kV LT, XLPE, PVC extruded Inner Sheath armoured UG LT cable as IS-7098-part 1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975	22.04.2024		
		2C x 6 Sq mm,(24 GI wire - 1.4mm)			
		4C x 16 Sq mm, (11 GI Strips - 4.0 x 0.8mm)			
		3.5C x 95 Sq mm, (21 GI Strips - 4.0 x 0.8mm)			
		3.5C x 400 Sq mm, (39 GI Strips - 4.0 x 0.8mm)			

11	M/s Torrent Cables Limited, Yoginagar, Mission Road, Nadiad - 387002 Changed the Company name to :M/s Torrent Power Limited, Yoginagar, Mission Road, Nadiad - 387002 , Gujarat	11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2)				
		3X120sqmm (57 GI Wires - 2.5mm Dia)	26.12.2019	GM(QS&S)/DGM-3/BC-11/19-20/CYS-116 dtd:18.09.2019		
		3CX240sq.mm (55 GI Wires - 3.15mm Dia)	05.10.2022			
3CX400sq.mm (51 GI Wires - 4mm Dia)	20.05.2024					
12	M/s Gupta Power Infrastructure Ltd, EN 62, sector V, 7th Floor, Salt Lake City, kolkatta - 700091. (E-mail: info@guptapower.com, rhino@guptapower.com)	HT XLPE UG Cable			GM(QS&S)/DGM-3/BC-11/17-18/CYS-90 dtd:05.08.2017	13.12.2020 GM(QS&S)/DGM-3/BC-11/19-20/CYS-169 dtd:16.12.2019
		3x95sq mm	12.04.2022			
		3x240sq mm	10.04.2022			
		3x400sq mm	18.04.2022			
		LT XLPE UG Cable				
		3.5x400sq mm XLPE LT UG cable,	15.06.2021			
		3.5x240sq mm XLPE LT UG cable,	15.06.2021			
		3.5x185sq mm, XLPE LT UG cable,	19.07.2021			
		3.5x95sq mm, XLPE LT UG cable	15.06.2021			
		4x16sq mm, XLPE LT UG cable	19.07.2021			
4x10sq mm, XLPE LT UG cable	19.07.2021					
13	M/s KEI Industries Ltd, Okhla industrial Area Phase-1, New Delhi Factory Unit: SP-919/920/922, RIICI Industrial Area, Ph:III, Bhiwadi Distt. Alwar-3010109	HT XLPE UG Cable			GM(QS&S)/DGM-3/BC-11/17-18/CYS-137 dtd:20.09.2017	18.01.2021 GM(QS&S)/DGM-3/BC-11/19-20/CYS-196 dtd:18.01.2020
		3x400sq mm	10.07.2022			
		Armoured XLPE insulated LT UG Cable 1.1kV Class				
		10 Sqmm, 4 Core	29.12.2021			
		16 Sqmm, 2 Core	17.08.2022			
		16 Sqmm, 4 Core	28.12.2021			
		25 Sqmm, 4 Core	03.01.2022			
		35 Sqmm, 3.5 Core	17.08.2022			
		50 Sqmm, 3.5 Core				
		70 Sqmm, 3.5 Core				
		95 Sqmm, 3.5 Core				
		150 Sqmm, 3.5 Core				
		185 Sqmm, 3.5 Core				
		240 Sqmm, 3.5 Core				
		300 Sqmm, 3.5 Core	22.06.2022			
400 Sqmm, 3.5 Core	18.07.2022					
11kV, 3 Core, HTUG Cable for insulations High quality clean XLPE compound shall be used (Free from microvoids, Moisture content, ambers and contaminations) with pressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2) Armouring wires dia in average $\pm$ 2.5% and resistivity 14.0 Ohms/KM (Max) as per IS-3975						
3 x 95 Sqmm, (54 GI Wires - 2.5mm Dia)	29.06.2025 (Subject to revalidation every year)	GM(QS&S)/DGM-3/BC-11/20-21/CYS-56 dtd:03.07.2020				
3 x 240 Sqmm, (55 GI Wires - 3.15mm Dia)						
14	M/s Finolex Cables Limited, 26/27, Mumbai Pune Road, Pimpri, Pune-411 018	11kV 3 x 240 sq.mm XLPE UG Cables	30.10.2020	GM(QS&S)/DGM-3/BC-11/16-17/CYS-18 dtd:28.04.2017	30.10.2020 GM(QS&S)/DGM-3/BC-11/19-20/CYS-187 dtd:01.01.2020	
		11kV 3 x 400 sq.mm XLPE UG Cables				
		11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2)	27.11.2023 (Subject to revalidation every year)	GM(QS&S)/DGM-3/BC-11/19-20/CYS-188 dtd:01.01.2020		
	3CX95sq.mm (54 GI Wires - 2.5mm Dia)					
15	M/s KEC International Limited(Cables Division), Survey No:803, Village: Godampura Taluka - Salvi Dist, Vadodara - 391520.	11kV 3 x 95 sq.mm XLPE UG Cables	03.01.2022	GM(QS&S)/DGM-4/BC-11/18-19/CYS-27 dtd:28.05.2017	23.12.2020 GM(QS&S)/DGM-3/BC-11/19-20/CYS-190 dtd:01.01.2020	
		11kV 3 x 240 sq.mm XLPE UG Cables				
		11kV 3 x 400 sq.mm XLPE UG Cables				
		4 x 240 sq.mm XLPE, LT UG Cable 1.1kV class	28.03.2021			
16	M/s Fortune Art Wires & Cables Pvt Ltd., Plot No: 215/A, phase - II, IDA, Chelapally, Hyderabad - 500051. Ph No: 8374098833. E-mail: smbasha@facables.com	1.1kV LT, XLPE PVC extruded Inner Sheath armoured LT UG cable as per IS-1554 (Part-1) or IS-7098 Part-1, Armouring strip thickness in average $\pm$ 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975	21.11.2024	GM(Q,S&S)DGM -3/BC-11/19-20/cys-205 dated:04.02.2020 (Subject revalidation every year)		
		10Sqmm, 4Core,(10 GI Strips- 4.0 x 0.8mm)				
		16 Sqmm, 4 Core,(11 GI Strips - 4.0 x 0.8mm)				
		25 Sqmm, 3.5 Core,(12 GI Strips - 4.0 x 0.8mm)				
		25 Sqmm, 4 Core,(13 GI Strips - 4.0 x 0.8mm)				
		35 Sqmm, 3.5Core,(14 GI Strips - 4.0 x 0.8mm)				
		50 Sqmm,3.5 Core, (16 GI Strips - 4.0 x 0.8mm)				
		70 Sqmm, 3.5 Core,(18 GI Strips - 4.0 x 0.8mm)				
		95 Sqmm, 3.5 Core,(21 GI Strips - 4.0 x 0.8mm)				
		120 Sqmm, 3.5Core,(23 GI Strips- 4.0 x 0.8mm)				
		150 Sqmm, 3.5 Core, (25 GI Strips-4.0 x 0.8mm)				
		185 Sqmm, 3.5Core,(28 GI Strips - 4.0 x 0.8mm)				
		300 Sqmm, 3.5 Core,(32 GI Strips- 4.0 x 0.8mm)				
		400 Sqmm, 3.5 Core,(39 GI Strips- 4.0 x 0.8mm)				
		1.1kV Class HR (Heat Resistant) PVC Insulated, Copper Control cables as per IS-554 (Part-1)				
		10Core, 2.5 Sqmm, 28 No GI Wires (1.6mm)	13.12.2023			

17	M/s Laser power & Infra Pvt Ltd, 4A, Pollock street, 3rd floor, Kolkata-700001 (Unit-1: Biprannapara, Jalan complex, P.S. Domjur, Hawrah-711411, Unit II: NH-6, Poly Park, Dhulagori, Howrah-711302)	11kV HT XLPE UG cable (Round & Flat Armour)			GM(Q,S&S)DGM -3)/ BC-11/19-20/cys-205 dated:04.02.2020 (Subject revalidation every year)	13.03.2021 GM(Q,S&S)DGM -3)/ BC-11/19-20/cys-225 dated:13.03.2020	
		3C x 400sq mm	09.08.2022				
		3C x 240sq mm	22.11.2021				
		1.1kV LT XLPE UG Cable					
		3.5C x 240sq mm	14.09.2022				
		3.5C x 95sq mm	16.11.2021				
		4C x 16sq mm					
		4C x 10sq mm					
		4C x 50sq mm					
		4C x 6sq mm					
4C x 25sq mm	14.09.2022						
3.5Cx150sq mm	27.05.2020						
Copper Control Cables 1.1kV Class							
4Cx2.5sq mm	03.11.2020						
27.05.2020							
03.11.2020							
18	M/s LKB Engineering Private Limited., Registered Office: 204&205, Shivam House, Karpura, Commercial Complex, New Delhi-15 (Factory Unit: E-418 to E-421, Industrial Area Chopanki, Biwadi Distt. Alwar(Rajasthan)-301019.	1.1kV LT, XLPE PVC extruded Inner Sheath armoured LT UG cable as per IS-1554 (Part-1) or IS-7098 Part-1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975			GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-49 dated:19.06.2020 (Subject revalidation every year)		
		300Sq mm, 3.5Core (32GI Strips - 4.0 x 0.8mm)	05.07.2024				
19	M/s SPM Power & Telecom Pvt Ltd., Regd Office : Plot NoA-28/1/12, Road No.15, I.D.A., Nacharam, Hyderabad - 500076 (Factory Unit: Sy No.245 & 246, Ramanthapur Village, Chegunta, Yelsurthy Mandal) Contact No: 91 40 29702652, 29702657 E-mail: info@spm-cables.in	6.35/11kV 3x95sq mm & 3x240sq mm HT XLPE UG cable		18.09.2025	GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-135 dated:08.10.2020 (Subject revalidation every year)		
20	M/s Apar Industries limited, (Unit Uniflex Cables) No: 301/306, Panorama complex R.C Dutt road, Vadodara 39000 (Factory Unit: Plot no: 158/163, GIDC, Umergaon Dist, Valsad, Gujarat - 396171) (Ph.No91(080)23443932/998604967 8 email-kr.sanjay@apar.com	6.35/11kV HT XLPE UG Cable			GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-140 dated:15.10.2020 ( subject to revalidation every year)		
		3x95 sq.mm, 3x240sq mm & 3x400sq mm, 11kV HT XLPE U.G. Cable		30.07.2025			
21	M/s Prime Cable Industries Pvt Ltd., E-894, 895, D.S.I.I.D.C. Industrial Area, Narela, Delhi - 110040 Ph No:011-27318598, E-mail:info@primecableindia.com, primecableindustries@gmail.com	1.1kV XLPE or Heat resistance PVC Insulated PVC extruded inner sheath Armoured LT UG Cable		11.06.2025	GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-142 dated:17.10.2020 (Subject revalidation every year)		
		2C x 10 sqmm					
		4C x 10sq mm					
		4C x 16sq mm					
		4C x25sq mm					
		4C x 50sq mm					
		4C x 95sq mm					
		3.5C x 50sq mm					
		3.5C x 70 sq mm					
		3.5C x 95 sq mm					
		3.5C x 120 sq mm					
		3.5C x 150sq mm					
		3.5C x 240sq mm					
		1.1kV class Heat Resistant or PVC Insulated and Unsheathed Aluminium Wires Multistrand Single Core Lead Wires'					30.11.2025
		1C x 16 sqmm					
		1C x 25 sqmm					
		1C x 35 sqmm					
		1C x50 sqmm					
1C x 70 sqmm							
1C x 95 sqmm							
1C x 120 sqmm							
1C x 150 sqmm							
1C x 185 sqmm							
1C x 240 sqmm							
22	M/s Shanti Insulated Cable Co., C/o. Arihant Cable Corporation, No:B-24/1, JHILMIL Industrial Area, Shahdara, Delhi - 110095 (Ph No:9311177331)	2C x 4sq mm to 3.5C x 400sq mm PVC Insulated and sheathed armour cable with Aluminium conductor		12.03.2023	GM(Q,S&S)DGM -4)/ BC-11/18-19/cys-06 dated:13.04.2018 (Subject revalidation every year)	12.03.2023 GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-201 dated:23.12.2020	
		2Cx 0.5sq mm to 4C x 185sq mm PVC insulated and sheathed flexible cable of copper conductor					
23	M/s Keli Flex Cables, C/o. Arihant Cable Corporation, No: A-34, 2nd Floor, Jhimil, Indl. Area, Shadara, Delhi - 110095.	1C x 0.5sq mm to 1C x 400sq mm PVC Insulated sheathed flexible cable with copper conductor		23.01.2023	GM(Q,S&S)DGM -4)/ BC-11/18-19/cys-07 dated:13.04.2018 (Subject revalidation every year)	23.01.2023 GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-183 dated:09.12.2020	
		2C x 0.5sq mm to 24C x 0.5sq mm PVC Insulated Unsheathed flexible cable with copper conductor					
24	M/s SPM Power & Telecom Pvt Ltd., Regd Office: Plot No: A-28/1/12, Road No.15, I.D.A., Nacharam, Hyderabad - 500076 (Factory Unit 1: Sy No.245 & 246, Ramanthapur Village, Chegunta, Yeldurthy Mandal-502255, Medan Factory Unit 2: Plot No: 136/2, phase II, I.D.A., Cherlapally, Hyderabad -	11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMoured as per IS-7098 (Part-2)			GM(Q,S&S)DGM -3)/		
		3CX95sq.mm (54 GI Wires - 2.5mm Dia) 3CX240sq.mm (55 GI Wires - 3.15mm Dia)					

	<p>500051)  Contact No:  91 40 29702652, 29702657  E-mail: info@spmcables.in</p>	<p>3C x 400 Sqmm  (51 GI Wires - 4mm Dia)</p>	<p>10.12.2021</p>	<p>BC-11/20-21/cys-186  dated:14.12.2020</p>	
<p>25</p>	<p>M/s Vardhman Cables &amp; Conductors.,  129/C, Shinoli(B.K), Taluk:Chandgad,  Dist :Kolhapur, Maharashtra - 416507  Contact No:  (02320) 236444/ 236482  E-mail: bharatecab@gmail.com</p>	<p>1.1kV LT, XLPE, PVC extruded Inner Sheath  armoured UG LT cable as IS-7098-part 1, Armouring  strip thickness in average ± 5% and resistivity 14  Ohms/Kms (Max) as per IS 3975</p> <p>10 Sqmm, 4 Core,  (10 GI Strips - 4.0 x 0.8mm)  16 Sqmm, 4 Core,  (11 GI Strips - 4.0 x 0.8mm)  95 Sqmm, 3.5 Core,  (21 GI Strips - 4.0 x 0.8mm)  120 Sqmm, 3.5 Core,  (23 GI Strips - 4.0 x 0.8mm)  185 Sqmm, 3.5 Core,  (28 GI Strips - 4.0 x 0.8mm)  240 Sqmm, 3.5 Core,  (30 GI Strips - 4.0 x 0.8mm)  300 Sqmm, 3.5 Core ,  (32 GI Strips - 4.0 x 0.8mm)</p>	<p>29.12.2021</p>	<p>GM(QS&amp;S)DGM(EL.-)3 )  /BC-11/ 20-21/Cys-  205 dated:29.12.2020</p>	