

HT , LT U.G. cables & PVC insulated AI wire

Sl.No	Name of the firm	particulars	Valid upto	O.M.No. & Date	Revalidated upto	
1	M/s. Chandresh Cables Ltd, G-6, New Madhavpura market, Near Police Commissioner Office, Ahmedabad-380004 Factory Unit: Block No.1108, Chhatral Taluka Kalol Dist, Gandhinagar - 382729 Gujrat (E-mail: sales@avocab.com, sangameshbc@avocab.com) (Ph No: 91-79-25623055, 25623056, 25623057)(Mob: 9901491011)	11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMoured as per IS-7098 (Part-2)				
		3CX240sq.mm (55 GI Wires - 3.15mm Dia)	17.02.2025	GM(QS&S)/DGM-3/BC-11/20-21/CYS-69 dtd:11.08.2020. (Subject revalidation every year)	02.09.2023 GM(QS&S)/DGM-3/BC-11/CYS-79 dtd:02.09.2021	
		3CX400sq.mm (51 GI Wires - 4mm Dia)				
		11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMoured as per IS-7098 (Part-2)				
		3CX95sq.mm (54 GI Wires - 2.5mm Dia)	31.12.2026	GM(QS&S)/DGM-3/BC-11/CYS-79 dtd:02.09.2021 (Subject to revalidation once in 2 years)		
		1.1kV Class HR (Heat Resistant) PVC Insulated, Copper Control cables as per IS-554 (Part-1)				
		4 Core, 2.5 Sqmm, 21 No GI Wires (1.4mm)	29.06.2026	GM(QS&S)/DGM-3/BC-11/CYS-79 dtd:02.09.2021 (Subject to revalidation once in 2 years)		
		4 Core, 6 Sqmm, 25 No GI Wires (1.6mm)				
		1.1kV LT, XLPE, PVC extruded Inner Sheath armoured LT UG cable as per IS-7098-part 1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975				
		4C x 16Sq mm,(11 GI Strips - 4.0 x 0.8mm)	24.10.2024	GM(Q,S&S)DGM -3)/BC-11/19-20/Cys-182 dated:27.12.2019 (subject to Revalidation every year)	02.09.2023 GM(Q,S&S)DGM -3)/BC-11/21-22 /Cys-79 dated: 02.09.2021	
		4C x 25Sq mm,(13 GI Strips - 4.0 x 0.8mm)				
		3.5C x 95Sq mm,(21 GI Strips - 4.0 x 0.8mm)				
		3.5C x 185Sq mm, (28 GI Strips - 4.0 x 0.8mm)				
		3.5C x 400Sq mm,(39 GI Strips - 4.0 x 0.8mm)				
		1.1kV LT, XLPE, PVC extruded Inner Sheath armoured LT UG cable as per IS-7098-part 1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975				
		3.5C x 70Sq mm,(18 GI Strips - 4.0 x 0.8mm)	24.10.2024	GM(QS&S)/DGM-3/BC-11/20-21/CYS-69 dtd:11.08.2020. (Subject revalidation every year)	02.09.2023 GM(Q,S&S)DGM -3)/BC-11/21-22 /Cys-79 dated: 02.09.2021	
		3.5C x 150Sq mm, (25 GI Strips - 4.0 x 0.8mm)				
		3.5C x 240Sq mm,(30 GI Strips - 4.0 x 0.8mm)				
3.5C x 300 Sqmm, (32 GI Strips - 4.0 x 0.8mm)						
4C x 10 Sqmm, (10 GI Strips - 4.0 x 0.8mm)						
1.1KV Class HR (Heat Resistant) PVC Insulated & UnSheathed Aluminium Wires Multistrand Single core Lead wires as per IS- 694: 2010						
PVC Wire - 25 Sqmm Al Wt: 6.7 Kgs, Total Wt: 11.5Kgs for 100Mtrs	18.01.2025	GM(QS&S)/DGM-3/BC-11/20-21/CYS-69 dtd:11.08.2020. (Subject revalidation every year)	02.09.2023 GM(Q,S&S)DGM -3)/BC-11/21-22 /Cys-79 dated: 02.09.2021			
PVC Wire - 240 Sqmm Al Wt: 63.5 Kgs, Total Wt: 87Kgs for 100Mtrs						
11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMoured as per IS-7098 (Part-2)						
11kV 3C x 95 sq. mm. (54 GI Wires - 2.5mm dia)	31.08.2025	GM(Q,S&S)DGM -3)/BC-11/20-21/CYS-153 dtd:02.11.2020 (Subject revalidation every year)	20.12.2023 GM(Q,S&S)/AE/BC-11/21-22/CYS-138 dtd:20.12.2021			
11kV 3x240 sq. mm (55 GI Wires - 3.15mm dia)						
11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMoured as per IS-7098 (Part-2)						
3CX400sq.mm (51 GI Wires - 4mm Dia)	02.01.2023	GM(Q,S&S)/AE/BC-11/21-22/CYS-138 dtd:20.12.2021				
1.1kV LT, XLPE PVC extruded Inner Sheath armoured LT UG cable as per IS-1554 (Part-1) or IS-7098 Part-1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975						

2	<p>M/s Polycab India Ltd., (Formerly Polycab Wires Limited) 74/8-9, Daman Indl Estate Village, Kadalya, Daman and 67-72 Noorpura, Tal- Halol. B-78, No:18, 4th Main Road, KSSIDC Industrial Estate, 6th block, Rajajinagar, Bangalore - 560010. Contact No: 8017036678 E-mail: kumar.gaurav@polycab.com</p>	<p>6 Sqmm, 2Core,(24 GI wire - 1.4mm) 10Sqmm, 2Core,(9GI Strips - 4.0 x 0.8mm) 10Sqmm, 4Core,(10 GI Strips- 4.0 x 0.8mm) 16 Sqmm, 2Core,(9 GI Strips - 4.0 x 0.8mm) 16 Sqmm, 4 Core,(11 GI Strips - 4.0 x 0.8mm) 25 Sqmm, 2 Core,(12 GI Strips - 4.0 x 0.8mm) 25 Sqmm, 3.5 Core,(12 GI Strips - 4.0 x 0.8mm) 25 Sqmm, 4 Core,(13 GI Strips - 4.0 x 0.8mm) 35 Sqmm, 3.5Core,(14 GI Strips - 4.0 x 0.8mm) 35 Sqmm, 4 Core,(15 GI Strips - 4.0 x 0.8mm) 50 Sqmm,3.5 Core, (16 GI Strips - 4.0 x 0.8mm) 50 Sqmm, 4 Core, (17 GI Strips - 4.0 x 0.8mm) 70 Sqmm, 3.5 Core,(18 GI Strips - 4.0 x 0.8mm) 95 Sqmm, 3.5 Core,(21 GI Strips - 4.0 x 0.8mm) 120 Sqmm, 3.5Core,(23 GI Strips- 4.0 x 0.8mm) 150 Sqmm, 3.5 Core, (25 GI Strips-4.0 x 0.8mm) 185 Sqmm, 3.5Core,(28 GI Strips - 4.0 x 0.8mm) 240Sqmm, 3.5 Core, (30 GI Strips - 4.0 x 0.8mm) 300 Sqmm, 3.5 Core,(32 GI Strips - 4.0 x 0.8mm) 400 Sqmm, 3.5 Core,(39 GI Strips - 4.0 x 0.8mm)</p>	05.10.2022		<p>05.10.2022 GM(Q,S&S)/AE/BC-11/21- 22/CYS-138 dtd:20.12.2021</p>
3	<p>M/s Havells India Ltd., 5th Floor, the estate, # 121-Dickenson road, Bangalore-560 042, INDIA (Factory Unit: A-461/462 & SP- 215,MIA, Alwar, Rajasthan- 301 030) Contact No: 9036992727 (E- mail:venkataraju.kt@havells.com)</p>	<p>11kV, 3 Core, HT UG Cable pressure extruded, inner sheath ROUND WIRE ARMoured as per IS-7098 (Part-2) 3CX95sq.mm (54 GI Wires - 2.5mm Dia) 3CX240sq.mm (55 GI Wires - 3.15mm Dia) 3C x 400 Sq mm, (51 GI Wires - 4mm Dia) 1.1kV LT, XLPE, PVC exutrated Inner Seath armoured UG LT cable as per IS-7098-part 1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975 2C x 10 sq mm (9 GI Strips - 4.0 x 0.8mm) 4C x 10 sq mm (10 GI Strips - 4.0 x 0.8mm) 16 Sqmm, 4 Core, (11 GI Strips - 4.0 x 0.8mm) 25 Sqmm, 3.5 Core, (12 GI Strips - 4.0 x 0.8mm) 3.5C x 35 sq mm (14 GI Strips - 4.0 x 0.8mm) 4C x 50 sq mm (17 GI Strips - 4.0 x 0.8mm) 3.5C x 95 sq mm (21 GI Strips - 4.0 x 0.8mm) 3.5C x 150 sq mm (25 GI Strips - 4.0 x 0.8mm) 3.5C x185 sq mm (28 GI Strips - 4.0 x 0.8mm) 3.5C x 240 sq mm (30 GI Strips - 4.0 x 0.8mm)</p>	<p>17.03.2022 23.01.2022 12.07.2024 20.12.2021 10.01.2024 20.12.2021 20.07.2022 31.01.2024 20.12.2021 10.01.2024 29.01.2024 11.01.2024 10.01.2024</p>	<p>GM(Q,S&S)DGM -4)/BC- 11/17-18 /cys-28 dated:17.05.2017 (Subject revalidation every year)</p> <p>GM(Q,S&S)DGM -3)/BC- 11/18-19/cys-69 dated:18.07.2019 (Subject revalidation every year)</p>	<p>GM(Q,S&S)DGM -3)/BC- 11/20-21 /cys-255 dated:24.02.2021</p> <p>17.03.2022 23.01.2022 09.02.2023 20.12.2021 09.02.2023 20.12.2021 20.07.2022 09.02.2023 21.12.2021 09.02.2023 09.02.2023 09.02.2023 09.02.2023</p>
4	<p>M/s Dynamic Cables Ltd., H-581-A- 592-A, Road No:6. VKI Area, Jaipur - 302013</p>	<p>11kV, 3 x 95 sq. mm HT XLPE UG cable 11kV, 3 x 240 sq. mm HT XLPE UG cable</p>	12.09.2022	<p>GM(Q,S&S)DGM -4)/BC- 11/17-18 /cys-163 dated:07.10.2017 (Subject revalidation every year)</p>	<p>GM(QS&S)/DGM(EI)-3/BC- 11/20-21/CYS-163 dtd:09.11.2020</p>

		11kV, 3 x 400 sq. mm HT XLPE UG cable		every year	
5	M/s Insucon cables & Cond(P) Ltd., # 314-A, 3rd Floor, City centre, Sansar chandra Road, Jaipur-302001, Raj(Factory Unit: Road No:5A, F-61-63, Bindayaka Industrial Area, Jaipur-12)	Armoured LT UG Cable 1.1class	30.06.2022	GM(Q,S&S)DGM -4)/BC-11/17-18 /cys-72 dated:11.07.2017 (Subject revalidation every year	30.06.2022 GM(QS&S)/DGM-3/BC-11/20-21/CYS-169 dtd:12.11.2020
		4C x 16sq mm 3.5C x 95sq mm 3.5C x 240sq mm 3.5C x 400sq mm 4C x 25sq mm			
6	M/s GEMSCAB INDUSTRIES LTD., No: 40, Rajasthani Udyog Nagar, G.T Karnal Road, Delhi-110 033 (Factory unit: SP-4-868/869, RIICO Industrial area, Pathredi (Bhiwadi), P.O Tapukara, Dist, Alwar, Rajasthan) Contact No: 7230085145, 7230085146 E-mail:bhiwadi@gemscab.com , pathredi@gemscab.com	11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2)	05.07.2026	GM(QS&S)/DGM-3/BC-11/21-22/CYS-32 dtd:05.07.2021 (Subject to revalidation once in 2 years)	
		3CX95sq.mm (54 GI Wires - 2.5mm Dia) 3CX240sq.mm (55 GI Wires - 3.15mm Dia) 3CX400sq.mm (51 GI Wires - 4mm Dia)			
7	M/s Vishal cables Pvt Ltd., No:56, Gr. Floor, Ashoka Shopping Centre, G.T. Hospital Complex, L.T. Road, Mumbai - 400001 Factory Unit: Plot No: E-41, Addl. Ambernath MIDC, Anandnagar, Ambernath East - 421506, Thane, Maharashtra Contact No: 0251-2620077 (E-mail: vishalcables@gmail.com)	1.1kV Class HR (Heat Resistant) PVC Insulated, Copper Control cables as per IS-554 (Part-1)	22.04.2024	GM(Q,S&S)DGM -3)/BC-11/19-20/cys-64 dated:11.07.2019 (Subject revalidation every year)	16.08.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-67 dtd:16.08.2021
		2 Core, 2.5 Sq mm (18 No GI Wires (1.4mm)) 4 Core, 2.5 Sq mm, (21 No GI Wires (1.4mm)) 19 Core, 2.5 Sq mm, (36 No GI Wires (1.6mm)) 2 Core, 6 Sq mm, (24 No GI Wires (1.4mm)) 4 Core, 16 Sq mm, (30 No GI Wires (1.6mm))			
8	M/s Torrent Cables Limited, Yognagar, Mission Road, Nadiad - 387002 Changed the Company name to :M/s Torrent Power Limited, Yognagar, Mission Road, Nadiad - 387002 , Gujarat	11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2)	05.10.2022	GM(QS&S)/DGM-3/BC-11/19-20/CYS-116 dtd:18.09.2019	05.10.2022 GM(QS&S)/DGM-3/BC-11/20-21/CYS-227 dtd:21.01.2021
		3CX240sq.mm (55 GI Wires - 3.15mm Dia) 3CX400sq.mm (51 GI Wires - 4mm Dia)	20.05.2024		19.01.2023 GM(QS&S)/DGM-3/BC-11/20-21/CYS-227 dtd:21.01.2021
9	M/s Gupta Power Infrastructure Ltd., Registered Office: EN-62, Sector V, 7th Floor, Salt Lake City, Kolkatta-700091. Works unit 1: IDOCD centre, khursha 752054, Odisha Works unit 2: Nandanagar Industrial Estate, Kashipur-244713, Uttarakhand E-mail: info@guptapower.com/ rhino@guptapower.com Ph No:91-33-40657348	11kV, 3Core, HT XLPE UG Cable withpressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2)	28.04.2026	GM(QS&S)/DGM-3/BC-11/21-22/CYS-12 dtd:28.04.2021 (Subject to revalidation once in 2 years)	
		3CX95sq.mm (54 GI Wires - 2.5mm Dia) 3CX240sq.mm (55 GI Wires - 3.15mm Dia) 3CX400sq.mm (51 GI Wires - 4mm Dia)			
		1.1kV LT, XLPE PVC extruded Inner Sheath armoured UG LT cable as per IS-1554 (Part-1) or IS-7098 Part-1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS-3975	28.04.2026	GM(QS&S)/DGM-3/BC-11/21-22/CYS-12	

		185Sqmm, 3.5 Core, (28 GI Strips - 4.0 x 0.8mm)		dtd:28.04.2021 (Subject to revalidation once in 2 years)	
		240Sqmm, 3.5 Core, (30 GI Strips - 4.0 x 0.8mm)			
		400Sqmm, 3.5 Core, (39 GI Strips - 4.0 x 0.8mm)	30.05.2023		
10	M/s KEI Industries Ltd, Okhla industrial Area Phase-1, New Delhi Factory Unit: SP-919/920/922, RIICO Industrial Area, Ph:III, Bhiwadi Distt. Alwar-301019, Rajasthan. Tel No: 01493-220106/221731 & 080- 23466260/23466255 Email: mumbai@kei-ind.com, bhiwadi@kei- ind.com & banglore@kei-ind.com	11kV, 3 Core, HTUG Cable for insulations High quality clean XLPE compound shall be used (Free from microvoids, Moisture content, ambers and contaminations) with pressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2) Armouring wires dia in average \pm 2.5% and resistivity 14.0 Ohms/KM (Max) as per IS-3975			
		3 x 95 Sqmm, (54 GI Wires - 2.5mm Dia)	29.06.2025 (Subject to revalidation every year)	GM(QS&S)/DGM-3/BC- 11/20-21/CYS-56 dtd:03.07.2020	07.01.2023 GM(QS&S)/DGM-3/BC-11/20- 21/CYS-214 dtd:08.01.2021
		3 x 240 Sqmm, (55 GI Wires - 3.15mm Dia)			
		3x400sq mm (51 GI wires - 4mm Dia)	24.11.2022	GM(QS&S)/DGM-3/AE/ BC-11/22-23/CYS-14 dtd: 24.05.2022	
		1.1kV LT, XLPE, PVC exutrated Inner Seath armoured UG LT cable as IS-7098-part 1, Armouring strip thickness in average \pm 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975			
		2C x 16 Sq mm (9 GI Strips - 4.0 x 0.8mm)	24.11.2022	GM(QS&S)/DGM-3/AE/ BC-11/22-23/CYS-14 dtd: 24.05.2022	
		4C x 10 Sq mm (10 GI Strips - 4.0 x 0.8mm)			
		4C x 25 Sq mm (13 GI Strips - 4.0 x 0.8mm)			
		3.5C x 50 Sq mm (16 GI Strips - 4.0 x 0.8mm)			
		3.5C x 70 Sq mm (18 GI Strips - 4.0 x 0.8mm)			
3.5C x 95 sq mm (21 GI Strips - 4.0 x 0.8mm)					
3.5Cx 150 sq mm (25 GI Strips - 4.0 x 0.8mm)					
3.5C x185 sq mm (28 GI Strips - 4.0 x 0.8mm)					
3.5C x 240 sq mm (30 GI Strips - 4.0 x 0.8mm)					
3.5C x 300 Sq mm (32 GI Strips - 4.0 x 0.8mm)					
3.5C x 400 Sq mm (39 GI Strips - 4.0 x 0.8mm)					
11	M/s Finolex Cables Limited, 26/27, Mumbai Pune Road, Pimpri, Pune-411 018	11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMOURED as per IS-7098 (Part-2)	27.11.2023 (Subject to revalidation every year)	GM(QS&S)/DGM-3/BC- 11/19-20/CYS-188 dtd:01.01.2020	
		3CX95sq.mm (54 GI Wires - 2.5mm Dia)			
12	M/s KEC International Limited(Cables Division), Survey No:803, Village: Godampura Taluka – Salvi Dist, Vadodara – 391520.	11kV, 3 Core, HTUG Cable fwith pressure extruded, inner sheeth ROUND WIRE ARMOURED as per IS-7098 (Part-2)	03.01.2022	GM(QS&S)/DGM-4/BC- 11/18-19/CYS-27 dtd:28.05.2017	03.01.2022 GM(QS&S)/DGM-3/BC-11/20- 21/CYS-218 dtd:11.01.2021
		3Cx95 Sqmm, (54 GI Wires - 2.5mm Dia)			
		3Cx240 Sqmm, (55 GI Wires - 3.15mm Dia)			
		11kV 3 x 400 sq.mm(51 GI Wires - 4mm Dia)			
		16 Sqmm, 4 Core, 1.1kV LT XLPE UG cable (11 GI Strips - 4.0 x 0.8mm)			
		25 Sqmm, 3.5 Core, 1.1kV LT XLPE UG cable (12 GI Strips - 4.0 x 0.8mm)			
		25 Sqmm, 4 Core, 1.1kV LT XLPE UG cable (13 GI Strips - 4.0 x 0.8mm)			
		50 Sqmm, 3.5 Core, 1.1kV LT XLPE UG cable (16 GI Strips - 4.0 x 0.8mm)	08.01.2022	GM(QS&S)/DGM-3/BC- 11/20-21CYS-217 dtd:11.01.2021	

		50 Sqmm, 4 Core, 1.1kV LT XLPE UG cable (17 GI Strips - 4.0 x 0.8mm)			
		95 Sqmm, 3.5 Core, 1.1kV LT XLPE UG cable (21 GI Strips - 4.0 x 0.8mm)			
		240 Sqmm, 3.5 Core, 1.1kV LT XLPE UG cable (30 GI Strips - 4.0 x 0.8mm)			
13	M/s Fortune Art Wires & Cables Pvt Ltd., Plot No: 215/A, phase - II, IDA, Chelapally, Hyderabad - 500051. Ph No: 8374098833. E-mail: smbasha@facables.com	1.1kV LT, XLPE PVC extruded Inner Sheath armoured LT UG cable as per IS-1554 (Part-1) or IS-7098 Part-1, Armouring strip thickness in average \pm 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975 10Sqmm, 4Core,(10 GI Strips- 4.0 x 0.8mm) 16 Sqmm, 4 Core,(11 GI Strips - 4.0 x 0.8mm) 25 Sqmm, 3.5 Core,(12 GI Strips - 4.0 x 0.8mm) 25 Sqmm, 4 Core,(13 GI Strips - 4.0 x 0.8mm) 35 Sqmm, 3.5Core,(14 GI Strips - 4.0 x 0.8mm) 50 Sqmm,3.5 Core, (16 GI Strips - 4.0 x 0.8mm) 70 Sqmm, 3.5 Core,(18 GI Strips - 4.0 x 0.8mm) 95 Sqmm, 3.5 Core,(21 GI Strips - 4.0 x 0.8mm) 120 Sqmm, 3.5Core,(23 GI Strips- 4.0 x 0.8mm) 150 Sqmm, 3.5 Core, (25 GI Strips-4.0 x 0.8mm) 185 Sqmm, 3.5Core,(28 GI Strips - 4.0 x 0.8mm) 300 Sqmm, 3.5 Core,(32 GI Strips- 4.0 x 0.8mm) 400 Sqmm, 3.5 Core,(39 GI Strips- 4.0 x 0.8mm) 1.1kV Class HR (Heat Resistant) PVC Insulated, Copper Control cables as per IS-554 (Part-1) 10Core, 2.5 Sqmm, 28 No GI Wires (1.6mm)	21.11.2024	GM(Q,S&S)DGM -3)/ BC-11/19-20/cys-205 dated:04.02.2020 (Subject revalidation every year)	
			13.12.2023		
14	M/s Laser power & Infra Pvt Ltd, 4A, Pollock street, 3rd floor, Kolkata-700001 (Unit-I: Biprannapara, Jalan complex, P.S. Domjur, Hawrah-711411, Unit II: NH-6, Poly Park, Dhulagori, Howrah-711302)	11kV HT XLPE UG cable (Round & Flat Armour) 3C x 400sq mm 1.1kV LT XLPE UG Cable 3.5C x 240sq mm 4C x 16sq mm 4C x 10sq mm 4C x 50sq mm 4C x 6sq mm 4C x 25sq mm	09.08.2022 14.09.2022 14.09.2022	GM(Q,S&S)DGM -3)/ BC-11/19-20/cys-205 dated:04.02.2020 (Subject revalidation every year)	13.03.2021 GM(Q,S&S)DGM -3)/ BC-11/19-20/cys-225 dated:13.03.2020
15	M/s LKB Engineering Private Limited., Registered Office: 204&205, Shivam House, Karpura, Commercial Complex, New Delhi-15 (Factory Unit: E-418 to E-421, Industrial Area Chopanki, Biwadi Distt. Alwar(Rajasthan)-301019.	1.1kV LT, XLPE PVC extruded Inner Sheath armoured LT UG cable as per IS-1554 (Part-1) or IS-7098 Part-1, Armouring strip thickness in average \pm 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975 300Sq mm, 3.5Core (32GI Strips - 4.0 x 0.8mm)	05.07.2024	GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-49 dated:19.06.2020 (Subject revalidation every year)	
16	M/s Apar Industries limited, (Unit Uniflex Cables) No: 301/306, Panorama complex R.C Dutt road, Vadodara 39000 (Factory Unit: Plot no: 158/163, GIDC, Umergaon Dist, Valsad, Gujarat - 396171) (Ph.No91(080)23443932/9986049678 email-kr.sanjay@apar.com	6.35/11kV HT XLPE UG Cable 3x95 sq.mm, 3x240sq mm & 3x400sq mm, 11kV HT XLPE U.G. Cable	30.07.2025	GM(Q,S&S)DGM -3)/BC-11/20-21/cys-140 dated:15.10.2020 (subject to revalidation every year)	
17	M/s Prime Cable Industries Pvt Ltd., E-894, 895, D.S.I.I.D.C. Industrial Area, Narela, Delhi - 110040 Ph No:011-27318598, E-mail:info@primecabindia.com, primecableindustries@gmail.com	1.1kV XLPE or Heat resistance PVC Insulated PVC extruded inner sheath Armoured LT UG Cable 2C x 10 sqmm 4C x 10sq mm 4C x 16sq mm 4C x25sq mm 4C x 50sq mm 4C x 95sq mm 3.5C x 50sq mm 3.5C x 70 sq mm 3.5C x 95 sq mm 3.5C x 120 sq mm 3.5C x 150sq mm 3.5C x 240sq mm 1.1kV class Heat Resistant or PVC Insulated and Unsheathed Aluminium Wires Multistrand Single Core Lead Wires 1C x 16 sqmm 1C x 25 sqmm 1C x 35 sqmm 1C x50 sqmm 1C x 70 sqmm 1C x 95 sqmm 1C x 120 sqmm 1C x 150 sqmm 1C x 185 sqmm 1C x 240 sqmm	11.06.2025 30.11.2025	GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-142 dated:17.10.2020 (Subject revalidation every year)	04.10.2023 GM(Q,S&S)DGM -3)/ BC-11/21-22/cys-98 dated:04.10.2021 04.10.2023 GM(Q,S&S)DGM -3)/ BC-11/21-22/cys-98 dated:04.10.2021

18	M/s Shanti Insulated Cable Co., C/o. Arihant Cable Corporation, No:B-24/1, JHILMIL Industrial Area, Shahdara, Delhi 110095 (Ph No:9311177331)	2C x 4sq mm to 3.5C x 400sq mm PVC Insulated and sheathed armour cable with Aluminium conductor 2Cx 0.5sq mm to 4C x 185sq mm PVC insulated and sheathed flexible cable of copper conductor	12.03.2023	GM(Q,S&S)DGM -4)/ BC-11/18-19/cys-06 dated:13.04.2018 (Subject revalidation every year)	12.03.2023 GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-201 dated:23.12.2020
19	M/s Keli Flex Cables, C/o. Arihant Cable Corporation, No: A-34, 2nd Floor, Jhimil, Indl. Area, Shadara, Delhi - 110095.	1C x 0.5sq mm to 1C x 400sq mm PVC Insulated sheathed flexible cable with copper conductor 2C x 0.5sq mm to 24C x 0.5sq mm PVC Insulated Unsheathed flexible cable with copper conductor	23.01.2023	GM(Q,S&S)DGM -4)/ BC-11/18-19/cys-07 dated:13.04.2018 (Subject revalidation every year)	23.01.2023 GM(Q,S&S)DGM -3)/ BC-11/20-21/cys-183 dated:09.12.2020
20	M/s SPM Power & Telecom Pvt Ltd., Regd Office : Plot NoA-28/1/12, Road No.15, I.D.A., Nacharam, Hyderabad - 500076 (Factory Unit: Sy No.245 & 246, Ramanthapur Village, Chegunta, Yelsurthy Mandal) Contact No: 91 40 29702652, 29702657 E-mail: info@spm-cables.in	11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMoured as per IS-7098 (Part-2) 3CX95sq.mm (54 GI Wires - 2.5mm Dia) 3CX240sq.mm (55 GI Wires - 3.15mm Dia) 3C x 400 Sqmm (51 GI Wires - 4mm Dia) 1.1kV LT, XLPE PVC extruded Inner Sheath armoured UG LT cable as per IS-1554 (Part-1) or IS-7098 Part-1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS-3975 10 Sqmm, 4 Core, (10 GI Strips - 4.0 x 0.8mm) 16 Sqmm, 4 Core, (11 GI Strips - 4.0 x 0.8mm) 50 Sqmm, 3.5 Core, (16 GI Strips - 4.0 x 0.8mm) 25 Sqmm, 4 Core, (13 GI Strips - 4.0 x 0.8mm) 70 Sqmm, 3.5 Core, (18 GI Strips - 4.0 x 0.8mm) 95 Sqmm, 3.5 Core, (21 GI Strips - 4.0 x 0.8mm) 120 Sqmm, 3.5 Core, (23 GI Strips - 4.0 x 0.8mm) 150 Sqmm, 3.5 Core, (25 GI Strips - 4.0 x 0.8mm) 185 Sqmm, 3.5 Core, (28 GI Strips - 4.0 x 0.8mm) 240 Sqmm, 3.5 Core, (30 GI Strips - 4.0 x 0.8mm) 300 Sqmm, 3.5 Core, (32 GI Strips - 4.0 x 0.8mm) 400 Sqmm, 3.5 Core, (39 GI Strips - 4.0 x 0.8mm)	06.12.2025	GM(Q,S&S)DGM -3)/ BC-11/21-22/cys-129 dated:07.12.2021	
21	M/s Vardhman Cables & Conductors., 129/C, Shinoli(B.K), Taluk:Chandgad, Dist :Kolhapur, Maharashtra - 416507 Contact No: (02320) 236444/ 236482 E-mail: bharatcab@gmail.com	1.1kV LT, XLPE, PVC extruded Inner Sheath armoured UG LT cable as IS-7098-part 1, Armouring strip thickness in average ± 5% and resistivity 14 Ohms/Kms (Max) as per IS 3975 400 Sqmm, 3.5 Core, (39 GI Strips - 4.0 x 0.8mm) 16 Sqmm, 4 Core, (11 GI Strips - 4.0 x 0.8mm) 95 Sqmm, 3.5 Core, (21 GI Strips - 4.0 x 0.8mm) 120 Sqmm, 3.5 Core, (23 GI Strips - 4.0 x 0.8mm) 185 Sqmm, 3.5 Core, (28 GI Strips - 4.0 x 0.8mm) 240 Sqmm, 3.5 Core, (30 GI Strips - 4.0 x 0.8mm) 300 Sqmm, 3.5 Core, (32 GI Strips - 4.0 x 0.8mm)	29.12.2021	GM(QS&S)DGM(EL.)-3 /BC-11/ 20-21/Cys-205 dated:29.12.2020	
		1.1kV Class HR (Heat Resistant) PVC insulated & Unsheathed Aluminium Wires Multistrand Single core Lead wires as per IS - 694: 2010			

22	M/s SBEE Cables (India), Ltd, No:29, J.C.W Industrial estate Kanakapura Road, B'lore-64 (Ph No: 080-26662172, 26860166)	PVC Wire - 16Sqmm Al Wt: 4.2 Kgs, Total Wt: 7.5Kgs for 100Mtrs	22.01.2026	GM(QS&S)/DGM-3/BC-11/20-21/CYS-229 dtd:22.01.2021	
		PVC Wire - 25Sqmm Al Wt: 6.7 Kgs, Total Wt: 11.5Kgs for 100Mtrs			
		PVC Wire - 50Sqmm Al Wt: 13.8 Kgs, Total Wt: 22 Kgs for 100Mtrs			
		PVC Wire - 95Sqmm Al Wt: 25 Kgs, Total Wt: 36Kgs for 100Mtrs			
		PVC Wire - 120Sqmm Al Wt: 32 Kgs, Total Wt: 45.5Kgs for 100Mtrs			
		PVC Wire - 185Sqmm Al Wt: 49 Kgs, Total Wt: 68Kgs for 100Mtrs			
		PVC Wire - 240Sqmm Al Wt: 63.5 Kgs, Total Wt: 87Kgs for 100Mtrs			
		1.1kV Class HR (Heat Resistant) PVC Insulated, Copper Control cables as per IS-554 (Part-1)			
		2Core, 2.5Sqmm, 18 No GI Wires (1.4mm)	22.01.2026	GM(QS&S)/DGM-3/BC-11/20-21/CYS-229 dtd:22.01.2021	
		4Core, 2.5Sqmm, 21 No GI Wires (1.4mm)			
		4Core, 6Sqmm, 25 No GI Wires (1.6mm)			
		4 Core, 10Sqmm, 28 No GI Wires (1.6mm)			
		19Core, 2.5Sqmm, 36 No GI Wires (1.6mm)			
		1.1kV LT, Heat resistant PVC insulated, PVC extruded Inner Seath armoured UG LT cable as per IS-1554 (Part-1) or IS-7098 Part-1,			
		50Sqmm, 3.5 Core, (16 GI Strips - 4.0 x 0.8mm)	22.01.2026	GM(QS&S)/DGM-3/BC-11/20-21/CYS-229 dtd:22.01.2021	
		16Sqmm, 4Core, (11 GI Strips - 4.0 x 0.8mm)			
		25Sqmm, 4Core, (13 GI Strips - 4.0 x 0.8mm)			
		1.1kV LT, XLPE Copper/Aluminium UG cable IS-7098 Part - 1			
		50Sqmm, 3.5 Core, (16 GI Strips - 4.0 x 0.8mm)	22.01.2026	GM(QS&S)/DGM-3/BC-11/20-21/CYS-229 dtd:22.01.2021	
		70Sqmm, 3.5 Core,(18 GI Strips - 4.0 x 0.8mm)			
		95Sqmm, 3.5 Core,(21 GI Strips - 4.0 x 0.8mm)			
		185Sqmm, 3.5 Core,(28 GI Strips - 4.0 x 0.8mm)			
240Sqmm, 3.5 Core, (30 GI Strips - 4.0 x 0.8mm)					
400Sqmm, 3.5 Core,(39 GI Strips - 4.0 x 0.8mm)					
16Sqmm, 4 Core, (11 GI Strips - 4.0 x 0.8mm)					
11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMoured as per IS-7098 (Part-2)	19.08.2024	GM(Q,S&S)DGM -3)/BC-11/19-20/cys-95 dated:23.08.2019 (subject to revalidation every year)	19.12.2022 GM(Q,S&S)DGM -3)/BC-11/20-21/cys-193 dated:21.12.2020		
(54 GI Wires - 2.5mm Dia)					
(55 GI Wires - 3.15mm Dia)					
(51 GI Wires - 4mm Dia)					
23	M/s RR Kabel Limited, Survey No: 202/1, 202/2, 203 & 327/3, P.O. Village Waghodia, khanda Road, Tal. Waghodia - 391760 Dist. Vadodara Contact No: 91-80-41250079/40902221 E-mail: bengaluru.rrkabel@rrglobal.com	1.1kV class HR (Heat Resistant) PVC Insulated & Sheathed Aluminium Single Core Wires as IS- 694:2010	29.07.2022	GM(QS&S)/DGM-3/BC-11/21-22/CYS-50 dtd:29.07.2021	
		2.5sq mm			
		1.1kV LT, XLPE Insulated, PVC Extruded Inner Sheath armoured UG LT cable as per IS-1551 (Part -1) or IS - 7098 Part -1, Armouring Strip, thickness in average ± 5% resistivity 14ohm/kms (Max) as pere IS - 3975			
		50 Sqmm, 4 Core, (17 GI Strips - 4.0 x 0.8mm)			
		240 Sqmm, 3.5 Core, (30 GI Strips - 4.0 x 0.8mm)			
1.1kV LT, XLPE Insulated, PVC Extruded Inner Sheathed armoured UG LT cable as per IS-1551 (Part -1) or IS - 7098 Part -1, Armouring Strip, thickness in average ± 5% resistivity 14ohm/kms (Max) as pere IS - 3975					
	M/e Rantan Cables India Pvt Ltd				

24	<p>M/s DLF Cables Limited Registered Office: Epitome Building No:05, 18th Floor, Tower -B, DLF Cyber City, Gurugram - 122001 (HR) Factory Unit: (Unit-II), A-6 (A), Kaharani Industrial area, Bhiwadi-301019 (Rajasthan) Contact No: 8130299032,8130299001, 8130299003</p>	<p>120Sq mm, 3.5 Core, (23 GI Strips - 4.0 x 0.8mm)</p> <p>185Sq mm, 3.5 Core, (28 GI Strips - 4.0 x 0.8mm)</p> <p>240Sq mm, 3.5 Core, (30 GI Strips - 4.0 x 0.8mm)</p>	29.07.2022	GM(QS&S)/DGM-3/BC-11/21-22/CYS-51 dtd:29.07.2021	
25	<p>M/s Vikas Cable Company, No.13, Haiderpur Delhi - 110088 Contact No: 91-11-27495529 E-mail:info@vikascable.com</p>	<p>1.1kV LT, XLPE Insulated, PVC Extruded Inner Sheathed armoured UG LT cable as per IS-1554 (Part -1) or IS - 7098 Part -1, Armouring Strip, thickness in average ± 5% resistivity 14ohm/kms (Max) as per IS - 3975</p> <p>50 Sqmm, 4 Core, (17 GI Strips - 4.0 x 0.8mm)</p> <p>400 Sqmm, 3.5 Core , (39 GI Strips - 4.0 x 0.8mm)</p> <p>16 Sqmm, 4 Core, (11 GI Strips - 4.0 x 0.8mm)</p> <p>25 Sqmm, 4 Core, (13 GI Strips - 4.0 x 0.8mm)</p> <p>70 Sqmm, 3.5 Core, (18 GI Strips - 4.0 x 0.8mm)</p> <p>95 Sqmm, 3.5 Core, (21 GI Strips - 4.0 x 0.8mm)</p> <p>120 Sqmm, 3.5 Core, (23 GI Strips - 4.0 x 0.8mm)</p> <p>150 Sqmm, 3.5 Core, (25 GI Strips - 4.0 x 0.8mm)</p> <p>185 Sqmm, 3.5 Core, (28 GI Strips - 4.0 x 0.8mm)</p> <p>240 Sqmm, 3.5 Core, (30 GI Strips - 4.0 x 0.8mm)</p> <p>1.1KV Class HR (Heat Resistant) PVC Insulated & UnSheathed Aluminium Wires Multistrand Single core Lead wires as per IS-694: 2010</p> <p>PVC Wire - 50 Sqmm Al Wt: 13.8 Kgs, Total Wt: 22 Kgs for 100Mtrs</p> <p>PVC Wire - 240 Sqmm Al Wt: 63.5 Kgs, Total Wt: 87Kgs for 100Mtrs</p>	07.08.2022	GM(QS&S)/DGM-3/BC-11/21-22/CYS-58 dtd: 07.08.2021	GM(QS&S)/DGM(EI)-3/BC-11/21-22/CYS-167 dtd:21.02.2022 (Subject to first revalidation dated before 17.02.2023 and then it will be revalidated once in 2 years)
26	<p>M/s Rotoplast Wires and Cables, Gala No: 3 & 4, Nr. Shri Ganesh Industrial Estate, Beside Green Masjid, Parmer Talao, Vasai Fata, Vasai (E), Dist. Palghar - 401208 Contact No: 9986672160 Email:rotoplastcables@gmail.com</p>	<p>1.1kV LT, XLPE Insulated, PVC Extruded Inner Sheath armoured UG LT cable as per IS-1554 (Part -1) or IS - 7098 Part -1, Armouring Strip, thickness in average ± 5% resistivity 14ohm/kms (Max) as per IS - 3975</p> <p>10 Sqmm, 4 Core, (10 GI Strips - 4.0 x 0.8mm)</p> <p>16 Sqmm, 4 Core, (11 GI Strips - 4.0 x 0.8mm)</p> <p>25 Sqmm, 3.5 Core, (12 GI Strips - 4.0 x 0.8mm)</p> <p>35 Sqmm, 3.5 Core, (14 GI Strips - 4.0 x 0.8mm)</p> <p>50 Sqmm, 3.5 Core, (16 GI Strips - 4.0 x 0.8mm)</p> <p>70 Sqmm, 3.5 Core, (18 GI Strips - 4.0 x 0.8mm)</p> <p>95 Sqmm, 3.5 Core, (21 GI Strips - 4.0 x 0.8mm)</p> <p>120 Sqmm, 3.5 Core, (23 GI Strips - 4.0 x 0.8mm)</p> <p>150 Sqmm, 3.5 Core, (25 GI Strips - 4.0 x 0.8mm)</p> <p>1.1kV Class HR (Heat Resistant) PVC Insulated, Copper Control cables as per IS-554 (Part-1)</p> <p>2 Core, 2.5 Sqmm, (18 No GI Wires (1.4mm))</p> <p>4 Core, 2.5 Sqmm, (21 No GI Wires (1.4mm))</p> <p>19 Core, 2.5 Sqmm, (36 No GI Wires (1.6mm))</p>	24.09.2022	GM(QS&S)/DGM-3/BC-11/21-22/CYS-92 dtd: 24.09.2021	
27	<p>M/s Gloster Cables Limited, Registered Office: No.183/184, (5-3-370 to 372A) 2nd Floor, Above Mody Motors, Rahttrapathi Road, Secunderabad-500003 Sy No: 310/E, NH-7, Kallakal Village, Toopran Mandal, Dist., Medak (A.P)- 502334 Ph No: 9180-22129305, 91-8454250511/12, 250769/71 Email:gclbanglore@glostercable.com, info@glostercable.com</p>	<p>11kV, 3Core, HT XLPE UG Cable with pressure extruded, inner sheath ROUND WIRE ARMoured as per IS-7098 (Part-2)</p> <p>3CX95sq.mm (54 GI Wires - 2.5mm Dia)</p> <p>3CX240sq.mm (55 GI Wires - 3.15mm Dia)</p>	20.08.2026	GM(QS&S)/DGM-3/BC-11/21-22/CYS-127 dtd: 26.11.2021 (subject to revalidation	

		3CX400sq.mm (51 GI Wires - 4mm Dia)		once in 2 years)	
28	M/s Karnataka Industries, Sy No.130, Shed A-4, Machohalli Industrial Area, Magadi Road, Bangalore - 560091 Contact No: 9902068381 E-mail: bristolcables@yahoo.com	1.1kV Class HR (Heat Resistant) PVC insulated & Unsheathed Aluminium Wires Multistrand Single core Lead wires as per IS - 694: 2010			
		PVC Wire - 16Sqmm Al Wt: 4.2 Kgs, Total Wt: 7.5Kgs for 100Mtrs	30.05.2022	GM(QS&S)/DGM-3/BC-11/21-22/CYS-128 dtd: 30.11.2021	
		PVC Wire - 25Sqmm Al Wt: 6.7 Kgs, Total Wt: 11.5Kgs for 100Mtrs			
29	M/s Paragon Power cable Ltd., Plot No: 60, Phase -1, HSIIDC Industrial Estate, Kundli, Sonipat, Haryana - 131028 Contact No: 91-9810049100 & 9811025711 E-mail: sales@paragoncables.com	1.1KV, LT XLPE, insulated, PVC extruded Inner Sheath armoured UG LT cable, confirming to IS-1554 (Part-1) or IS-7098 Part-1, Armouring strip, thickness in average $\pm 5\%$ and resistivity 14Ohms/Kms (Max) as per IS-3975			
		240 sqmm, 3.5 Core (30 GI Strips - 4.0x0.8mm)	30.12.2025	GM(QS&S)/AE/BC-11/21-22/CYS-145 dtd: 31.12.2021 (Subject to first revalidation dated before 30.12.2022 and then it will be revalidated once in 2 years)	
		16 sqmm, 4 Core (11 GI Strips - 4.0x0.8mm)			