

AB Cables

Sl.No.	Name of the Firm	Cables particulars	Valid Upto	O.M.No. & Date	Revalidated upto
1	M/s Shanti Insulated Cable Co., C/o. Arihant Cable Corporation, No:24/1, JHIMIL Industrial Area, Shahdara, Delhi - 110095 (Ph No:080-22262116, 080-41249050 E-mail:arihantcablesu@gmail.com)	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation 3x95+1x70+1x16 Sq mm Street light (Insulated messenger cum Neutral)	15.03.2024	GM(Q,S&S)DGM -3)/BC-11/18-19/cys-67 dated:16.07.2019 (Subject revalidation every year)	15.03.2024 BESCOM/GM(Q,S&S)DGM -3)/AE/BC-11/22-23/CYS-93 dtd:21.12.2022
2	M/s Vishal cables Pvt Ltd., No:56, Gr. Floor, Ashoka Shopping Centre, G.T. Hospital Complex, L.T. Road, Mumbai - 400001 Factory Unit: Plot No: E-41, Addl. Ambernath MIDC, Anandnagar, Ambernath East - 421506, Thane, Maharashtra Contact No: 0251-2620077 (E-mail: vishalcables@gmail.com)	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation 3x95+1x70+1x35 Sq mm Street light (Insulated messenger cum Neutral)	02.05.2024	GM(Q,S&S)DGM -3)/ BC-11/19-20/cys-64 dated:11.07.2019 (Subject revalidation every year)	16.08.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-67 dtd:16.08.2021
3	M/s Gupta Power Infrastructure Ltd., Registered Office: EN-62, Sector V, 7th Floor, Salt Lake City, Kolkatta-700091. Works unit 1: IDOCD centre, khursha-752054, Odisha Works unit 2: Nandanagar Industrial Estate, Kashipur-244713, Uttarakhand (E-mail: infor@guptapower.com, rhino@guptapower.com) Ph No:91-33-40657348	11kV [6.35/11kV(E)] HT Aerial Bunched Cable for insulations High quality clean XLPE compound shall be used (Free from microvoids, Moisture content, ambers and contaminations) with Metallic screen of EC Grade copper Tape 0.5 mm as per IS-7098(Part-2), 2011 3x95+1x70 Sqmm (Insulated Messenger Wire) 3x120+1x95 Sqmm (Insulated Messenger Wire) 1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995. 3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	28.04.2026 28.04.2026	GM(QS&S)/DGM-3/BC-11/21-22/CYS-12 dtd:28.04.2021 (Subject to revalidation once in 2 years)	
4	M/s SPM Power & Telecom Pvt Ltd., Regd Office: Plot No: A-28/1/12, Road No.15, I.D.A., Nacharam, Hyderabad - 500076 Factory Unit 1: Plot No: 136/2, phase II, I.D.A., Cherlapally, Hyderabad - 500051 Factory Unit 2: Sy No.245 & 246, Chegunta Post, Ramanthapur Village, Yeldurthy Mandal-502255, Medak Dist -502255. Telangana Contact No: 040-27151145/58 & Ph No:9701199990 E-mail: info@spmcables.in	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation 3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	06.12.2025	BESCOM/GM(QS&S)/AE/BC-11/21-22/CYS-129 dtd:07.12.2021 (Subject to revalidation once in 2 years)	06.12.2025BESCOM/GM(QS&S)/AE/BC-11/23-24/CYS-159 dtd:12.01.2024
5	M/s Prime Cable Industries Pvt Ltd., E-894, 895, D.S.I.I.D.C. Industrial Area, Narela, Delhi - 110040 Ph No:011-27318598, E-mail:info@primecabindia.com, primecableindustries@gmail.com	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation Parameter shall be as below 1. Hot Set Test: a) Elongation under Load: 50% (Max) b) Permanent Elongation After Cooling: 3% (Max) 2. Thermal Aging in oven: a) Tensile Strength: 16N/mm ² (Min) b) Elongation: 375% (Min) 3. Water Absorption Test a) Water absorbed: 0.5mg/cm ² (Max) 4. Carbon Black Content shall be ranging from 2% to 3%			
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	11.01.2026	BESCOM/GM(QS&S)/AE/BC-11/21-22/CYS-169 dtd:25.02.2022 (Subject to revalidation once in 2 years)	11.01.2026 BESCOM/GM(QS&S)/AE/BC-11/23-24/CYS-180 dtd: 03.02.2024
6	M/s Insucon Cables & cond.(P)Ltd., #314-A, 3rd Floor, City centre, Sansar Chandra Road, Jaipur - 302001(Raj) & Factory Unit: No:5A, F-61-63, Bindayaka Industrial Area, Jaipur - 12. E-mail: marketing@insuconcables.com	1.1 kV, LT Aerial Bunched Cable, XLPE insulation confirming to IS-14255:1995 3x95 + 1x70 + 1x16 Sqmm Street light (Insulated Messenger cum Neutral)	18.08.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-78 dtd: 08.11.2022 (subject to revalidation once in 2 years)	
	M/s Havells India Ltd.,	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995.			

7	5th Floor, the estate, # 121-Dickenson road, Bangalore-560 042, INDIA Factory Unit: A-461/462 & SP-215, MIA, Alwar, Rajasthan- 301 030 Contact No: 9036992727 E-mail: venkataraju.kt@havells.com/ bangalore.office@havells.com	3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	11.08.2027	BESCOM/GM(QS&S)/DGM- 3/AE/BC-11/22-23/CYS-54 dtd:12.09.2022 (Subject to revalidation once in 2 years)	
		11kV [6.35/11kV(E)] HT Aerial Bunched Cable for insulations High quality clean XLPE compound shall be used (Free from microvoids, Moisture content, ambers and contaminations) with Metallic screen of EC Grade copper Tape 0.5 mm as per IS-7098 (Part-2), 2011			
		3x95+1x70 Sqmm (Insulated Messenger Wire)	25.08.2027		
8	M/s Vikas Cable Company, No.13, Haiderpur Delhi - 110088 Contact No: 91-11-27495529 E-mail: info@vikascable.com	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation	07.12.2025	BESCOM/GM(QS&S)/DGM- 3/AE/BC-11/22-23/CYS-107 dtd:07.01.2023 (Subject to revalidation once in 2 years)	
		3x95+1x70+1x16 Sq mm Street light (Insulated messenger cum Neutral)			
9	M/s Apar Industries Limited, (Unit: Uniflex Cables) No: 301/306, Panorama complex R.C Dutt road, Vadodara 390007 (Factory Unit: Plot No: 158/163, GIDC, Umargaon Dist., Valsad, Gujarat - 396171) Contact No:91(080)23443932 /9986049678 E-mail:kr.sanjaya@apar.com	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255: 1995 XLPE insulation	02.05.2028	BESCOM/GM(QS&S)/DGM- 3/AE/BC-11/22-23/CYS-33 dtd: 12.06.2023 (Subject to revalidation once in 2 years)	
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)			
10	M/s Paragon Power cable Private Limited, Plot No: 60, Phase -1, HSIIDC Industrial Estate, Kundli, Sonapat, Haryana - 131028 Contact No: 91-9810049100 & 9811025711 E-mail: sales@paragoncables.com	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation	01.08.2024	BESCOM/GM(QS&S)/DGM- 3/AE/BC-11/22-23/CYS-69 dtd: 03.08.2023	
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)			
11	M/s Rotoplast Wires and Cables, Gala No: 3 & 4, Nr. Shri Ganesh Industrial Estate, Beside Green Masjid, Parmer Talao, Vasai Fata, Vasai (E), Dist. Palghar - 401208 Contact No: 9986672160 Email:rotoplastcables@gmail.com	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation	02.06.2028	BESCOM/GM(QS&S)/DGM- 3/AE/BC-11/22-23/CYS-71 dtd: 11.08.2023 (Subject to revalidation once in 2 years from the date of issue of this OM)	
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)			
		3x25+1x25+1x16 Sqmm Street light (Insulated messenger cum Neutral)			
12	M/s SBEE cables (India) Ltd, Unit -1, #29, JC Industrial Estate, Kanakapura Road, Bangalore - 560062. Unit 2, #282 & 283, KIADB Industrial Area, Harohalli phase II, kanakapura Taluk, Ramanagara District - 562112 Contact No: 91 80 26662171, 91 80 26860166 E-mail:info@sbeecables.in	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation	01.03.2027	BESCOM/GM(QS&S)/DGM- 3/AE/BC-11/23-24/CYS-111 dtd: 31.10.2023 (Subject to revalidation once in 2 years from the date of issue of this OM)	
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)			
13	M/s Dynamic Cables Ltd, Registered office: F-260, Road No.13, VKI Area, Jaipur-302013 Unit III- H-581A-592A, Road No:6, VKI Area, Jaipur- 302013 Contact No: 911412262589, 4042005 E-mail: info@dynamiccables.co.in	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation	05.01.2028	BESCOM/GM(QS&S)/DGM- 3/AE/BC-11/23-24/CYS-166 dtd: 20.01.2024 Subject to revalidation once in 2 years from the date of issue of this OM	
		3x95+1x70+1x16Sqmm Street light (Insulated messenger cum Neutral)			
14	M/s Paramount Communications Limited, SP-30A, 30B & E-31, RIICO Industrial area, Khushkhera District, Alwar, Rajasthan-301707 Ph No: 91-11-45618800 E-mail: pcl@paramountcables.com	11 kV [6.35/11 kV(E)], HT Aerial Bunched Cable XLPE insulation confirming to IS- 14255: 1995	29.03.2026	BESCOM/GM(QS&S)/DGM-3/AE/BC- 11/22-23/CYS-169 dtd: 25.01.2024	
		3x120 + 1x95 Sqmm (Insulated Messenger Wire)			

15

M/s KEI Industries Ltd, Okhla industrial Area Phase-1, New Delhi Factory Unit: SP-919/920/922,RIICO Industrial Area, Ph.III, Bhiwadi Distt.Alwar-301019, Rajasthan. Tel No: 01493-220106/221731 & 080-23466260/23466255 Email:mumbai@kei-ind.com, bhiwadi@kei-ind.com & banglore@kei-ind.com	1.1kV LT AB Cable			
	1.1kV,3Cx95+1Cx70+1Cx16sqmm XLPE Insulated AB Cable	07.01.2029	GM(QS&S)/DGM-3/BC-11/23- 24/CYS-191 dtd: 14.02.2024 (Subject to revalidation once in 2 years from the date of issue of this OM)	