

## AB Cables

Sl.No.	Name of the Firm	Cables particulars	Valid Upto	O.M.No. & Date	Revalidated upto
1	M/s KEI Industries Ltd, Okhla industrial Area Phase-1, New Delhi Factory Unit: SP-919/920/922, RIICI Industrial Area, Ph.III, Bhiwadi Distt. Alwar-3010109, Rajasthan Tel No:01493-220106/221731, Email:mumbai@kei-ind.com, bhiwadi@kei-ind.com	1.1kV,3Cx95+1Cx70+1C x16 sq mm XLPE Insulated AB Cable	08.01.2024	GM(Q,S&S)DGM -3)/BC-11/19-20 /cys-41 dated:03.06.2019 (Subject revalidation every year)	<b>07.01.2023</b> GM(QS&S)/DGM-3/BC-11/20-21/CYS-214 dtd:08.01.2021
		11kV, 3C x 120 + 1C x 95 sqmm AB cable	07.01.2024		<b>07.01.2023</b> GM(QS&S)/DGM-3/BC-11/20-21/CYS-214 dtd:08.01.2021
2	M/s Shanti Insulated Cable Co., C/o. Arihant Cable Corporation, No:24/1, JHIMIL Industrial Area, Shahdara, Delhi - 110095 (Ph No:080-22262116, 080-41249050 E-mail:arihantcablesu@gmail.com)	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation	15.03.2024	GM(Q,S&S)DGM -3)/BC-11/18-19/cys-67 dated:16.07.2019 (Subject revalidation every year)	<b>15.03.2024</b> BESCOM/GM(Q,S&S)DGM -3)/AE/BC-11/22-23/CYS-93 dtd:21.12.2022
		3x95+1x70+1x16 Sq mm Street light (Insulated messenger cum Neutral)			
3	M/s Vishal cables Pvt Ltd., No:56, Gr. Floor, Ashoka Shopping Centre, G.T. Hospital Complex, L.T. Road, Mumbai - 400001 Factory Unit: Plot No: E-41, Addl. Ambernath MIDC, Anandnagar, Ambernath East - 421506, Thane, Maharashtra Contact No: 0251-2620077 (E-mail: vishalcables@gmail.com)	<b>1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation</b>	02.05.2024	GM(Q,S&S)DGM -3)/ BC-11/19-20/cys-64 dated:11.07.2019 (Subject revalidation every year)	16.08.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-67 dtd:16.08.2021
		3x95+1x70+1x35 Sq mm Street light (Insulated messenger cum Neutral)			
4	M/s Gupta Power Infrastructure Ltd., Registered Office: EN-62, Sector V, 7th Floor, Salt Lake City, Kolkatta-700091. <b>Works unit 1:</b> IDOCD centre, khursha-752054, Odisha <b>Works unit 2:</b> Nandanagar Industrial Estate, Kashipur-244713, Uttarakhand (E-mail: infor@guptapower.com, rhino@guptapower.com) Ph No:91-33-40657348	<b>11kV [6.35/11kV(E)] HT Aerial Bunched Cable for insulations High quality clean XLPE compound shall be used (Free from microvoids, Moisture content, ambers and contaminations) with Metallic screen of EC Grade copper Tape 0.5 mm as per IS-7098(Part-2), 2011</b>	28.04.2026	GM(QS&S)/DGM-3/BC-11/21-22/CYS-12 dtd:28.04.2021 (Subject to revalidation once in 2 years)	
		3x95+1x70 Sqmm (Insulated Messenger Wire)	28.04.2026		
		3x120+1x95 Sqmm (Insulated Messenger Wire)			
		<b>1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995.</b>	28.04.2026		
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)			
5	M/s KEI Industries Ltd, Okhla industrial Area Phase-1, New Delhi Factory Unit: SP-919/920/922,RIICO Industrial Area, Ph.III, Bhiwadi Distt.Alwar-301019, Rajasthan. Tel No: 01493-220106/221731 & 080-23466260/23466255 Email:mumbai@kei-ind.com, bhiwadi@kei-ind.com & banglore@kei-ind.com	<b>1.1kV LT AB Cable</b>		GM(QS&S)/DGM-3/BC-11/21-22/CYS-82 dtd: 24.11.2022 (Subject to revalidation once in 2 years)	
		1.1kV,3Cx95+1Cx70+1Cx16sqmm XLPE Insulated AB Cable	08.01.2024		
		11kV, 3C x 120 + 1C x 95sqmm AB cable	07.01.2024		
6	M/s SPM Power & Telecom Pvt Ltd., Regd Office: Plot No: A-28/1/12, Road No.15, I.D.A., Nacharam, Hyderabad - 500076 Factory Unit 1: Plot No: 136/2, phase II, I.D.A., Cherlapally, Hyderabad - 500051 Factory Unit 2: Sy No.245 & 246, Chegunta Post, Ramanthapur Village, Yeldurthy Mandal- 502255, Medak Dist -502255. Telangana Contact No: 040-27151145/58 & Ph No:9701199990 E-mail: info@spmcables.in	<b>1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation</b>		BESCOM/GM(QS&S)/AE/BC-11/21-22/CYS-129 dtd:07.12.2021 (Subject to revalidation once in 2 years)	
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	06.12.2025		

7	M/s Prime Cable Industries Pvt Ltd., E-894, 895, D.S.I.I.D.C. Industrial Area, Narela, Delhi - 110040 Ph No:011-27318598, E-mail:info@primecabindia.com, primecableindustries@gmail.com	1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation Parameter shall be as below 1. Hot Set Test: a) Elongation under Load: 50% (Max) b) Permanent Elongation After Cooling: 3% (Max) 2. Thermal Aging in oven: a) Tensile Strength: 16N/mm <sup>2</sup> (Min) b) Elongation: 375% (Min) 3. Water Absorption Test a) Water absorbed: 0.5mg/cm <sup>2</sup> (Max) 4. Carbon Black Content shall be ranging from 2% to 3%			
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	11.01.2026	BESCOM/GM(QS&S)/AE/BC-11/21-22/CYS-169 dtd:25.02.2022 (Subject to revalidation once in 2 years)	
8	M/s Insucon Cables & cond.(P)Ltd., #314-A, 3rd Floor, City centre, Sansar Chandra Road, Jaipur - 302001(Raj) & Factory Unit: No:5A, F-61-63, Bindayaka Industrial Area, Jaipur - 12. E-mail: marketing@insuconcables.com	<b>1.1 kV, LT Aerial Bunched Cable, XLPE insulation confirming to IS-14255:1995</b>			
		3x95 + 1x70 + 1x16 Sqmm Street light (Insulated Messenger cum Neutral)	18.08.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-78 dtd: 08.11.2022 (subject to revalidation once in 2 years)	
9	M/s Havells India Ltd., 5th Floor, the estate, # 121-Dickenson road, Bangalore-560 042, INDIA Factory Unit: A-461/462 & SP-215, MIA, Alwar, Rajasthan- 301 030 Contact No: 9036992727 E-mail: venkataraju.kt@havells.com/ bangalore.office@havells.com	<b>1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995.</b>			
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	11.08.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-54 dtd:12.09.2022 (Subject to revalidation once in 2 years)	
		<b>11kV [6.35/11kV(E)] HT Aerial Bunched Cable for insulations High quality clean XLPE compound shall be used (Free from microvoids, Moisture content, ambers and contaminations) with Metallic screen of EC Grade copper Tape 0.5 mm as per IS-7098 (Part-2), 2011</b>			
		3x95+1x70 Sqmm (Insulated Messenger Wire)	25.08.2027		
10	M/s Vikas Cable Company, No.13, Haiderpur Delhi - 110088 Contact No: 91-11-27495529 E-mail: info@vikascable.com	<b>1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation</b>			
		3x95+1x70+1x16 Sq mm Street light (Insulated messenger cum Neutral)	07.12.2025	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-107 dtd:07.01.2023 (Subject to revalidation once in 2 years)	
11	M/s Apar Industries Limited, (Unit: Uniflex Cables) No: 301/306, Panorama complex R.C Dutt road, Vadodara 390007 (Factory Unit: Plot No: 158/163, GIDC, Umargaon Dist., Valsad, Gujarat - 396171) Contact No:91(080)23443932 /9986049678 E-mail:kr.sanjaya@apar.com	<b>1.1KV, LT Aerial Bunched Cable, confirming to IS-14255: 1995 XLPE insulation</b>			
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	02.05.2028	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-33 dtd: 12.06.2023 (Subject to revalidation once in 2 years)	
12	M/s Paragon Power cable Private Limited, Plot No: 60, Phase -1, HSIIDC Industrial Estate, Kundli, Sonipat, Haryana - 131028 Contact No: 91-9810049100 & 9811025711 E-mail: sales@paragoncables.com	<b>1.1KV, LT Aerial Bunched Cable, confirming to IS-14255: 1995 XLPE insulation</b>			
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	01.08.2024	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-69 dtd: 03.08.2023	
13	M/s Rotoplast Wires and Cables, Gala No: 3 & 4, Nr. Shri Ganesh Industrial Estate, Beside Green Masjid, Parmer Talao, Vasai Fata, Vasai (E), Dist. Palghar - 401208 Contact No: 9986672160 Email:rotoplastcables@gmail.com	<b>1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation</b>			
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	02.06.2028	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-71 dtd: 11.08.2023 (Subject to revalidation once in 2 years from the date of issue of this OM)	
		3x25+1x25+1x16 Sqmm Street light (Insulated messenger cum Neutral)			
		3x70 + 1x50 + 1x16 Sqmm Street light (Insulated Messenger cum Neutral)			
14	M/s SBEE cables (India) Ltd, Unit -1, #29, JC Industrial Estate, Kanakapura Road, Bangalore - 560062. Unit 2, #282 & 283, KIADB Industrial Area, Harohalli phase II, kanakapura Taluk, Ramanagara District - 562112 Contact No: 91 80 26662171, 91 80 26860166 E-mail:info@sbeecables.in	<b>1.1KV, LT Aerial Bunched Cable, confirming to IS-14255:1995 XLPE insulation</b>			
		3x95+1x70+1x16 Sqmm Street light (Insulated messenger cum Neutral)	01.03.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-111 dtd: 31.10.2023 (Subject to revalidation once in 2 years from the date of issue of this OM)	