

Compact Sub Station

Sl. No.	Name of the firm	Approved Material	Valid upto	O.M.No. & Date	Revalidated upto
1	M/s ABB India Limited, Regd Off No: 21 floor, World Trade Centre, Brigade Gateway, Malleswaram West, Bangalore. Factory Unit: Plot No:79, MIDC Satpur, Nashik – 422007 Manufactured at: M/s Rajhans Fabrication Pvt Limited, Nasik & M/s Vibha Corporation, Nasik (both system houses of BB India Limited, Nasik) Ph No: 91 80 22949250/ 9972212633 E-mail: krishna-prasad.s@in.abb.com ganapathi.raj@in.abb.com	COMPACT PRE - FABRICATED PACKAGED SUB - STATION as per IEC-60694/IS-3427 Compact Pre - fabricated Packaged Sub-Station 11kV/ 433V consisting 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amorphous Core, Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following outgoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer rating from 100kVA to 1000kVA transformer make: M/s Danish Private Limited/ from any BESCO approved vendor suitable for Compact Sub Station	23.08.2025	GM(Q,S&S)/DGM-3/BC-11/21-22/CYS-69 dtd:23.08.2021 (Subject to revalidation once in 2 years)	
2	M/s Amara Raja Power Systems Limited., Renigunta – Cuddapah Road, Karakambadi – 517520, Tirupati, Andhra Pradesh Ph :8772265000 E-mail: amararaja@amararaja.co.in blrpsd@amararaja.com	Compact Pre - fabricated Packaged Sub - Station 11kv/433V consisting of 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amoprhus Core Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following ougoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer of rating upto 1000kVA from any BESCO Approved Vendor suitable for CSS shall be provided	29.09.2022	GM(Q,S&S)/DGM-3/BC-11/21-22/CYS-94 dtd:29.09.2021	
3	M/s Arrivaa Power System Private Limited., No.96, 80 Feet Ring Road, Pipeline West, Prem Nagar, Laggere, Bangalore-560 058 Factory Unit: #5,8 & 9 MES Road, Sharadamba Nagar, Jalahalli Industrial Area, Bangalore - 560013 Ph : 9538892233 E-mail: sales@arrivaa.in	COMPACT PRE - FABRICATED PACKAGED SUB - STATION as per IEC-60694/IS-3427 Compact Pre - fabricated Packaged Sub-Station Indoor /Outdoor 11kV/ 433V consisting 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amorphous Core, Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following outgoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer of rating 1000kVA used in CSS shall be from BESCO approved vendor suitable for CSS.	31.01.2023	BESCO/GM(Q,S&S)/AE/B C-11/21-22/CYS-151 dtd: 12.01.2022	