

Compact Sub Station

Sl. No.	Name of the firm	Approved Material	Valid upto	O.M.No. & Date	Revalidated upto
1	M/s Schneider Electric Infrastructure Ltd., Milestone -87, Vadodara - Halol Highway village, Kotambi, O.O. Jarod, Taluk Kavav, Dist. Vadodara, Gujarat, E-mail: www.scheider-electric.co.in Ph No:9741312002	11/0.433kV, prefabricated/ Packaged Sub Station(PSS) with LV Switchgear and transformer rating upto 1000kVA	27.02.2021	GM(Q,S&S)/DGM-3/BC-11/19- 20/CYS-217 dtd:04.03.2020	
2	M/s C & S Electric Limited., 26A, Sector-31, Surajpur industrial Area, Kasna Road, Greater Noida- 201310 (U.P.) & Regd office: M/s C & S Electric Limited., 222, Okhla Industrial Estate, phase-III, New Delhi- 110020 Contact No:9900063038 (Tel: +91-11-03088 7520 -29) (E-mail: info@cselectric.co.in)	Compact Pre - fabricated Packaged Sub -Station 11kv/433V consisting of 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amorphous Core Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following outgoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer Make: M/s NGG Power Tech India Pvt Ltd. of rating 1000kVA Distribution Transformer only (with duly valid vendor approval of BESCOM)	20.06.2021	GM(Q,S&S)/DGM-3/BC-11/20- 21/CYS-51 dtd:23.06.2020	
3	M/s Transgear Power Systems Private Limited, Sy No: 49/9, Site No:50A and 50B, 1st Cross, 8th Main, SLV Industrial Estate, Peenya 2nd Stage, Bengaluru Ph No: 9731604488/9731564488 Email: rajju@tgps.in/ santhosh@tgps.in	COMPACT PRE - FABRICATED PACKAGED SUB - STATION as per IEC-60694/IS-3427 Compact Pre - fabricated Packaged Sub-Station Indoor /Outdoor 11kV/ 433V consisting 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amorphous Core, Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following outgoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer Make: M/s Vijay Electric Co.of rating upto 1000kVA/from any BESCOM Approved Vendor suitable for CSS.	01.01.2022	GM(Q,S&S)/DGM-3/BC-11/20- 21/CYS-296 dtd:31.03.2021	
4	M/s Unimag Power Transformer Pvt Ltd., 26/A, II phase, Peenya Industrial Area, Bangalore-560 058 Ph :91(80) 28396184 E-mail:contact@umt.in	COMPACT PRE - FABRICATED PACKAGED SUB - STATION as per IEC-60694/IS-3427 Compact Pre - fabricated Packaged Sub-Station Indoor /Outdoor 11kV/ 433V consisting 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amorphous Core, Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following outgoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer Make: M/s Unimag power transformer (P) Ltd of rating upto 500kVA/ from any BESCOM Approved Vendor suitable for CSS.	31.01.2022	GM(Q,S&S)/Mgr/BC-11/21- 22/CYS-57 dtd:06.08.2021	
5	M/s ABB India Limited, Regd Off No: 21 floor, World Trade Centre, Brigade Gateway, Malleswaram West, Bangalore. Factory Unit: Plot No:79, MIDC Satpur, Nashik - 422007 Manufactured at: M/s Rajhans Fabrication Pvt Limited, Nasik & M/s Vibha Corporation, Nasik (both system houses of BB India Limited, Nasik) Ph No: 91 80 22949250/ 9972212633 E-mail: krishna-prasad.s@in.abb.com ganapathi.raj@in.abb.com	COMPACT PRE - FABRICATED PACKAGED SUB - STATION as per IEC-60694/IS-3427 Compact Pre - fabricated Packaged Sub-Station 11kV/ 433V consisting 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amorphous Core, Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following outgoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer rating from 100kVA to 1000kVA transformer make: M/s Danish Private Limited/ from any BESCOM approved vendor suitable for Compact Sub Station	23.08..2025	GM(Q,S&S)/DGM-3/BC-11/21- 22/CYS-69 dtd:23.08.2021 (Subject to revalidation once in 2 years)	
6	M/s Amara Raja Power Systems Limited., Renigunta - Cuddapah Road, Karakambadi - 517520, Tirupati, Andhra Pradesh Ph :8772265000 E-mail: amararaja@amararaja.co.in blrspds@amararaja.com	Compact Pre - fabricated Packaged Sub - Station 11kv/433V consisting of 3 way SF6/VCB insulated compact RMU, oil cooled CRGO/Amorphous Core Star-2 rated (5-star) Transformer and LT section with one MCCB/ACB as incoming and following ougoing MCCB feeders and with enclosure made of electronically Galvanized steel sheet (min 2 mm Thickness) with powder coated finish, Cu bus bar with LT Metering facility Transformer of rating upto 1000kVA from any BESCOM Approved Vendor suitable for CSS shall be provided	29.09.2022	GM(Q,S&S)/DGM-3/BC-11/21- 22/CYS-94 dtd:29.09.2021	