

Current Transformers & Potential Transformers

Sl.No	Name of the firm	Approved Material	Valid upto	O.M.No. & Date	Revalidated upto
1	M/s Vyoma Switch Gears, Plot No. 28C, II Phase, Near Asian Paints Godown, Peenya Industrial Area, Bangalore,	11kV Metering cubicle(3CT,3PT) with LBS	23.06.2021 (Subject to revalidation every year)	GM(Q,S&S)DGM -4)/BC-11/16-17/cys-49 dated: 28.06.2016 (subject to revalidation every year)	25.09.2020 (cys-125 dated:30.09.2019)
		11kV Metering cubicle (3CT,3PT)			
		11kV Current Transformers of ratios upto 200/1A			
		11kV /110V, 25VA Potential Transformers			
2	M/s K.S. Instruments LLP., No: 72, 3 rd Main, 1 st stage, Industrial suburb, Yeshwantpur, Bangalore-560022	Tape Insulated ring type LT current transformers of ratios up to 800/5A of 0.5 class.	13.12.2021	GM(Q,S&S)DGM -4)/BC-11/16-17/cys-36 dated: 19.05.2017 (subject to revalidation every year)	Revalidated upto 27.06.2020(Cys-57 dated:04.07.2019)
3	M/s Ampturn Electricals ILP., Survey No:7/2, site No:31, Kachohalli Industrial Area, Vishwaneedam Post, Bangalore - 562123 E-mail :info@ampturn.com sumanya@ampturn.com Ph No:9986067517"	LT Current Transformers of ratio up to 800/5A Ring Type, tape Insulated	06.12.2022	GM(Q,S&S)DGM -4)/BC-11/17-18/Cys-273 dated: 20.02.2018 (subject to revalidation every year)	26.07.2020 BESCO/GM(QS&S)/DGM(Ele)-3/BC-11/19-20/CYS-81 dtd:02.08.2019
4	M/s S.K. High Voltage Equipments, No.10&11, S.L.V Industrial Estate, 8th Main, 10th Cross, Andrahalli Main Road, Bangalore-560058	11kV Indoor and Outdoor type, CTs of Ratio from 5/1A to 400/1A, accuracy class:0.2 & 0.2S, 2.5VA/3.75VA	29.12.2022	GM(Q,S&S)DGM -3)/BC-11/17-18/Cys-36 dated: 04.06.2018 (subject to revalidation every year)	Revalidated upto 19.07.2020(Cys-71 dated:19.07.2019)
		LT CTs Indoor type, CTs of Ratio from 50/5A to 400/5A, accuracy class:0.2 & 0.5			
		11kV/ $\sqrt{3}$ /110V/ $\sqrt{3}$, 2.5VA to 50VA, Indoor and Outdoor, Voltage Transformer 0.2 & 0.5 class.			
5	M/s EIC meters private limited, No.30 & 31, Dr Anjaneyappa Industrial Estate, Kanakapura road, Near Delhi Public school, Bangalore- 560 080 Contact No: 9686113478 E-mail: eicmpl@gmail.com.	Tape wound, ring Type LT current transformers of ratio 50/5A & 75/5A, Class 1 & 100/5A to 800/5A of 0.5 class	08.02.2024	GM(Q,S&S)DGM -3)/BC-11/19-20/ Cys-15 dated:29.04.2019 (subject to revalidation every year)	
6	M/s Kalpa Elektrikal Pvt Ltd., No.4413, 149/25, III main, Industrial Town, Rajajinagar, Bangalore - 560073. Contact No: 23303103, 23356049,23405248 E-mail: sales@kalpaelektrikal.com/ info@kalpaelektrikal.com	11kV CT(Secondary – 1A) for 3phase 4wire Metering, Burden:2.5VA,0.2 Accuracy Class Ratio:1.25A to 2.5/1A Ratio: 5/1A to 100/1A Ratio: 125/1A to 200/1A Ratio:225/1A to 400/1A	31.03.2021	GM(Q,S&S)DGM -3)/BC-11/19-20 /Cys-83 dated: 06.08.2019 (subject to revalidation every year)	31.07.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-30 dtd:01.07.2021.
		11kV PT PT 11kV $\sqrt{3}$ /110V/ $\sqrt{3}$, 25VA, single phase Insulation level 15/35/95kV as per IS 3156, 0.2 Accuracy class	31.07.2023		
7	M/s Victory Electrical Industries, #8, Sapthagiri building, sai krupa layout, 1st main road, Thotadagudadahalli, Bangalore – 560073 (Ph No:9342321124, 9741335017, 9902108488) (E-mail:victoryelecindus@gmail.com)	LT current transformers of ratios up to 800/5A	13.06.2022	GM(Q,S&S)DGM -4)/BC-11/17-18/Cys-82 dated: 29.07.2017 (subject to revalidation every year)	03.02.2021 GM(Q,S&S)DGM -3)/BC-11/19-20 /Cys-207 dated: 04.02.2020
8	M/s Santosh Electronics, Shed No.165, 2nd Main, 7th Cross, M.S.R. Nagar, Mathikere Post, Bangalore-560054 (Ph No:9632153842, 9483969002)	Tape Insulated ring type, Resin Cast LT current transformers of ratios 50/5A to 250/5A of 0.5 class	27.06.2022	GM(Q,S&S)DGM -3)/BC-11/17-18/Cys-153 dated: 14.12.2018 (subject to revalidation every year)	27.06.2022 GM(Q,S&S)DGM -3)/BC-11/20-21 /Cys-225 dated: 20.01.2021