

## Current Transformers & Potential Transformers

Sl. No.	Name of the firm	Approved Material	Valid upto	O.M.No. & Date	Revalidated upto
1	M/s EIC meters private limited, No.30 & 31, Dr Anjaneyappa Industrial Estate, Kanakapura road, Near Delhi Public school, Bangalore- 560 080 Contact No: 9686113478 E-mail: eicmpl@gmail.com.	Tape wound, ring Type LT current transformers of ratio 50/5A & 75/5A, Class 1 & 100/5A to 800/5A of 0.5 class	08.02.2024	GM(Q,S&S)DGM -3)/BC-11/19-20/ Cys-15 dated:29.04.2019 ( subject to revalidation every	08.02.2024 GM(QS&S)/DGM-3/BC-11/21-22/CYS-117 dtd:10.11.2021
2	M/s Kalpa Elektrikal Pvt Ltd., No.4413, 149/25, III main, Industrial Town, Rajajinagar, Bangalore - 560073. Contact No: 9945238615/ 23303103 E-mail: sales@kalpaelektrikal.com/ info@kalpaelektrikal.com	11kV PT PT 11kV $\sqrt{3}/110V/\sqrt{3}$ , 25VA, single phase Insulation level 15/35/95kV as per IS 3156, 0.2 Accuracy class	31.07.2023	GM(Q,S&S)DGM -3)/BC-11/19-20 /Cys-83 dated: 06.08.2019 ( subject to revalidation every year)	31.07.2023 GM(QS&S)/DGM-3/BC-11/21-22/CYS-30 dtd:01.07.2021.
		LT current transformers of ratios up to 800/5A	27.10.2023	GM(QS&S)/DGM-3/BC-11/21-22/CYS-111 dtd:08.11.2021	
		LT Current transformers, Indoor, resin cast of ratios 50/1A to 250/1A 2.5VA, 0.2S	05.07.2023	GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-26 dtd:05.07.2022	
		440V/ $\sqrt{3}$ :110V/ $\sqrt{3}$ , single phase Voltage Transformer, Indoor, resin cast, 50Hz, 5VA, 0.2Accuracy			
3	M/s Vyoma Switchgear, Plot No:33/1A, 1st floor, 2nd phase, Peenya Industrial Area, Bangalore- 560058 (Ph No: 9844062416/ 9844302358) (E-mail: vyomas@gmail.com)	11kV Current Transformers of ratio upto 400/1A	16.01.2026	GM(QS&S)/DGM-3/BC-11/20-21/ CYS-222 dated:19.01.2021 (Subject to revalidation once in 2 years)	30.12.2024 BESCOM/GM(QS&S)/DGM-3/BC-11/22-23/ CYS-99 dated: 30.12.2022
		11kV/110V, 25VA Potential Transformer			
4	M/s Paras Power Engineering Pvt Ltd, Plot No: 434, 12th cross, 4th phase, Peenya Industrial area, Bangalore-560 058 Contact No: 080-28364166/ 9916924505 Email:paraspower2001@gmail.com	LT Current transformers, Indoor, resin cast of ratios 50/1A to 250/1A 2.5VA, 0.2S	11.05.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-102 dtd:05.01.2023 (Subject to revalidation once in 2 years)	
		440V/ $\sqrt{3}$ :110V/ $\sqrt{3}$ , single phase Voltage Transformer, Indoor, resin cast, 50Hz, 5VA, 0.2Accuracy			