

Current Transformers & Potential Transformers

Sl. No.	Name of the firm	Approved Material	Valid upto	O.M.No. & Date	Revalidated upto
1	M/s EIC meters private limited, No.30 & 31, Dr Anjaneyappa Industrial Estate, Kanakapura road, Near Delhi Public school, Bangalore- 560 080 Contact No: 9686113478 E-mail: eicmpl@gmail.com.	Tape wound, ring Type LT current transformers of ratio 50/5A & 75/5A, Class 1 & 100/5A to 800/5A of 0.5 class	08.02.2024	GM(Q,S&S)DGM -3/BC-11/19-20/ Cys-15 dated:29.04.2019 (subject to revalidation every	08.02.2024 GM(QS&S)/DGM-3/BC-11/21-22/CYS-117 dtd:10.11.2021
2	M/s Vyoma Switchgear, Plot No:33/1A, 1st floor, 2nd phase, Peenya Industrial Area, Bangalore- 560058 (Ph No: 9844062416/ 9844302358) (E-mail: vyomas@gmail.com)	11kV Current Transformers of ratio upto 400/1A 11kV/110V, 25VA Potential Transformer	16.01.2026	GM(QS&S)/DGM-3/BC-11/20-21/ CYS-222 dated:19.01.2021 (Subject to revalidation once in 2 years)	30.12.2024 BESCOM/GM(QS&S)/DGM-3/BC-11/22-23/ CYS-99 dated: 30.12.2022
3	M/s Paras Power Engineering Pvt Ltd, Plot No: 434, 12th cross, 4th phase, Peenya Industrial area, Bangalore-560 058 Contact No: 080-28364166/ 9916924505 Email:paraspower2001@gmail.com	LT Current transformers, Indoor, resin cast of ratios 50/1A to 250/1A 2.5VA, 0.2S 440V/√3:110V/√3, single phase Voltage Transformer, Indoor, resin cast, 50Hz, 5VA, 0.2Accuracy	11.05.2027	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-102 dtd:05.01.2023 (Subject to revalidation once in 2 years)	
4	M/s Venkat Switchgears, Factory Unit 1: No:150, 10th Main, 3rd Phase, Peenya Industrial Area, Bangalore-560 058 Factory Unit 2: #439 & 440, 12th Main Road, 4th Main phase, Peenya Industrial Area, Bangalore - 560058 Ph No: 080 23722274/9972741545 E-mail: lakshmiathiad@venkatswitchgears.com	11kV CT(Secondary – 1A) for 3phase 4wire Metering, Burden:2.5VA,0.2 Accuracy Class Ratio:1.25A to 2.5/1A Ratio: 5/1A to 100/1A Ratio: 125/1A to 200/1A Ratio:225/1A to 400/1A PT 11 kV/√3/110V/√3, 25 VA, Single phase Insulation level 15/35/95 kV as per IS 3156, 0.2 Accuracy Class 440V/√3:110V/√3, single phase Voltage Transformer, Indoor, resin cast, 50Hz, 5VA, 0.2Accuracy LT Current transformers, Indoor, resin cast of ratios 50/1A to 250/1A 2.5VA, 0.2S	29.06.2028 16.06.2028 23.07.2028 10.07.2028	BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-89 dtd:13.09.2023 (Subject to revalidation once in 2 years)	
5	M/s Kalpa Elektrikal Pvt Ltd., No.4413, 149/25, III main, Industrial Town, Rajajinagar, Bangalore - 560073. Contact No- 9945238615/ 23303103, 23356049, 23405248 E-mail: sales@kalpaelektrikal.com/info@kalpaelektrikal.com	LT Current Transformers of ratios upto 800/5A, 0.5 class, 3.75VA 11kV CT(Secondary – 1A) for 3phase 4wire Metering, Burden:2.5VA, 0.2S Accuracy Class Ratio:1.25/A to 2.5/1A Ratio: 5/1A to 100/1A Ratio: 125/1A to 200/1A Ratio:225/1A to 400/1A 11kV, PT √3/110V/√3, 25VA, single phase Insulation level 15/35/95kV as per IS 3156, 0.2 Accuracy class LT Current transformers, Indoor, resin cast of ratios 50/1A to 250/1A 2.5VA, 0.2S 440V/√3:110V/√3, single phase Voltage Transformer, Indoor, resin cast, 50Hz, 5VA, 0.2Accuracy	07.09.2028 24.02.2026 07.07.2026 24.05.2027 07.06.2027	LT Current Transformers of ratios upto 800/5A, 0.5 class, 3.75VA BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-114 dtd:04.11.2023 Subject to revalidation once in 2 years from the date of issue of this OM	