

## Current Transformers & Potential Transformers

| Sl. No. | Name of the firm   | Approved Material   | Valid upto   | O.M.No. & Date  | Revalidated upto  |
|---------|--|---|--|---|---|
| 1       | M/s EIC meters private limited, No.30 & 31, Dr Anjaneyappa Industrial Estate, Kanakapura road, Near Delhi Public school, Bangalore- 560 080<br>Contact No: 9686113478<br>E-mail: eicmpl@gmail.com.   | Tape wound, ring Type LT current transformers of ratio 50/5A & 75/5A, Class 1 & 100/5A to 800/5A of 0.5 class   | 08.02.2024   | GM(Q,S&S)DGM -3/BC-11/19-20/ Cys-15 dated:29.04.2019 ( subject to revalidation every  | 08.02.2024<br>GM(QS&S)/DGM-3/BC-11/21-22/CYS-117<br>dtd:10.11.2021        |
| 2       | M/s Vyoma Switchgear,<br>Plot No:33/1A, 1st floor, 2nd phase, Peenya Industrial Area,<br>Bangalore- 560058<br>(Ph No: 9844062416/ 9844302358)<br>(E-mail: vyomasg@gmail.com)   | 11kV Current Transformers of ratio upto 400/1A<br><br>11kV/110V, 25VA Potential Transformer   | 16.01.2026   | GM(QS&S)/DGM-3/BC-11/20-21/ CYS-222 dated:19.01.2021 (Subject to revalidation once in 2 years)  | 30.12.2024<br>BESCOM/GM(QS&S)/DGM-3/BC-11/22-23/ CYS-99 dated: 30.12.2022 |
| 3       | M/s Paras Power Engineering Pvt Ltd,<br>Plot No: 434, 12th cross, 4th phase, Peenya Industrial area,<br>Bangalore-560 058<br>Contact No:<br>080-28364166/ 9916924505<br>Email:paraspower2001@gmail.com   | LT Current transformers, Indoor, resin cast of ratios 50/1A to 250/1A<br>2.5VA, 0.2S<br><br>440V/√3:110V/√3, single phase Voltage Transformer, Indoor, resin cast, 50Hz, 5VA, 0.2Accuracy   | 11.05.2027   | BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-102<br>dtd:05.01.2023<br>(Subject to revalidation once in 2 years)                                 |   |
| 4       | M/s Venkat Switchgears,<br>Factory Unit 1:<br>No:150, 10th Main, 3rd Phase,<br>Peenya Industrial Area,<br>Bangalore-560 058<br>Factory Unit 2:<br>#439 & 440,<br>12th Main Road, 4th Main phase,<br>Peenya Industrial Area,<br>Bangalore - 560058<br>Ph No: 080 23722274/9972741545<br>E-mail: lakshmiathiad@venkatswitchgears.com | 11kV CT(Secondary – 1A) for 3phase 4wire Metering, Burden:2.5VA,0.2 Accuracy Class<br>Ratio:1.25A to 2.5/1A<br>Ratio: 5/1A to 100/1A<br>Ratio: 125/1A to 200/1A<br>Ratio:225/1A to 400/1A<br><br>PT 11 kV/√3/110V/√3, 25 VA, Single phase Insulation level 15/35/95 kV as per IS 3156, 0.2 Accuracy Class<br><br>440V/√3:110V/√3, single phase Voltage Transformer, Indoor, resin cast, 50Hz, 5VA, 0.2Accuracy<br><br>LT Current transformers, Indoor, resin cast of ratios 50/1A to 250/1A<br>2.5VA, 0.2S  | 29.06.2028<br><br>16.06.2028<br><br>23.07.2028<br><br>10.07.2028                   | BESCOM/GM(QS&S)/DGM-3/AE/BC-11/22-23/CYS-89<br>dtd:13.09.2023<br>(Subject to revalidation once in 2 years)                                  |   |
| 5       | M/s Kalpa Elektrikal Pvt Ltd., No.4413, 149/25, III main, Industrial Town, Rajajinagar, Bangalore - 560073.<br>Contact No- 9945238615/<br>23303103, 23356049, 23405248<br>E-mail: sales@kalpaelektrikal.com/<br>info@kalpaelektrikal.com   | LT Current Transformers of ratios upto 800/5A, 0.5 class, 3.75VA<br><br><b>11kV CT(Secondary – 1A) for 3phase 4wire Metering, Burden:2.5VA, 0.2S Accuracy Class</b><br>Ratio:1.25/A to 2.5/1A<br>Ratio: 5/1A to 100/1A<br>Ratio: 125/1A to 200/1A<br>Ratio:225/1A to 400/1A<br><br>11kV, PT √3/110V/√3, 25VA, single phase Insulation level 15/35/95kV as per IS 3156, 0.2 Accuracy class<br><br>LT Current transformers, Indoor, resin cast of ratios 50/1A to 250/1A 2.5VA, 0.2S<br><br>440V/√3:110V/√3, single phase Voltage Transformer, Indoor, resin cast, 50Hz, 5VA, 0.2Accuracy | 07.09.2028<br><br>24.02.2026<br><br>07.07.2026<br><br>24.05.2027<br><br>07.06.2027 | BESCOM/GM(QS&S)/DGM-3/AE/BC-11/23-24/CYS-114<br>dtd:04.11.2023<br>Subject to revalidation once in 2 years from the date of issue of this OM |   |