

### H.T. Metering Cubicles & Switchgear Panels

| Sl. No. | Name of the firm  | Material Approved   | Valid upto | O.M.No. & Date  | Revalidated upto   |
|---------|---|---|------------|---|--|
| 1       | M/s Star Switchgears, No: 6-A, 1st Stage, 1st Cross, Sudhamnagar, Lalbagh Road, Bangalore   | 11kV HT Metering Cubicle (3 CT, 3 PT)   | 15.03.2022 | GM(Q,S&S)DGM -4)/BC-11/17-18/Cys-22 dated: 08.05.2017 (Subject revalidation every year)       | 09.05.2020<br>GM(QS&S)/DGM(Ele)-3/BC-11/19-20/CYS-29<br>dtd:15.05.2019<br>11kV HT Metering Cubicle (3 CT, 3 PT)<br>11kV 630A LBS & LBS panel<br>11kV LBS/VCB panel |
|         |   | 11kV Metering Cubicle (3CT, 3PT) with LBS   |            |   |  |
|         |   | 11kV 630A LBS & LBS panel   |            |   |  |
|         |   | 11kV LBS/VCB RMU panel  |            |   |  |
| 2       | New No:16/21, Kachohalli Industrial Area, Dasanapura Hobli, Bangalore - 560091<br>(Ph No: 9902001155/953858886/9742933336)<br>(E mail: omegaswitchgear2018@gmail.com)   | 11kV 3CT & 3PT Metering cubicle with and without LBS Panel  | 18.03.2023 | GM(QS&S)DGM(EI.-)4)/BC-11/17-18/Cys-313 dated:24.03.2018 (Subject to revalidation every year) | 23.09.2021<br>GM(QS&S)/DGM-3/BC-11/20-21/CYS-129 dtd: 24.09.2020<br>11kV, HT Metering Cubicle (3CT, 3PT)<br>11kV 630A LBS Panel<br>11kV VCB Panel                  |
|         |   | 11kV 630A Load Break Switch/LBS Panel   |            |   |  |
|         |   | 11kV LBS RMU Panel  |            |   |  |
|         |   | 11kV VCB Panel  |            |   |  |
| 3       | M/s Royal Power systems Pvt Ltd., No. 35, Behind Siddartha School, Gangondanahalli Main Road, Doddabidirakallu, Bangalore - 73<br>Contact No: 9448803891, 9448495530<br>Email: rpspl.india@gmail.com  | 11kV HT Metering Cubicle (3CT, 3PT)   | 17.02.2024 | GM(Q,S&S)DGM -3)/BC-11/19-20 /Cys-31 dated: 16.05.2019 (Subject revalidation every year)      | 27.11.2022<br>GM(QS&S)/DGM-3/BC-11/20-21/CYS-176 dtd:30.11.2020<br><br>13.03.2022<br>GM(QS&S)/DGM-3/BC-11/20-21/CYS-176 dtd:30.11.2020                             |
|         |   | 11kV, 630A Load Break Switch & LBS Panel  | 13.03.2022 |   |  |
| 4       | M/s Paras Power Engineering Pvt Ltd., Plot No:434, 12th Cross, 4th phase Industrial Area, Bangalore - 560058  | 11kV HT Metering cubicle (3CT, 3PT)   | 24.10.2021 | GM(Q,S&S)DGM -3)/BC-11/19-20/cys-213 dated:24.02.2020 (Subject to Revalidation Every Year)    |  |
|         |   | 11kV CTs(Secondary -1A) for 3phase -4 wire Metering Burden:2.5VA Accuracy Class 0.2 ratio upto 200/1A                     | 30.12.2024 |   |  |
|         |   | PT 11kV/ $\sqrt{3}$ /110V/ $\sqrt{3}$ , 25VA, Single phase Insulation level 15/35/95kV as per IS 3156, Accuracy class 0.2 | 30.12.2024 |   |  |
| 5       | M/s Dev Switchgear, No: 105 & 106, 16th cross, Bairaveswara Industrial Estate, Andrahalli Main Road, Near Shrushruthi bank, Bangalore-560 091   | 11kV HT Metering Cubicle (3 CT, 3 PT)   | 05.08.2024 | GM(Q,S&S)DGM -3)/BC-11/19-20/Cys-107 dated: 04.09.2019  |  |
|         |   | 11kV 630A LBS panel   |            |   |  |
| 6       | M/s LNT Switchgears, #62 & 63, KPTCL Road, Opp. SBM Bank, Kachanayakanahalli, Bommasandra industrial Area, Bangalore-560 099  | 11kV HT Metering cubicle (3CT, 3 PT)  | 04.12.2024 | GM(Q,S&S)DGM -3)/BC-11/19-20/Cys-104 dated: 03.09.2019 (Subject revalidation every year)      |  |
|         |   | 11kV 630A LBS Panel   |            |   |  |
| 7       | M/s Oliver Power Controls, No.47, 100ft Ring Road Near SBI Bank, Jigani Indl. Area, Anekal Taluk, Bangaluru - 560105.<br>E-mail: oliverpowercontrols@gmail.com<br>Ph No:9845612491  | 11kV,HT Metering cubicle (3CT, 3PT)   | 22.08.2024 | GM(Q,S&S)DGM -3)/BC-11/19-20 /Cys-145 dated: 05.11.2019 (Subject revalidation every year)     |  |
|         |   | 11kV Load Break Switch (Make: M/s global switchgear)  |            |   |  |
| 9       | M/s Banashankari Engineers, Plot No.27, Ravi Nagar Main Road, Opp. Akshay Park, Airport Road, Hubballi-580030<br>Contact No:0836-2335463, 2970433<br>Email: banashankarienghl@gmail.com   | 11kV HT Metering cubicle (3CT, 3PT)   | 19.11.2021 | GM(Q,S&S)DGM -3)/BC-11/19-20/cys-162 dated:30.11.2019 (Subject to Revalidation Every Year)    |  |
| 10      | M/s Sringar Switch Gears, D-388, 1st cross, 1st stage, Peenya Industrial Area, Bangalore - 560058<br>(Ph No:9448084539, 080-2839549, 23490984)(E-mail:sringarelectricals@gmail.com)   | 11kV HT Metering Cubicle (3CT, 3PT)   | 27.08.2022 | GM(Q,S&S)DGM -3)/BC-11/19-20/cys-90 dated:09.08.2018 (Subject to Revalidation Every Year)     | 24.02.2021<br>GM(Q,S&S)DGM -3)/BC-11/19-20/cys-215 dated:25.02.2020  |
|         |   | 11kV 630A LBS Panel   |            |   |  |
| 11      | M/s Selmount Power Systems Pvt. Ltd., (Formerly known as Sahayadri Electricals Pvt Ltd.,) Selmount Arcade, No.254/1-6, Behind HDFC Bank, 11th Main Road, 3rd phase, Peenya Industrial area, Bangalore-560058<br>Ph No: 9448260562, 8050060562 (E-mail:sales@selmount.com) | 11kV HT Metering Cubicle (3CT, 3PT)   | 11.12.2022 | GM(Q,S&S)DGM -3)/BC-11/20-21/cys-101 dated:03.09.2020 (Subject to Revalidation Every Year)    |  |
|         |   | 11kV 630A LBS Panel   |            |   |  |
|         | M/s Banavathy Power systems Pvt Ltd., #376A, 10th Cross.  | 11kV HT Metering cubicle (3CT, 3 PT)  |            |   |  |

|    |   |  |            |  |  |
|----|---|--|------------|--|--|
| 12 | 4th main, 4th phase,<br>Peenya Indl. Area,<br>Bangalore- 560058<br>(Ph No: 080-41726440)<br>(E-mail:info@banavathy.com)   | 11kV 630A LBS Panel                            | 07.06.2025 | GM(QS&S)/DGM-3/BC-11/20-21/ CYS-160<br>dated:06.11.2020<br>(Subject to revalidation once in 2 years) |  |
|    |   | 11kV VCB Panel                                 |            |  |  |
|    |   | 11kV Compact Sub station Panel                 | 19.01.2025 |  |  |
| 13 | M/s Venkat Switchgears,<br>No:150, 10th Main, 3rd Phase, Peenya Industrial Area, Bangalore-560 058<br>(Ph No: 080 23722274)<br>(E-mail: lakshmipathiad@venkatswitchgears.com) | 11kV HT Metering cubicle (3CT,3PT)             | 23.12.2024 | GM(QS&S)/DGM-3/BC-11/20-21/ CYS-167<br>dated:11.11.2020<br>(Subject to revalidation once in 2 years) |  |
| 14 | M/s Arrivaa Power System Private Limited, No.96, 2nd Cross, Pipeline Road, Prem Nagar, Laggere, Bengaluru - 560058(Ph No: 9538893330) (E-mail: sales@arrivaa.in)              | 11kV HT Metering cubicle (3CT, 3PT)            | 05.01.2023 | GM(QS&S)/DGM-4/BC-11/1819/ CYS-05 dated:13.04.2018<br>(Subject to revalidation every years)          | 05.01.2023<br>GM(QS&S)/DGM-3/BC-11/20-21/ CYS-213 dated:08.01.2021 |
|    |   | 11kV 630A LBS Panel                            |            |  |  |
|    |   | LT Feeder Pillar Panel                         |            |  |  |
| 15 | M/s Vyoma Switchgear,<br>Plot No:33/1A, 1st floor, 2nd phase, Peenya Industrial Area, Bangalore- 560058<br>(Ph No: 9844062416/ 9844302358)<br>(E-mail: vyomasg@gmail.com)     | 11kV HT Metering Cubicle (3CT 3PT)             | 16.01.2026 | GM(QS&S)/DGM-3/BC-11/20-21/ CYS-222<br>dated:19.01.2021<br>(Subject to revalidation once in 2 years) |  |
|    |   | 11kV LBS Panel                                 |            |  |  |
|    |   | 11kV VCB Panel                                 |            |  |  |
|    |   | 11kV Current Transformers of ratio upto 400/1A |            |  |  |
|    |   | 11kV/110V, 25VA Potential Transformer          |            |  |  |