

# Lightening arrester

Sl.No.	Name of the firm	Approved material	Valid upto	O.M.No. & Date	revalidated upto
1	M/s Raychem RPG(P) Ltd., No.37/7, Ground Floor, Aga Abbas Ali Road, Off Halasur Road, Bangalore-560 042( ph No: 9180-40676666, F-9180-25586039, www.raychemrpg.com	10kV 5kA LA Polymeric type with Ground disconnecter	28.01.2024	GM(QS&S)/DGM-3/BC-11/20-21/CYS-234 dtd: 29.01.2021 (Subject to revalidation once in 2 years)	
2	M/s Orange Power T & D Equipments Pvt Ltd., Regd Off: No: 2, Small Scale Industrial Area, 1st Cross, Rajajinagar, Bangalore -560010 (Factory Unit: No.233, KIADB Industrial Area, 3rd phase, Malur - 563130, (Kolar Dist)). E-mail: orange.power@rediffmail.com. Ph no: 9845243011.	<b>Lightning Arresters as per IEC-60099-4</b>	12.02.2026	GM(QS&S)/DGM-3/BC-11/20-21/CYS-248 dtd: 17.02.2021 (Subject to revalidation once in 2 years)	
		9KV 5kA LA Metal Oxide Ceramic type with GROUND DISCONNECTOR (Dwg No. BESCO/GM/QS&S/26 Dtd 24.11.2018)			
		10KV 5kA LA Polymeric type with GROUND DISCONNECTOR			
3	M/s New Aquaria Electech Pvt Ltd., No.30, Kucharam Industrial Park, Toopran Mandal, Medak, Telangana - 502336 Contact No: 7997248039/ 8806667603 & 9538880209 E-mail: sales@newaquariaelectech.com	9kV, 5kA Lightning Arrester Polymeric type with GROUND DISCONNECTOR	08.03.2024	BESCO/GM(QS&S)/DGM-3/BC-11/AE/22-23/CYS-135 dtd:08.03.2023	
4	M/s SLN Electricals & Saran Insulators private limited, (Formerly Saran Insulators Private Limited) plot No: 39A, KIADB, Hirehalli Industrial Area, Tumakuru-572168 Ph No:7619463611 E-mail:slnele.gm@gmail.com	<b>Lightning Arrester</b>			
		9KV 5kA LA Polymeric type with Ground Disconnecter	19.04.2024	BESCO/GM(QS&S)/DGM-3/BC-11/AE/23-24/CYS-204 dtd:22.02.2024	