



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly Owned Government of Karnataka Undertaking)

No: BESCOM:CGM(O)/DGM(OP-3)/AGM-1/21-22/ 45-134

Corporate Office
K.R. Circle
Bangalore-560 001
Date:

AMENDMENT

- 9 NOV 2021

Sub: Amendment to the Circular issued for arranging Power supply under Sub-Meter Applications including EV Charging Stations with respect to 9th Amendment of Cos and 11th Amendment to ROE of KERC.

Ref: 1) T.O. Circular Dated on CGM(O)/DGM(O)-3/AGM(O)-3/F-332/20-21/CYS-83/28.10.2020
2) Note Approved by DT, BESCOM dated on 18.10.2021

Preamble: This office has issued a circular for adopting the procedures for arranging power supply under Sub-Meter applications including EV Charging stations vide letter cited under reference (1). Further KERC has issued an amendment for arranging Power supply on LT basis up to 150 KVA vide Notification Number KERC/CoS/tech/DDD/05/20-21/976, Bengaluru, dated 11.12.2020

Further, DGM(SG&EV) has requested this office to issue Amendments to the circular vide under ref(1) with respect to provision made under 9th Amendment of CoS and 11th Amendment of RoE

Hence the following amendment.

Sl. No	Scenario	As Existing	As Amended
1.	Fresh Applications	<p>A. In the case, where the applicant is the owner of single domestic installation:</p> <p>d. As per clause No.3.1.1 of KERC up to 34KW (Including Additional Load) can be arranged from licensee network under LT basis.</p> <p>g. If the total load is more than 35KW and less than 99 KW power supply can be arranged under LT tariff but Necessary infrastructure to be developed by applicant.</p>	<p>A. In the case, where the applicant is the owner of single domestic installation:</p> <p>d. As per clause No.3.1.1 (A) & Note (ii) (iii) (iv) (v) of KERC up to 150 KW can be arranged from licensee network under LT basis.</p> <p>g. If the total load is more than 35KW and up to and inclusive of 150 KW power supply can be arranged under LT tariff but Necessary infrastructure to be developed by applicant.</p>



		<p>B. In all other cases</p> <p>b. As per clause No.3.1.1 of KERC up to 34KW (Including Additional Load) can be arranged from licensee network under LT basis.</p> <p>d. If the total load is more than 35KW and less than 99 KW power supply can be arranged under LT tariff but Necessary infrastructure to be developed by applicant and load to the single installation restricted to 99KW..</p>	<p>B. In all other cases</p> <p>b. As per clause No.3.1.1(A) and Note (ii)(iii)(iv)(v) of KERC up to 150 KW can be arranged from licensee network under LT basis</p> <p>d. If the total load is more than 35KW and upto and inclusive of 150KW power supply can be arranged under LT tariff but Necessary infrastructure to be developed by applicant and load to the single installation restricted to 150KW..</p>
2.	Mixed load	<p>b. As per clause No.3.1.1 of KERC up to 34KW (Including Additional Load) can be arranged from licensee network under LT basis.</p> <p>d. If the total load is more than 35KW and up to and less than 99 KW power supply can be arranged under LT tariff but Necessary infrastructure to be developed by applicant and load to the single installation restricted to 50KW.</p>	<p>b. As per clause No.3.1.1(A) and Note (ii)(iii)(iv)(v) of KERC up to 150 KW can be arranged from licensee network under LT basis</p> <p>d. If the total load is more than 35KW and up to and inclusive of 150KW power supply can be arranged under LT tariff but Necessary infrastructure to be developed by applicant and load to the single installation restricted to 150KW.</p>
3.	If Existing installation is HT installation under HT2(a), HT2(b), HT2(c), HT4 tariff.	<p>d. Sub meter can be provided on LT side for the total load not exceeding the 99 KW and power supply restricted to 50 KW for single installation and to be billed under LT6(c) tariff. The Clause 8.14(ii) is applicable defined in CoS of KERC.</p> <p>e. If the total load crosses more than 99 kW power supply can be arranged on HT Basis and to be billed under LT6(c) on HT basis.</p>	<p>d. Sub meter can be provided on LT side for the total load not exceeding the 150 KW and power supply restricted to 150 KW for single installation and to be billed under LT6(c) tariff. The Clause 8.14(ii) is applicable defined in CoS of KERC.</p> <p>e. If the total load crosses more than 150 kW power supply can be arranged on HT Basis and to be billed under LT6(c) on HT basis.</p>


Chief General Manager (Operations)
BESCO

Draft Approved by DT

Copy to:

1. Chief General Manager (CA/I/A), Corporate office, BESCO, Bangalore for information
2. All Chief Engineers, C, O & M Zones, BESCO for information
3. The General Managers (IT/Revenue/F&R/Commercial/M&C/Procurement), corporate office, BESCO, Bangalore for information.
4. All Superintending Engineers, C, O & M Circles, BESCO for information and for needful action
5. DGM (SG&EV) & DGM(RA), Corporate office BESCO
6. All Executive Engineers, C, O & M Divisions & MT Divisions, BESCO for needful action.
7. All Assistant Executive Engineers, C, O & M Sub-Divisions, BESCO for needful action.
8. PS to MD/DT to place before Hon'ble MD/D (T) for kind information. 9) M/f